



City of Ocala

GROWTH MANAGEMENT DEPARTMENT
201 SE 3rd ST, (Second Floor), Ocala, FL 34471
Email: building@ocalafl.org; (352) 629-8421

TENT PERMIT APPLICATION

Please note: Tents greater than 10 x 10 with sides require a permit.
Tents greater than 10 x 20 with or without sides require a permit.
See attached requirements for Consumer Fireworks sales.

Name of Applicant _____

Contact Person _____ Phone _____

E-mail _____

Mailing Address _____

Name of Event/Business _____

Location Address _____

Parcel Number _____

Number of Tents _____ Size of Tent(s) _____

Dates Tent will be in Place _____

Electric Service to Tent No _____ Yes _____ *If Yes, a separate electric permit is required.*

****A Flame Certificate must accompany this application****

I swear or affirm that the above information is true and correct to the best of my knowledge.

Applicant's Signature _____ Date _____

Applicant's Title _____



Ocala Fire Rescue

Fire Prevention Division

Consumer Fireworks Retail

Sales Facilities Requirements

#	REQUIREMENTS	Chapter 65 of NFPA 1
1	One 2.5-gallon water extinguisher and one 2A-10BC fire extinguisher, readily accessible.	(65.10.3.6.3)
2	At least one sign with minimum two-inch-high letters on a contrasting background, shall be conspicuously posted at each entrance or within ten feet of every aisle directly serving the CFRS area in a store that reads as follows: FIREWORKS - NO SMOKING.	(65.10.3.11.2)
3	New CFRS facilities and stores, existing CFRS stands and tents, and temporary CFRS facilities shall not be located within 50 ft. of a motor vehicle fuel-dispensing station.	(65.10.3.12.2)
4	The minimum number of exits provided from the retail sales area shall not be less than two or as determined in accordance with NFPA 1 Chapter 14 and NFPA 101, whichever number is greater.	(65.10.3.14.1.1)
5	Exits shall be marked by an approved sign in accordance with NFPA 1 Chapter 14 and NFPA 101.	(65.10.3.14.5.1)
6	Exit signs shall be self-luminous or internally or externally illuminated.	(65.10.3.14.5.2)
7	The means of egress, including the exit discharge, shall be illuminated whenever the facility is occupied in accordance with NFPA 1 Chapter 14 and NFPA 101.	(65.10.3.14.6)
8	Emergency lighting shall be provided for CFRS facilities and stores and shall comply with NFPA 1 Chapter 14 and NFPA 101.	(65.10.3.14.6.2)
9	The area within 30ft of a CFRS facility shall be kept clear of accumulated dry grass, dry brush, and other combustible debris.	(65.10.4.6.1)
10	No motor vehicle or trailer used for the storage of consumer fireworks shall be parked within 10ft of a CFRS facility, except when delivering, loading, or unloading fireworks or other merchandise and materials used, stored, or displayed for in the facility.	(65.10.4.6.2)
11	At least one sign that reads as follows, in letters at least 4 inches high on a contrasting background, shall be conspicuously posted on the exterior of each side of the CFRS facility: NO FIREWORKS DISCHARGE WITHIN 300 FEET.	(65.10.4.6.3)
12	Exit openings shall be not less than 44 inches.	(65.10.4.8.5)
13	Portable electrical generators shall be located no less than 20ft of a CFRS facility.	(65.10.4.9.2.2)
14	Open flame cooking equipment shall not be located within 50ft and all other types of cooking equipment shall not be permitted within 20ft of tents, canopies, or membrane structures used for the storage, display or sale of consumer fireworks.	(65.10.4.9.3.2)
15	Tent shall be a minimum of twenty (20) feet from the nearest structure, tent or stand.	(65.10.4.7.2)
Definition: Consumer Fireworks Retail Sales Facility (CFRS Facility) – a permanent or temporary building or structure, CFRS stand, tent, canopy or membrane structure that is used primarily for the retail display and sale of consumer fireworks to the public.		
FPF# 110 - AO 2021		