

Appendix A: Grievance Procedure

A-1: City of Ocala Title II Grievance Procedure

A-2: City of Ocala Title II Grievance Form



CITY OF OCALA, FLORIDA GRIEVANCE PROCEDURE UNDER THE AMERICANS WITH DISABILITIES ACT

This Grievance Procedure is established to meet the requirements of the Americans with Disabilities Act of 1990 (ADA). It may be used by anyone who wishes to file a complaint alleging discrimination on the basis of disability in the provision of services, activities, programs, or benefits by the City of Ocala. The City's Personnel Policy governs employment-related complaints of disability discrimination.

The complaint should be in writing and contain information about the alleged discrimination such as name, address, phone number of complainant and location, date, and description of the problem. Alternative means of filing complaints, such as personal interviews or a tape recording of the complaint, will be made available for persons with disabilities upon request.

The complaint should be submitted by the grievant and/or his/her designee as soon as possible but no later than 60 calendar days after the alleged violation to:

Christopher J. Watt, Esq. SHRM-SCP
ADA/504 Coordinator
City Hall, 3rd Floor
110 SE Watula Avenue
Ocala, FL 34471
Office: 352-401-3994
Relay: 7-1-1
cwatt@ocalafl.org

Within 15 calendar days after receipt of the complaint, Christopher J. Watt or his designee will meet with the complainant to discuss the complaint and the possible resolutions. Within 15 calendar days of the meeting, Christopher J. Watt or his designee will respond in writing, and where appropriate, in a format accessible to the complainant, such as large print, Braille, or audio tape. The response will explain the position of the City of Ocala and offer options for substantive resolution of the complaint.

If the response by Christopher J. Watt or his designee does not satisfactorily resolve the issue, the complainant and/or his/her designee may appeal the decision within 15 calendar days after receipt of the response to the City Manager or his/her designee.

Within 15 calendar days after receipt of the appeal, the City Manager or his/her designee will meet with the complainant to discuss the complaint and possible resolutions. Within 15 calendar days after the meeting, the City Manager or his/her designee will respond in writing, and, where appropriate, in a format accessible to the complainant, with a final resolution of the complaint.

All written complaints received Christopher J. Watt or his designee, appeals to the City Manager or his/her designee, and responses from these two (2) offices will be retained by the City of Ocala for at least three (3) years.



OFFICE USE ONLY DATE COMPLAINT OPENED: _____ DATE COMPLAINT CLOSED: _____

CITY OF OCALA, FLORIDA TITLE II ADA GRIEVANCE FORM

Instructions: Please complete and sign the form and email or mail it to the City within 60 calendar days of any incident to:

ADA/504 Coordinator – Christopher J. Watt

Physical address:

Christopher J. Watt, Esq. SHRM-SCP
ADA/504 Coordinator
City Hall, 3rd Floor
110 SE Watula Avenue
Ocala, FL 34471

Phone: 352-401-3994
Email: cwatt@ocalafl.org

1. Type of Grievance (check all that apply):

- Accommodation Request
- Program/Service
- Facility Accessibility
- Other: _____
- _____
- _____

CONTACT INFORMATION

2. Reporting Individual:

Full Name:	
Address:	
City, State, Zip code:	
Phone:	Alternate Phone:
Email:	

3. Authorized Representative of Reporting Individual (if any):

Full Name:	
Address:	
City, State, Zip code:	
Phone:	Alternate Phone:
Email:	

DETAILS OF COMPLAINT / INCIDENT

4. Date/Time of Incident: _____

5. Department/Facility/Location Involved:

6. Describe the incident/complaint with enough detail so the nature of the grievance can be understood. Add additional pages if necessary:

7. Have attempts been made to resolve the complaint through a City Department? If yes, please describe the efforts that have been made.

8. Remedy Sought. What action do you want taken?

Signature

Date

Attach additional pages as necessary. If you need assistance, require an accessible format, or have questions about this form, please contact the City's ADA/504 Coordinator at:

Physical address:

Christopher J. Watt, Esq. SHRM-SCP
ADA/504 Coordinator
City Hall, 3rd Floor
110 SE Watula Avenue
Ocala, FL 34471

Phone: 352-401-3994
Email: cwatt@ocalafl.org

Appendix B: Notice Under the Americans with Disabilities Act

B-1: Current City of Ocala Notice Under the ADA

B-2: Revised City of Ocala Notice Under the ADA

NOTICE UNDER THE AMERICANS WITH DISABILITIES ACT (ADA)

Section 504 of the Rehabilitation Act of 1973, the Americans with Disabilities Act of 1990 ("ADA"), and related federal and state laws and regulations prohibit discrimination against individuals who have disabilities. The City of Ocala will not discriminate against qualified individuals with disabilities in its employment practices, programs, services, or activities.

Employment: The City of Ocala does not discriminate on the basis of disability in its hiring or employment practices and complies with all regulations promulgated by the U.S. Equal Employment Opportunity Commission under Title I of the ADA.

Effective Communication: The City of Ocala will generally, upon request, provide appropriate aids and services leading to effective communication for qualified persons with disabilities so they can participate equally in City of Ocala programs, services, and activities, including qualified sign language interpreters, documents in Braille, and other ways of making information and communications accessible to people who have speech, hearing, or vision impairments.

Modifications to Policies and Procedures: City of Ocala will make all reasonable modifications to policies and programs to ensure that people with disabilities have an equal opportunity to enjoy all of its programs, services, and activities.

- Anyone who would like to request a modification of policies or procedures to participate in a program, service, or activity of the City of Ocala should contact the appropriate individual as indicated in the public announcement or the ADA/Title VI Coordinator at the address and/or number listed below. The request should be made as soon as possible but no later than forty-eight (48) hours before the scheduled event.

Christopher J. Watt, Esq
Human Resources Manager

110 SE Watula Avenue
Ocala FL 34471
Phone: (352) 629-8205
Fax: (352) 401-6942
E-mail: cwatt@ocalafl.org

- Requests for auxiliary aids and services to ensure effective communication for qualified individuals with a disability for public meetings should be directed to the Office of the City Clerk:

Angel B. Jacobs
City Clerk

110 SE Watula Avenue
Ocala FL 34471
Phone: (352) 629-8266
Fax: (352) 629-5208
E-mail: clerk@ocalafl.org

- The ADA does not require the City of Ocala to take any action that would fundamentally alter the nature of its programs or services, or impose an undue financial or administrative burden.



CITY OF OCALA, FLORIDA NOTICE UNDER THE AMERICANS WITH DISABILITIES ACT

In accordance with the requirements of Title II of the Americans with Disabilities Act of 1990 (ADA), the City of Ocala will not discriminate against qualified individuals with disabilities on the basis of disability in its services, programs, or activities.

Employment: City of Ocala does not discriminate on the basis of disability in its hiring or employment practices and complies with all regulations promulgated by the U.S. Equal Employment Opportunity Commission under Title I of the ADA.

Effective Communication: City of Ocala will generally, upon request, provide appropriate aids and services leading to effective communication for qualified persons with disabilities so they can participate equally in City of Ocala's programs, services, and activities, including qualified sign language interpreters, documents in Braille, and other ways of making information and communications accessible to people who have speech, hearing, or vision impairments.

Modifications to Policies and Procedures: City of Ocala will make all reasonable modifications to policies and programs to ensure that people with disabilities have an equal opportunity to enjoy all of its programs, services, and activities. For example, individuals with service animals are welcomed in City of Ocala offices, even where pets are generally prohibited.

Anyone who requires an auxiliary aid or service for effective communication, or a modification of policies or procedures to participate in a program, service, or activity of the City of Ocala, should contact the office of ***Christopher J. Watt, ADA/504 Coordinator at 352-401-3994 or cwatt@ocalafl.org*** as soon as possible but no later than 48 hours before the scheduled event.

The ADA does not require the City of Ocala to take any action that would fundamentally alter the nature of its programs or services or impose an undue financial or administrative burden.

Complaints that a program, service, or activity of the City of Ocala is not accessible to persons with disabilities should be directed to ***Christopher J. Watt, ADA/504 Coordinator at 352-401-3994 or cwatt@ocalafl.org***.

City of Ocala will not place a surcharge on a particular individual with a disability or any group of individuals with disabilities to cover the cost of providing auxiliary aids/services or reasonable modifications of policy, such as retrieving items from locations that are open to the public but are not accessible to persons who use wheelchairs.

Appendix C: City of Ocala Documents, Forms, and Videos

City of Ocala
Documents, Forms, and Videos Review

Documents / Forms / Videos Name	Reference Link
Chapter 119, Records Custodian	https://www.ocalafl.org/Home/ShowDocument?id=7222
2019 Budget Resolutions	https://www.ocalafl.org/government/city-departments-a-h/budget/budget-resolutions/2019-budget-resolutions
FY 2018-2019 Proposed Budget Workshop Presentation	https://www.ocalafl.org/Home/ShowDocument?id=16005
FY 2018-2019 Proposed Budget Workshop Document	https://www.ocalafl.org/Home/ShowDocument?id=16001
FY 2018-2019 Proposed Budgeted Reserves	https://www.ocalafl.org/Home/ShowDocument?id=15999
FY 2018-2019 Proposed Budget Letter	https://www.ocalafl.org/Home/ShowDocument?id=15997
FY 2019 Proposed Sponsorships Recommendations	https://www.ocalafl.org/Home/ShowDocument?id=15995
FY 2019 Fiscal Year Budget Calendar	https://www.ocalafl.org/Home/ShowDocument?id=15722
FY 2019 Citizen's Guide to the Budget	https://www.ocalafl.org/Home/ShowDocument?id=17490
FY 2018-2019 Capital Improvement Plan	https://www.ocalafl.org/Home/ShowDocument?id=17488
Community Cash Sponsorship Policy	https://www.ocalafl.org/Home/ShowDocument?id=14301
General Conditions for Construction	https://www.ocalafl.org/home/showdocument?id=3225
Project Specifications Sections for Water and Sewer Construction	https://www.ocalafl.org/home/showdocument?id=7743
Project Specifications Details for Water and Sewer Construction	https://www.ocalafl.org/home/showdocument?id=7341
Water Resources Internship Program	https://www.ocalafl.org/Home/ShowDocument?id=12734
Flood Inundation Map	https://www.ocalafl.org/Home/ShowDocument?id=4675
Capital Improvement Projects Update	https://www.ocalafl.org/Home/ShowDocument?id=9007
Flood Information Brochure	https://www.ocalafl.org/Home/ShowDocument?id=2539
Flood Protection Tips	https://www.ocalafl.org/Home/ShowDocument?id=7060
Floodplain Management Definitions	https://www.ocalafl.org/Home/ShowDocument?id=1731
Water & Sewer System Construction and Maintenance Note	https://www.ocalafl.org/Home/ShowDocument?id=6770
Sewer Verification Waiver	https://www.ocalafl.org/Home/ShowDocument?id=3123
Community Redevelopment Agency Commercial Building Improvement Grants Program	https://www.ocalafl.org/Home/ShowDocument?id=17256
Small Business Investment Program	https://www.ocalafl.org/Home/ShowDocument?id=1307
Economic Investment Program	https://www.ocalafl.org/Home/ShowDocument?id=2322
Enterprise Zone	https://www.ocalafl.org/Home/ShowDocument?id=2330
2016 Economic Development Survey Results	https://www.ocalafl.org/Home/ShowDocument?id=3666
Downtown Parking Study and Master Plan	https://www.ocalafl.org/Home/ShowDocument?id=1285
Downtown Retail Market Analysis	https://www.ocalafl.org/Home/ShowDocument?id=1287
Supermarket Feasibility Analysis and Implementation Plan	https://www.ocalafl.org/Home/ShowDocument?id=1289
Inland Logistics Center Feasibility Study - Engineering	https://www.ocalafl.org/Home/ShowDocument?id=1723
Inland Logistics Center Feasibility Study - Environment	https://www.ocalafl.org/Home/ShowDocument?id=17256
Inland Logistics Center Feasibility Study - Financial	https://www.ocalafl.org/Home/ShowDocument?id=1727
Ocala 2035 Vision	https://www.ocalafl.org/Home/ShowDocument?id=4625
Economic Development	https://www.ocalafl.org/Home/ShowDocument?id=1309
Downtown Master Plan	https://www.ocalafl.org/Home/ShowDocument?id=1283
West Ocala Community Plan	https://www.ocalafl.org/Home/ShowDocument?id=1293
West Ocala CRA Adopted Plan 2015	https://www.ocalafl.org/Home/ShowDocument?id=4625
SHIP Approved Lenders	https://www.ocalafl.org/Home/ShowDocument?id=17746
Housing Programs 2018	https://www.ocalafl.org/Home/ShowDocument?id=14601
2018 Community Development Block Grant Action Plan	https://www.ocalafl.org/Home/ShowDocument?id=17197
Local Housing Assistance Plan	https://www.ocalafl.org/Home/ShowDocument?id=1319
Renew Ocala Brownfields Program	https://www.ocalafl.org/Home/ShowDocument?id=4237
Pine Oak Square Vision	https://www.ocalafl.org/Home/ShowDocument?id=4236
Benefits Handbook	https://www.ocalafl.org/home/showdocument?id=15752
Employee Handbook	https://www.ocalafl.org/home/showdocument?id=7078
Important Notices	https://www.ocalafl.org/home/showdocument?id=15758
Pet Insurance	https://www.ocalafl.org/home/showdocument?id=2356
Open Enrollment Calendar	https://www.ocalafl.org/home/showdocument?id=15943
Benefits Highlights and Changes	https://www.ocalafl.org/home/showdocument?id=15740
Dependent Audit	https://www.ocalafl.org/home/showdocument?id=5247
Premium Assistance Under Medicaid and the Children Health Insurance Program	https://www.ocalafl.org/home/showdocument?id=15700
HIPPA Notice	https://www.ocalafl.org/home/showdocument?id=15702
Special Enrollment Rights	https://www.ocalafl.org/home/showdocument?id=15704

City of Ocala
Documents, Forms, and Videos Review

Documents / Forms / Videos Name	Reference Link
The Newborn's and Mother's Health Protection Act	https://www.ocalafl.org/home/showdocument?id=15704
Women's Health and Cancer Rights Act Enrollment Notice	https://www.ocalafl.org/home/showdocument?id=15704
Notice Regarding Wellness Programs	https://www.ocalafl.org/home/showdocument?id=15708
Notice of Exchange Availability	https://www.ocalafl.org/home/showdocument?id=15710
Medicare Part D Notice 3359	https://www.ocalafl.org/home/showdocument?id=15712
Medicare Part D Notice 5902	https://www.ocalafl.org/home/showdocument?id=15714
Summary of Benefits and Coverage 5902	https://www.ocalafl.org/home/showdocument?id=15720
Summary of Benefits and Coverage 3359	https://www.ocalafl.org/home/showdocument?id=15718
Collective Bargaining Agreement with International Brotherhood of Electrical Workers	https://www.ocalafl.org/home/showdocument?id=17371
Collective Bargaining Agreement with the Fraternal Order of Police	https://www.ocalafl.org/home/showdocument?id=2477
Collective Bargaining Agreement with the Fraternal Order of Police - Lieutenants & Sergeants	https://www.ocalafl.org/home/showdocument?id=2475
Collective Bargaining Agreement with International Association of Fire Fighters	https://www.ocalafl.org/home/showdocument?id=2479
Retirement Records Custodian	https://www.ocalafl.org/home/showdocument?id=9258
What to Expect Upon Retirement	https://www.ocalafl.org/home/showdocument?id=6517
Retiree EDEN Portal Instructions	https://www.ocalafl.org/home/showdocument?id=15899
City of Ocala 2018 Ballot Guide	https://www.ocalafl.org/home/showdocument?id=17070
City of Ocala and Elect RX Partnership	https://www.ocalafl.org/home/showdocument?id=4398
Analysis of Investment Performance June 2018	https://www.ocalafl.org/home/showdocument?id=15971
Long Wharf/ City of Ocala Retirement Pension Board of Trustees	https://www.ocalafl.org/home/showdocument?id=16023
Boards and Commissions Information Booklet	https://www.ocalafl.org/home/showdocument?id=897
Ocala Firefighters Retirement Plan Performance Review 9/30/18	https://www.ocalafl.org/home/showdocument?id=899
City of Ocala Firefighters Retirement Plan	https://www.ocalafl.org/home/showdocument?id=17944
Ocala Police Retirement System Quarterly Report 06/30/18	https://www.ocalafl.org/home/showdocument?id=15594
Ocala Police Retirement Board of Trustees	https://www.ocalafl.org/home/showdocument?id=15969
Ocala Policy Retirement Summary	https://www.ocalafl.org/home/showdocument?id=6523
Review of Water Resources Fee Schedule	https://www.ocalafl.org/home/showdocument?id=5353
Ocala Website Content Audit	https://www.ocalafl.org/home/showdocument?id=17942
Review of Airport Commission Revenues	https://www.ocalafl.org/home/showdocument?id=17690
Ocala Fire Rescue History Timeline	https://www.ocalafl.org/home/showdocument?id=17670
2017 Ocala Fire Rescue Annual Report to the Community	https://www.ocalafl.org/home/showdocument?id=2384
T-Hanger Policies	https://www.ocalafl.org/home/showdocument?id=16021
Airport Layout Plan	https://www.ocalafl.org/home/showdocument?id=15805
Airport Master Plan	https://www.ocalafl.org/home/showdocument?id=3616
Ocala Airport Rules and Regulations	https://www.ocalafl.org/home/showdocument?id=3618
Ocala Airport Development Standards	https://www.ocalafl.org/home/showdocument?id=654
Ocala Airport Lease Policy	https://www.ocalafl.org/home/showdocument?id=658
Ocala Airport Minimum Standards	https://www.ocalafl.org/home/showdocument?id=664
T-Hanger Campus Layout	https://www.ocalafl.org/home/showdocument?id=12887
Ocala International Airport General Aviation Charrette	https://www.ocalafl.org/home/showdocument?id=1419
Sanitation Rates	https://www.ocalafl.org/home/showdocument?id=12939
Commercial Dumpster Information	https://www.ocalafl.org/Home/ShowDocument?id=17444
Commercial Sanitation Schedule	https://www.ocalafl.org/Home/ShowDocument?id=3966
Sanitation General Information	https://www.ocalafl.org/Home/ShowDocument?id=4000
Residential Sanitation Schedule	https://www.ocalafl.org/Home/ShowDocument?id=4032
Sanitation Rules and Procedures	https://www.ocalafl.org/Home/ShowDocument?id=12751
Sanitation/Recycle Routes	https://www.ocalafl.org/Home/ShowDocument?id=3997
Sanitation and Flies	https://www.ocalafl.org/Home/ShowDocument?id=4022
Honorary Designation Policy	https://www.ocalafl.org/Home/ShowDocument?id=4040
Recreation and Parks Rental Rules	https://www.ocalafl.org/Home/ShowDocument?id=3999
Rental Rates for Facilities	https://www.ocalafl.org/home/showdocument?id=15025
Arts & Economic Prosperity 5	https://www.ocalafl.org/home/showdocument?id=15023
Community Cultural Arts Master Plan	https://www.ocalafl.org/home/showdocument?id=7126
	https://www.ocalafl.org/home/showdocument?id=17466

City of Ocala
Documents, Forms, and Videos Review

Documents / Forms / Videos Name	Reference Link
Levitt AMP Ocala Grant Voting Guide	https://www.ocalafl.org/home/showdocument?id=17754
Special Even Permit Application and Quick Guide	https://www.ocalafl.org/home/showdocument?id=2462
Certificate of Liability Information	https://www.ocalafl.org/home/showdocument?id=2505
Special Event Permit Fees	https://www.ocalafl.org/home/showdocument?id=2469
Special Event Support Services Fees	https://www.ocalafl.org/home/showdocument?id=2485
Exhibit A: Recreation, Open Space and Cultural Arts Element	https://www.ocalafl.org/home/showdocument?id=6509
Skate Park Staff Evaluation	https://www.ocalafl.org/home/showdocument?id=6511
Tuscawilla Park Master Plan Report	https://www.ocalafl.org/home/showdocument?id=6513
Tuscawilla Park Cultural Arts Plan	https://www.ocalafl.org/home/showdocument?id=6515
Budget Resolution 2019-100	https://www.ocalafl.org/Home/ShowDocument?id=17496
Budget Resolution 2019-101	https://www.ocalafl.org/Home/ShowDocument?id=17498
Budget Resolution 2019-102	https://www.ocalafl.org/Home/ShowDocument?id=17500
Budget Resolution 2019-103	https://www.ocalafl.org/Home/ShowDocument?id=17502
Budget Resolution 2019-104	https://www.ocalafl.org/Home/ShowDocument?id=17504
Budget Resolution 2019-105	https://www.ocalafl.org/Home/ShowDocument?id=17506
Budget Resolution 2019-106	https://www.ocalafl.org/Home/ShowDocument?id=17726
Budget Resolution 2019-107	https://www.ocalafl.org/Home/ShowDocument?id=17728
Budget Resolution 2019-108	https://www.ocalafl.org/Home/ShowDocument?id=17730
Budget Resolution 2019-109	https://www.ocalafl.org/Home/ShowDocument?id=17732
Budget Resolution 2019-110	https://www.ocalafl.org/Home/ShowDocument?id=17734
Budget Resolution 2019-111	https://www.ocalafl.org/Home/ShowDocument?id=17921
Budget Resolution 2019-112	https://www.ocalafl.org/Home/ShowDocument?id=17923
Budget Resolution 2019-113	https://www.ocalafl.org/Home/ShowDocument?id=17925
Budget Resolution 2019-114	https://www.ocalafl.org/Home/ShowDocument?id=17927
Budget Resolution 2019-115	https://www.ocalafl.org/Home/ShowDocument?id=17929
FY 2018-2019 Proposed Budget	https://www.ocalafl.org/Home/ShowDocument?id=16005
FY 2018-2019 Proposed Budgeted Reserves	https://www.ocalafl.org/Home/ShowDocument?id=15999
FY 2018-2019 Proposed Budget Letter	https://www.ocalafl.org/Home/ShowDocument?id=15997
FY 2018-2019 Community Sponsorship Recommendation	https://www.ocalafl.org/Home/ShowDocument?id=15995
FY 2018-2019 Budget Calendar	https://www.ocalafl.org/Home/ShowDocument?id=15722
2018-2019 Adopted Budget & Capital Improvement Plan Document	https://www.ocalafl.org/Home/ShowDocument?id=17488
City of Ocala Treasury Investment Policy	https://www.ocalafl.org/home/showdocument?id=2362
Explanation of Billed City of Ocala Municipal Services	https://www.ocalafl.org/home/showdocument?id=17574
Outdoor Lighting	https://www.ocalafl.org/home/showdocument?id=2336
Municipal Services Statement - Rate and Fee Information	https://www.ocalafl.org/home/showdocument?id=12973
Development Services Fees	https://www.ocalafl.org/Home/ShowDocument?id=2885
Impact Fee Schedule	https://www.ocalafl.org/Home/ShowDocument?id=4256
How to Schedule Inspections	https://www.ocalafl.org/home/showdocument?id=3362
Contractor Certification Requirements	https://www.ocalafl.org/home/showdocument?id=2075
Commercial Minimum Inspections Required	https://www.ocalafl.org/Home/ShowDocument?id=17484
FBC Minimum Site Plan Requirements	https://www.ocalafl.org/Home/ShowDocument?id=15600
Mobile Home Repairs or Exemptions	https://www.ocalafl.org/Home/ShowDocument?id=15935
New Single Family & Residential Minimum Inspections Required	https://www.ocalafl.org/Home/ShowDocument?id=17486
ProjectDox System User Requirements 9.0 and above	https://www.ocalafl.org/Home/ShowDocument?id=15460
Residential Reroof Inspection Procedure	https://www.ocalafl.org/Home/ShowDocument?id=108
Sinkhole - Foundation Repair	https://www.ocalafl.org/Home/ShowDocument?id=15660
Standard Environmental Details	https://www.ocalafl.org/Home/ShowDocument?id=2716
Ocala Historic District	https://www.ocalafl.org/Home/ShowDocument?id=2195
Downtown Historic District	https://www.ocalafl.org/Home/ShowDocument?id=2189
West Ocala Historic District	https://www.ocalafl.org/Home/ShowDocument?id=2203
Historic Preservation Design Guidelines	https://www.ocalafl.org/Home/ShowDocument?id=6519
An Analysis of Residential Market Potential	https://www.ocalafl.org/Home/ShowDocument?id=7192
City of Ocala Comprehensive Plan	https://www.ocalafl.org/Home/ShowDocument?id=5197
Parking Study and Master Plan	https://www.ocalafl.org/Home/ShowDocument?id=5201
City of Ocala Form-Based Code	https://www.ocalafl.org/Home/ShowDocument?id=13185
Midtown Master Plan	https://www.ocalafl.org/Home/ShowDocument?id=5211
TPO Transit Development Plan	https://www.ocalafl.org/Home/ShowDocument?id=5207

City of Ocala
Documents, Forms, and Videos Review

Documents / Forms / Videos Name	Reference Link
Tuscawilla Master Plan Report	https://www.ocalafl.org/Home/ShowDocument?id=5209
Site Plan Review Meeting Agenda	https://www.ocalafl.org/Home/ShowDocument?id=1965
Building Plan Review Flow Chart	https://www.ocalafl.org/Home/ShowDocument?id=1955
Site Plan Review Flow Chart	https://www.ocalafl.org/Home/ShowDocument?id=1959
Subdivision Review Flow Chart	https://www.ocalafl.org/Home/ShowDocument?id=1961
10 Ways to Avoid Getting a Parking Ticket	https://www.ocalafl.org/Home/ShowDocument?id=4993
How to use the Parking Meters	https://www.ocalafl.org/Home/ShowDocument?id=4991
Downtown CRA Grant Summary	https://www.ocalafl.org/home/showdocument?id=14399
North Magnolia CRA Grant Summary	https://www.ocalafl.org/home/showdocument?id=14401
West Ocala CRA Grant Summary	https://www.ocalafl.org/home/showdocument?id=14403
East Ocala CRA Grant Summary	https://www.ocalafl.org/home/showdocument?id=17680
2017 Ocala Police Annual Report	https://issuu.com/ocalapd/docs/2017_annual_report
Ocala PD EEO Utilization Report	https://www.ocalapd.com/home/showdocument?id=15318
Police/Citizen Encounters	https://www.ocalapd.com/home/showdocument?id=5147
Ocala/Marion TPO 2018 ITS Strategic Plan Update	https://www.ocalamariontpo.org/home/showdocument?id=15338
Ocala/Marion Long Range Transportation Plan	https://www.ocalamariontpo.org/home/showdocument?id=4018
2018 Transportation Improvement Plan	https://www.ocalamariontpo.org/home/showdocument?id=15618
Ocala Marion Unified Planning Work Program	https://www.ocalamariontpo.org/home/showdocument?id=4016
Approved UPWP Amendment De-obligation	https://www.ocalamariontpo.org/home/showdocument?id=15668
Ocala Marion TPO 2035 Bicycle Pedestrian Master Plan	https://www.ocalamariontpo.org/home/showdocument?id=4562
CarFit Flyer	https://www.ocalamariontpo.org/home/showdocument?id=9284
Cycle Savvy Flyer	https://www.ocalamariontpo.org/home/showdocument?id=9286
FY 2024 Priority Projects FDOT	https://www.ocalamariontpo.org/home/showdocument?id=15308
2024 Off System Priority	https://www.ocalamariontpo.org/home/showdocument?id=15614
FY 2024 Trail Priorities Final	https://www.ocalamariontpo.org/home/showdocument?id=15613
TPO General Terms and Conditions	https://www.ocalamariontpo.org/home/showdocument?id=9186
TPO Standard Insurance Requirements	https://www.ocalamariontpo.org/home/showdocument?id=9192
FTA Fiscal Year 2016 Certifications and Assurances	https://www.ocalamariontpo.org/home/showdocument?id=9143
TPO Disadvantaged Business Enterprise Affirmative Action Plan	https://www.ocalamariontpo.org/home/showdocument?id=17800
TPO Title VI Plan	https://www.ocalamariontpo.org/home/showdocument?id=15288
Metropolitan Planning Organization Agreement	https://www.ocalamariontpo.org/home/showdocument?id=9147
TPO Staff Services Agreement	https://www.ocalamariontpo.org/home/showdocument?id=9149
SunTran Bus Wrap Specifications	https://www.suntran.org/home/showdocument?id=9196
Suntran Advertising Policy	https://www.suntran.org/home/showdocument?id=9198
SunTran Interlocal Agreement	https://www.suntran.org/home/showdocument?id=11374
FTA Fiscal Year 2017 Certifications and Assurances	https://www.suntran.org/home/showdocument?id=11376
SunTran Transit Development Plan	https://www.suntran.org/home/showdocument?id=9208
SunTran 2018-2017 Transportation Disadvantaged Service Plan	https://www.suntran.org/home/showdocument?id=9083
How to Ride SunTran	https://www.suntran.org/home/showdocument?id=12514
SunTran Route Map	https://www.suntran.org/home/showdocument?id=17946
MTS Paratransit Brochure	https://www.suntran.org/home/showdocument?id=9085
SunTran ADA Brochure	https://www.suntran.org/home/showdocument?id=9085
Ocala TPS Bus Stop ADA Assessment	https://www.suntran.org/home/showdocument?id=9089
Severe Weather Preparation Guide	https://www.ocalafl.org/home/showdocument?id=1503
Guidelines for City of Ocala Electric Utility Insulation/HVAC Pre-Qualified Contractors	https://www.ocalafl.org/home/showdocument?id=14757
HVAC Pre-Qualified Contractors	https://www.ocalafl.org/home/showdocument?id=1465
Attic Insulation Pre-Qualified Contractors	https://www.ocalafl.org/home/showdocument?id=1463
Solar/Net Metering - FAQ	https://www.ocalafl.org/home/showdocument?id=6750
Solar/Net Metering - Fact Sheet	https://www.ocalafl.org/home/showdocument?id=2235
Procurement Policy	http://bidocala.com/wp-content/uploads/Procurement-Policy.pdf
General Terms and Conditions	http://bidocala.com/wp-content/uploads/General-Terms-and-Conditions.pdf
Local Vendor Attributes	http://bidocala.com/wp-content/uploads/Local-Vendor-Attributes.pdf
Standard Insurance Requirements	http://bidocala.com/wp-content/uploads/Standard-Insurance-Requirements.pdf
Grease Trap Detail	https://www.ocalafl.org/Home/ShowDocument?id=2279

City of Ocala
Documents, Forms, and Videos Review

Documents / Forms / Videos Name	Reference Link
2017 Water Quality Report	https://www.ocalafl.org/Home/ShowDocument?id=14285
Hydrant Maintenance and Line Flushing	https://www.ocalafl.org/Home/ShowDocument?id=3714
Water Coloring Book	https://www.ocalafl.org/Home/ShowDocument?id=2283
Rain Barrel Fact Sheet	https://www.ocalafl.org/Home/ShowDocument?id=12456
Groundwater Recharge Wetland Conceptual Cross-Section	https://www.ocalafl.org/Home/ShowDocument?id=6730
Coming Soon- Wetland Groundwater Recharge Park	https://www.ocalafl.org/Home/ShowDocument?id=6960
Why Does Nitrate Matter?	https://www.ocalafl.org/Home/ShowDocument?id=3602
Citizen Reporter	http://crwtrakit.ocalafl.org/etrakit3/CRM/issue.aspx
Code Red - Community Notification Enrollment	https://public.coderedweb.com/CNE/en-US/70D689CF4947
Community Cash Sponsorship Application	https://www.ocalafl.org/Home/ShowDocument?id=14209
City Feedback	https://www.ocalafl.org/government/city-departments-a-i/city-manager-s-office/city-feedback
Pet Waste Pledge	https://www.ocalafl.org/home/showdocument?id=4328
R.O.W. Utilization Permit Application	https://www.ocalafl.org/Home/ShowDocument?id=10308
Final Brownfield Grant 2017	https://www.ocalafl.org/Home/ShowDocument?id=3880
New Residential Municipal Services Request	https://forms.ocalafl.org/AppNet/UnityForm.aspx?key=UFKey
Service Disconnect Request	https://www.ocalafl.org/government/city-departments-j-z/utility-services/customer-service-office/service-disconnect-request
Residential Transfer Service Request	https://www.ocalafl.org/government/city-departments-a-i/customer-service-office/my-account-info/transfer-service-request
Commercial Utility and Billed Services	https://www.ocalafl.org/home/showdocument?id=16066
Contract and Deposit Agreement Residential Utility and Billed Services - Prepaid	https://www.ocalafl.org/home/showdocument?id=16064
Contract and Deposit Agreement Residential Utility and Billed Services - Billed	https://www.ocalafl.org/home/showdocument?id=16062
City of Ocala Wellness Incentive	https://www.ocalafl.org/home/showdocument?id=15744
Charity Domination Form	https://www.ocalafl.org/home/showdocument?id=15855
Direct Deposit	https://www.ocalafl.org/home/showdocument?id=5275
Duty Status Form	https://www.ocalafl.org/home/showdocument?id=2731
Claim for Damages	https://www.ocalafl.org/home/showdocument?id=7290
Change of Address	https://www.ocalafl.org/home/showdocument?id=5300
Blue Cross Blue Shield Claim Form	https://www.ocalafl.org/home/showdocument?id=5292
PrimeMail RX Order Form	https://www.ocalafl.org/home/showdocument?id=5293
Florida Blue Appeals Form	https://www.ocalafl.org/home/showdocument?id=5276
The Standard Dental Claim Form	https://www.ocalafl.org/home/showdocument?id=6941
The Standard Out-of-Network Claim Form	https://www.ocalafl.org/home/showdocument?id=6943
MetLife Enrollment Form LTD	https://www.ocalafl.org/home/showdocument?id=5281
MetLife Disability Claim Form EE	https://www.ocalafl.org/home/showdocument?id=5284
MetLife Disability Claim Form ER	https://www.ocalafl.org/home/showdocument?id=5283
MetLife Disability Claim Form Physician Statement	https://www.ocalafl.org/home/showdocument?id=5282
Allstate Wellness Claim Form	https://www.ocalafl.org/home/showdocument?id=5289
Outpatient Physician's Treatment Benefit Claim Form	https://www.ocalafl.org/home/showdocument?id=5291
Allstate Enrollment Form	https://www.ocalafl.org/home/showdocument?id=5290
Allstate Evidence of Insurability	https://www.ocalafl.org/home/showdocument?id=5288
Allstate Cancer/Critical Illness Claim Form	https://www.ocalafl.org/home/showdocument?id=5287
Allstate Accident Claim Form	https://www.ocalafl.org/home/showdocument?id=5286
Beneficiary Designation	https://www.ocalafl.org/home/showdocument?id=15756
Request for Pension Estimate	https://www.ocalafl.org/home/showdocument?id=15746
City of Ocala Pension Beneficiary	https://www.ocalafl.org/home/showdocument?id=1335
Pension Department Change of Address Form	https://www.ocalafl.org/home/showdocument?id=17562
Retiree Direct Deposit Form	https://www.ocalafl.org/home/showdocument?id=17564
Retiree Contact Information Update Form	https://www.ocalafl.org/home/showdocument?id=15895
Retiree Change of Surname	https://www.ocalafl.org/home/showdocument?id=15897
Withholding Certificate for Pension or Annuity Payments	https://www.ocalafl.org/home/showdocument?id=15750
Report a Web Accessibility Issue	https://www.ocalafl.org/government/city-departments-a-i/information-technology/report-a-web-accessibility-issue

City of Ocala
Documents, Forms, and Videos Review

Documents / Forms / Videos Name	Reference Link
Webmaster Feedback Form	https://www.ocalafl.org/government/city-departments/information-technology/webmaster-feedback-form
Smoke Detector Request Form	https://www.ocalafl.org/government/city-departments/fire-rescue/smoke-detector-request-form
Citizen CPR Request Form	https://www.ocalafl.org/government/city-departments/fire-rescue/citizen-s-cpr
Fire Rescue Mentorship Request Form	https://www.ocalafl.org/government/city-departments/fire-rescue/coaching-mentoring-program
Door Alarm Request Form	https://www.ocalafl.org/government/city-departments-a-i/fire-rescue/community-outreach/fire-station-tours/door-alarm-request
Emergency Notification Registration	https://public.coderedweb.com/CNE/en-US/70D689CF4947
T-Hanger Lease Interest Form	https://www.ocalafl.org/home/showdocument?id=15803
Airport Identification Badge Application	https://www.ocalafl.org/home/showdocument?id=12879
Ocala Airport Agreement Under Standards Exhibit C-1	https://www.ocalafl.org/home/showdocument?id=660
Ocala Airport Ground Lease	https://www.ocalafl.org/home/showdocument?id=662
T-Hangar Lease Agreement	https://www.ocalafl.org/home/showdocument?id=668
Permit for Temporary Street, Alley, Sidewalk, Parade, or Procession Closure	https://www.ocalafl.org/Home/ShowDocument?id=674
Adopt-A-Street Program	https://www.ocalafl.org/Home/ShowDocument?id=4320
City of Ocala Parks Survey Monkey	https://www.surveymonkey.com/r/CityofOcalaParks
Let them Play Scholarship Fund	https://apm.activecommunities.com/ocalamarioncounty/ActiveNet_Home/onlineDonationDetail.sdi?oc=ShoppingCart&campaign_id=15&online=true&sdiregauth=1426797547403
City of Ocala Recreation & Parks Facility Event Application	https://www.ocalafl.org/home/showdocument?id=15027
Art in City Spaces Exhibit Application	https://www.ocalafl.org/home/showdocument?id=14685
First Friday Visual Artist Registration	https://www.ocalafl.org/home/showdocument?id=15484
First Friday Performing Artist Registration	https://www.ocalafl.org/home/showdocument?id=15482
First Friday Arts Organization Registration	https://www.ocalafl.org/home/showdocument?id=15574
First Friday Downtown Business Registration	https://www.ocalafl.org/home/showdocument?id=15572
Ocala Municipal Arts Commission Grant Program	https://www.ocalafl.org/home/showdocument?id=15514
City of Ocala Volunteer Application	https://www.ocalafl.org/home/showdocument?id=2334
Undergraduate Internship Application	https://www.ocalafl.org/home/showdocument?id=692
Intern Program Interest Form	https://www.ocalafl.org/home/showdocument?id=2424
Events Summary Registration Form	https://www.ocalafl.org/home/showdocument?id=2465
Special Event Permit Application	https://www.ocalafl.org/home/showdocument?id=2471
Community Sponsorship Policy	https://www.ocalafl.org/home/showdocument?id=678
City of Ocala Recreation and Parks Vendor Mailing List	https://us15.list-manage.com/subscribe?u=e693401d5956d382262d6faa5&id=68efb86135
35th Annual Light up Ocala Vendor Application	https://form.jotform.com/81204147742148
Light Up Ocala Even Sponsorship	https://www.ocalafl.org/home/showdocument?id=15140
Recreation and Parks ADA Website Information	https://www.ocalafl.org/Home/ShowDocument?id=676
Community Garden Application and Participation Rules	https://www.ocalafl.org/Home/ShowDocument?id=2460
Concessionaire Application	https://www.ocalafl.org/Home/ShowDocument?id=680
Metal Detecting Excavation Permit	https://www.ocalafl.org/Home/ShowDocument?id=4337
Noise Permit Application	https://www.ocalafl.org/Home/ShowDocument?id=2467
Contract and Deposit Agreement Residential Utility and Billed Services	https://www.ocalafl.org/home/showdocument?id=16064
Requesting a Payment Extension	https://www.ocalafl.org/government/city-departments-j-z/utility-services/customer-service-office/my-account-info/payment-extension
Ocala Electric Utility Application for Medical Alert Customer Status	https://www.ocalafl.org/home/showdocument?id=2135
Update Contact Information	https://www.ocalafl.org/government/city-departments-j-z/utility-services/customer-service-office/update-contact-information
Abandoned Property Registration Form	https://www.ocalafl.org/Home/ShowDocument?id=1967
Fictitious Name Registration Affidavit of Compliance	https://www.ocalafl.org/Home/ShowDocument?id=156
Alcohol Permit	https://www.ocalafl.org/Home/ShowDocument?id=158
Bingo Application	https://www.ocalafl.org/Home/ShowDocument?id=16001

City of Ocala
Documents, Forms, and Videos Review

Documents / Forms / Videos Name	Reference Link
Business Tax Certificate Application	https://www.ocalafl.org/Home/ShowDocument?id=162
Non-Profit Car Wash Even Application	https://www.ocalafl.org/Home/ShowDocument?id=164
Doggy Dining Permit Application	https://www.ocalafl.org/Home/ShowDocument?id=166
Electric Fence License Application	https://www.ocalafl.org/Home/ShowDocument?id=168
Gun Range Permit Application	https://www.ocalafl.org/Home/ShowDocument?id=170
Home Occupational License Application	https://www.ocalafl.org/Home/ShowDocument?id=172
Juvenile Dance Hall Application	https://www.ocalafl.org/Home/ShowDocument?id=17488
Mobile Auto Detailing	https://www.ocalafl.org/Home/ShowDocument?id=14319
Mobile Vendor Guidelines and Application	https://www.ocalafl.org/Home/ShowDocument?id=176
Pawnbroker: Second Hand Dealers License	https://www.ocalafl.org/Home/ShowDocument?id=178
Sidewalk Café Application	https://www.ocalafl.org/Home/ShowDocument?id=180
Alcohol Permit for Special Events	https://www.ocalafl.org/Home/ShowDocument?id=184
Teenage Dance Application	https://www.ocalafl.org/Home/ShowDocument?id=186
Transportation Franchise Application	https://www.ocalafl.org/Home/ShowDocument?id=188
Valet Parking Application and Indemnification Agreement	https://www.ocalafl.org/Home/ShowDocument?id=190
Valet Parking Renewal Application	https://www.ocalafl.org/Home/ShowDocument?id=192
Contractor Certification Application	https://www.ocalafl.org/home/showdocument?id=2073
Letter of Authorization	https://www.ocalafl.org/home/showdocument?id=2079
State Certified Contractor Form	https://www.ocalafl.org/home/showdocument?id=3768
Address Request Application	https://www.ocalafl.org/Home/ShowDocument?id=64
Affidavit of Compliance	https://www.ocalafl.org/Home/ShowDocument?id=66
Asbestos Renovation or Demolition Application	https://www.ocalafl.org/Home/ShowDocument?id=70
Blower Door Test Form	https://www.ocalafl.org/Home/ShowDocument?id=14815
Change of Contractor Authorization fill form	https://www.ocalafl.org/Home/ShowDocument?id=7643
Commercial Plan Check List	https://www.ocalafl.org/Home/ShowDocument?id=72
Construction Permit Application	https://www.ocalafl.org/Home/ShowDocument?id=6970
Construction Permit Revisions - Fill Form	https://www.ocalafl.org/Home/ShowDocument?id=7643
Demolition Permit	https://www.ocalafl.org/Home/ShowDocument?id=78
Demolition Permit (Off-Site Advertising Signs)	https://www.ocalafl.org/Home/ShowDocument?id=80
Driveway Permit Application	https://www.ocalafl.org/Home/ShowDocument?id=82
Gas Calculation Worksheet	https://www.ocalafl.org/Home/ShowDocument?id=8841
Gas Piping Test Affidavit	https://www.ocalafl.org/Home/ShowDocument?id=8841
House Moving Permit	https://www.ocalafl.org/Home/ShowDocument?id=90
Mobile Home Inspections	https://www.ocalafl.org/Home/ShowDocument?id=12448
New Commercial Plumbing Quantity Sheet	https://www.ocalafl.org/Home/ShowDocument?id=6974
Notice of Commencement	https://www.ocalafl.org/Home/ShowDocument?id=96
Notice of Termination	https://www.ocalafl.org/Home/ShowDocument?id=98
Owner - Builder Statement	https://www.ocalafl.org/Home/ShowDocument?id=100
Permit Extension Request	https://www.ocalafl.org/Home/ShowDocument?id=15065
Permit Revision Request Fill Form	https://www.ocalafl.org/Home/ShowDocument?id=102
Preliminary Inspection Request	https://www.ocalafl.org/Home/ShowDocument?id=17088
Product Approval Spec Sheet	https://www.ocalafl.org/Home/ShowDocument?id=104
Residential Plan Checklist	https://www.ocalafl.org/Home/ShowDocument?id=106
Roofing Affidavit	https://www.ocalafl.org/Home/ShowDocument?id=15216
Sign Permit - Permanent	https://www.ocalafl.org/Home/ShowDocument?id=110
Sign Permit - Temporary	https://www.ocalafl.org/Home/ShowDocument?id=112
Tent Permit Application	https://www.ocalafl.org/Home/ShowDocument?id=114
Threshold Building Affidavit	https://www.ocalafl.org/Home/ShowDocument?id=5055
Tree Removal Permit Application	https://www.ocalafl.org/Home/ShowDocument?id=116
Annexation Agreement	https://www.ocalafl.org/Home/ShowDocument?id=4
Appeal of Address Change to Board of Adjustment	https://www.ocalafl.org/Home/ShowDocument?id=6974
Appeal from the Decision of the Building Official	https://www.ocalafl.org/Home/ShowDocument?id=8841
Certificate of Appropriateness	https://www.ocalafl.org/Home/ShowDocument?id=4370
Certificate of Appropriateness - Demolition	https://www.ocalafl.org/Home/ShowDocument?id=4372
Comprehensive Plan Amendment	https://www.ocalafl.org/Home/ShowDocument?id=14
Developers Agreement	https://www.ocalafl.org/Home/ShowDocument?id=20
Division of Reconfiguration of Land Request	https://www.ocalafl.org/Home/ShowDocument?id=17610

**City of Ocala
Documents, Forms, and Videos Review**

Documents / Forms / Videos Name	Reference Link
Land Development Regulation Amendment Request	https://www.ocalafl.org/Home/ShowDocument?id=22
Land Use Amendment Large Scale	https://www.ocalafl.org/Home/ShowDocument?id=24
Land Use Amendment Small Scale	https://www.ocalafl.org/Home/ShowDocument?id=26
Land Use and Zoning Request for Information	https://www.ocalafl.org/Home/ShowDocument?id=2700
Minor Site Plan Approval	https://www.ocalafl.org/Home/ShowDocument?id=28
Preapplication Meeting Request fill Form	https://www.ocalafl.org/Home/ShowDocument?id=17828
Pre-Conceptual Shopping Center Plan Application	https://www.ocalafl.org/Home/ShowDocument?id=30
Project Completion Certification	https://www.ocalafl.org/Home/ShowDocument?id=2905
Public Hearing Request	https://www.ocalafl.org/Home/ShowDocument?id=32
PUD Amendment	https://www.ocalafl.org/Home/ShowDocument?id=34
PUD Rezoning	https://www.ocalafl.org/Home/ShowDocument?id=36
Request for Abrogation or Plat Vacation	https://www.ocalafl.org/Home/ShowDocument?id=38
Request for Rezoning	https://www.ocalafl.org/Home/ShowDocument?id=40
Request Rezoning Small Scale Land Use	https://www.ocalafl.org/Home/ShowDocument?id=42
RZL Rezoning	https://www.ocalafl.org/Home/ShowDocument?id=44
Shopping Center Rezoning	https://www.ocalafl.org/Home/ShowDocument?id=46
Sidewalk Waiver Request Form	https://www.ocalafl.org/Home/ShowDocument?id=2904
Signage Public Hearing	https://www.ocalafl.org/Home/ShowDocument?id=48
Site Plan Package Application and Checklists	https://www.ocalafl.org/Home/ShowDocument?id=52
Special Exceptions	https://www.ocalafl.org/Home/ShowDocument?id=54
Statement for Maintenance of Improvements	https://www.ocalafl.org/Home/ShowDocument?id=2902
Street-Specific Setback Reduction Request	https://www.ocalafl.org/Home/ShowDocument?id=15059
Subdivision Application Step 1 Preconceptual	https://www.ocalafl.org/Home/ShowDocument?id=7248
Subdivision Application Step 2 Conceptual	https://www.ocalafl.org/Home/ShowDocument?id=7250
Subdivision Application Step 3 Improvement Plan	https://www.ocalafl.org/Home/ShowDocument?id=7252
Subdivision Application Step 4 Final Plat	https://www.ocalafl.org/Home/ShowDocument?id=7254
Tree Restoration Plan Application	https://www.ocalafl.org/Home/ShowDocument?id=56
Variance	https://www.ocalafl.org/Home/ShowDocument?id=58
Voluntary Annexation Petition	https://www.ocalafl.org/Home/ShowDocument?id=60
Parking Contract Application	https://www.ocalafl.org/Home/ShowDocument?id=2849
Freight Zone Contract Application	https://www.ocalafl.org/Home/ShowDocument?id=2849
Ansafone Parking Contract Application	https://www.ocalafl.org/Home/ShowDocument?id=2851
Downtown CRA Grant Application	https://www.ocalafl.org/home/showdocument?id=17682
North Magnolia CRA Grant Application	https://www.ocalafl.org/home/showdocument?id=17684
West Ocala CRA Grant Application	https://www.ocalafl.org/home/showdocument?id=17686
East Ocala CRA Grant Application	https://www.ocalafl.org/home/showdocument?id=14397
Ocala PD Business Emergency Contact Form	https://www.ocalapd.com/home/showdocument?id=5135
Ocala PD Citizen Complaint Form	https://www.ocalapd.com/home/showdocument?id=8893
Ocala PD Citizen Report Form	https://www.ocalapd.com/home/showdocument?id=5143
Seniors Versus Crime Program Volunteer Application	https://www.ocalapd.com/home/showdocument?id=5153
Agreement for Police Special Duty Officers	https://www.ocalapd.com/home/showdocument?id=5155
Ocala PD Volunteer Application	https://www.ocalapd.com/home/showdocument?id=5157
PACC Summer Camp Application	https://www.ocalapd.com/home/showdocument?id=13205
Alarm Emergency Contact Form	https://www.ocalapd.com/reports/forms-documents/alarm-emergency-contact-form
Ocala PD Online Reporting	https://www.ocalapd.com/i-want-to/file-a-police-report
Residential Internet Inquiry	https://www.ocalafl.org/government/city-departments-j-z/ocala-fiber-network/residential-internet-inquiry
Business Internet Service Request	https://www.ocalafl.org/government/city-departments-j-z/telecommunications/shared-business-internet/internet-service-request
TPO Feedback Form	https://www.ocalamariontpo.org/what-we-do/tpo-feedback-form
TPS Enotification	https://www.ocalamariontpo.org/who-we-are/advanced-components/enotification
SunTran Feedback Form	https://www.suntran.org/how-to-ride/suntran-feedback-form
Suntran eNotification	https://www.suntran.org/about-us/advanced-components/enotification

City of Ocala
Documents, Forms, and Videos Review

Documents / Forms / Videos Name	Reference Link
SunTran Employment Application	https://www.suntran.org/home/showdocument?id=9071
Streetlight Outage Report Form	https://www.ocalafl.org/government/city-departments/utility-services/electric-utility/report-a-problem/streetlight-outage-report-form
Report a Utility Theft	https://www.ocalafl.org/government/city-departments/electric-utility/report-a-problem/utility-theft
Bus Stop Lighting	https://www.ocalafl.org/government/city-departments/electric-utility/report-a-problem/bus-stop-lighting
Sponsorship Request Form	https://www.ocalafl.org/government/city-departments-a-i/electric-utility/public-power/sponsorship-request-form
Rebate Form - Solar Water Heater	https://www.ocalafl.org/home/showdocument?id=14893
Rebate Form - Refrigerator	https://www.ocalafl.org/home/showdocument?id=14759
Rebate Form - Programmable Thermostat	https://www.ocalafl.org/home/showdocument?id=14761
Rebate Form - Freezer	https://www.ocalafl.org/home/showdocument?id=14763
Rebate Form - Dishwasher	https://www.ocalafl.org/home/showdocument?id=14755
Rebate Form - Clothes Washer	https://www.ocalafl.org/home/showdocument?id=14753
Rebate Form - Attic Insulation	https://www.ocalafl.org/home/showdocument?id=14749
Rebate Form - Air Conditioner/Heat Pump	https://www.ocalafl.org/home/showdocument?id=15045
Rebate Form - Heat Pump Water Heater	https://www.ocalafl.org/home/showdocument?id=14897
Rebate Form - Package Terminal AC or Heat Pump	https://www.ocalafl.org/home/showdocument?id=14899
Rebate Form - Commercial Lighting	https://www.ocalafl.org/home/showdocument?id=14757
Tree Pruning Request	https://www.ocalafl.org/government/city-departments/electric-utility/vegetation-management/tree-pruning-request
Mulch Delivery Request	https://www.ocalafl.org/government/city-departments/utility-services/electric-utility/vegetation-management/mulch-delivery-request
Solar/Net Metering Customer Checklist	https://www.ocalafl.org/home/showdocument?id=6752
Electric Utility Contact Us	https://www.ocalafl.org/government/city-departments/utility-services/electric-utility/contact-us
Procurement - Contact Us	http://bidocala.com/contact-us/
New Vendor Registration	https://vendors.worldprocurementusa.com/SignUp/CompanyInfo.aspx
Procurement Enotification	https://www.ocalafl.org/services/advanced-components/enotification
Bid Bond	http://bidocala.com/wp-content/uploads/Bid-Bond.pdf
Common Carrier Insurance Waiver Request	http://bidocala.com/wp-content/uploads/Common-Carrier-Insurance-Waiver-Request.pdf
Local Vendor Affidavit	http://bidocala.com/wp-content/uploads/Local-Vendor-Affidavit.pdf
Maintenance and Guarantee Bond, 1 Year	http://bidocala.com/wp-content/uploads/Maintenance-and-Guarantee-Bond-1-Year.pdf
Maintenance and Guarantee Bond, 2 Years	http://bidocala.com/wp-content/uploads/Maintenance-and-Guarantee-Bond-2-Years.pdf
Maintenance and Guarantee Bond, 3 Years	http://bidocala.com/wp-content/uploads/Maintenance-and-Guarantee-Bond-3-Years.pdf
Manufacturer's Certificate of Proper Installation	http://bidocala.com/wp-content/uploads/Manufacturers-Certificate-of-Proper-Installation.pdf
Vendor Information Form	http://bidocala.com/wp-content/uploads/New-Vendor-Information-Form.pdf
O&M Drawing Submittal	http://bidocala.com/wp-content/uploads/OM-Drawing-Submittal.pdf
Officer and Employee Disclosure Statement	http://bidocala.com/wp-content/uploads/Officer-and-Employee-Disclosure-Statement-and-Intro.pdf
Public Construction Bond	http://bidocala.com/wp-content/uploads/Public-Construction-Bond.pdf
Workers Compensation Exemption Affidavit	http://bidocala.com/wp-content/uploads/Workers-Compensation-Exemption-Affidavit.pdf
Sewer Verification Waiver	https://www.ocalafl.org/Home/ShowDocument?id=3123
Water Resources Internship Application	https://www.ocalafl.org/Home/ShowDocument?id=12734
Citizen Reporter	http://crwtrakit.ocalafl.org/etrakit3/CRM/issue.aspx

City of Ocala
Documents, Forms, and Videos Review

Documents / Forms / Videos Name	Reference Link
Code Red - Community Notification Enrollment	https://public.coderedweb.com/CNE/en-US/70D689CF4947
Community Cash Sponsorship Application	https://www.ocalafl.org/Home/ShowDocument?id=14209
City Feedback	https://www.ocalafl.org/government/city-departments-a-i/city-manager-s-office/city-feedback
Pet Waste Pledge	https://www.ocalafl.org/home/showdocument?id=4328
R.O.W. Utilization Permit Application	https://www.ocalafl.org/Home/ShowDocument?id=10308
Final Brownfield Grant 2017	https://www.ocalafl.org/Home/ShowDocument?id=3880
New Residential Municipal Services Request	https://forms.ocalafl.org/AppNet/UnityForm.aspx?key=UFKey
Service Disconnect Request	https://www.ocalafl.org/government/city-departments-j-z/utility-services/customer-service-office/service-disconnect-request
Residential Transfer Service Request	https://www.ocalafl.org/government/city-departments-a-i/customer-service-office/my-account-info/transfer-service-request
Commercial Utility and Billed Services	https://www.ocalafl.org/home/showdocument?id=16066
Contract and Deposit Agreement Residential Utility and Billed Services - Prepaid	https://www.ocalafl.org/home/showdocument?id=16064
Contract and Deposit Agreement Residential Utility and Billed Services - Billed	https://www.ocalafl.org/home/showdocument?id=16062
City of Ocala Wellness Incentive	https://www.ocalafl.org/home/showdocument?id=15744
Charity Domination Form	https://www.ocalafl.org/home/showdocument?id=15855
Direct Deposit	https://www.ocalafl.org/home/showdocument?id=5275
Duty Status Form	https://www.ocalafl.org/home/showdocument?id=2731
Claim for Damages	https://www.ocalafl.org/home/showdocument?id=7290
Change of Address	https://www.ocalafl.org/home/showdocument?id=5300
Blue Cross Blue Shield Claim Form	https://www.ocalafl.org/home/showdocument?id=5292
PrimeMail RX Order Form	https://www.ocalafl.org/home/showdocument?id=5293
Florida Blue Appeals Form	https://www.ocalafl.org/home/showdocument?id=5276
The Standard Dental Claim Form	https://www.ocalafl.org/home/showdocument?id=6941
The Standard Out-of-Network Claim Form	https://www.ocalafl.org/home/showdocument?id=6943
MetLife Enrollment Form LTD	https://www.ocalafl.org/home/showdocument?id=5281
MetLife Disability Claim Form EE	https://www.ocalafl.org/home/showdocument?id=5284
MetLife Disability Claim Form ER	https://www.ocalafl.org/home/showdocument?id=5283
MetLife Disability Claim Form Physician Statement	https://www.ocalafl.org/home/showdocument?id=5282
Allstate Wellness Claim Form	https://www.ocalafl.org/home/showdocument?id=5289
Outpatient Physician's Treatment Benefit Claim Form	https://www.ocalafl.org/home/showdocument?id=5291
Allstate Enrollment Form	https://www.ocalafl.org/home/showdocument?id=5290
Allstate Evidence of Insurability	https://www.ocalafl.org/home/showdocument?id=5288
Allstate Cancer/Critical Illness Claim Form	https://www.ocalafl.org/home/showdocument?id=5287
Allstate Accident Claim Form	https://www.ocalafl.org/home/showdocument?id=5286
Beneficiary Designation	https://www.ocalafl.org/home/showdocument?id=15756
Request for Pension Estimate	https://www.ocalafl.org/home/showdocument?id=15746
City of Ocala Pension Beneficiary	https://www.ocalafl.org/home/showdocument?id=1335
Pension Department Change of Address Form	https://www.ocalafl.org/home/showdocument?id=17562
Retiree Direct Deposit Form	https://www.ocalafl.org/home/showdocument?id=17564
Retiree Contact Information Update Form	https://www.ocalafl.org/home/showdocument?id=15895
Retiree Change of Surname	https://www.ocalafl.org/home/showdocument?id=15897
Withholding Certificate for Pension or Annuity Payments	https://www.ocalafl.org/home/showdocument?id=15750
Report a Web Accessibility Issue	https://www.ocalafl.org/government/city-departments-a-i/information-technology/report-a-web-accessibility-issue
Webmaster Feedback Form	https://www.ocalafl.org/government/city-departments/information-technology/webmaster-feedback-form
Smoke Detector Request Form	https://www.ocalafl.org/government/city-departments/fire-rescue/smoke-detector-request-form
Citizen CPR Request Form	https://www.ocalafl.org/government/city-departments/fire-rescue/citizen-s-cpr
Fire Rescue Mentorship Request Form	https://www.ocalafl.org/government/city-departments/fire-rescue/coaching-mentoring-program

**City of Ocala
Documents, Forms, and Videos Review**

Documents / Forms / Videos Name	Reference Link
Door Alarm Request Form	https://www.ocalafl.org/government/city-departments-a-i/fire-rescue/community-outreach/fire-station-tours/door-alarm-request
Emergency Notification Registration	https://public.coderedweb.com/CNE/en-US/70D689CF4947
T-Hanger Lease Interest Form	https://www.ocalafl.org/home/showdocument?id=15803
Airport Identification Badge Application	https://www.ocalafl.org/home/showdocument?id=12879
Ocala Airport Agreement Under Standards Exhibit C-1	https://www.ocalafl.org/home/showdocument?id=660
Ocala Airport Ground Lease	https://www.ocalafl.org/home/showdocument?id=662
T-Hangar Lease Agreement	https://www.ocalafl.org/home/showdocument?id=668
Permit for Temporary Street, Alley, Sidewalk, Parade, or Procession Closure	https://www.ocalafl.org/Home/ShowDocument?id=674
Adopt-A-Street Program	https://www.ocalafl.org/Home/ShowDocument?id=4320
City of Ocala Parks Survey Monkey	https://www.surveymonkey.com/r/CityofOcalaParks
Let them Play Scholarship Fund	https://apm.activecommunities.com/ocalamarioncounty/ActiveNet_Home/onlineDonationDetail.sdi?oc=ShoppingCart&campaign_id=15&online=true&sdireqauth=1426797547403
City of Ocala Recreation & Parks Facility Event Application	https://www.ocalafl.org/home/showdocument?id=15027
Art in City Spaces Exhibit Application	https://www.ocalafl.org/home/showdocument?id=14685
First Friday Visual Artist Registration	https://www.ocalafl.org/home/showdocument?id=15484
First Friday Performing Artist Registration	https://www.ocalafl.org/home/showdocument?id=15482
First Friday Arts Organization Registration	https://www.ocalafl.org/home/showdocument?id=15574
First Friday Downtown Business Registration	https://www.ocalafl.org/home/showdocument?id=15572
Ocala Municipal Arts Commission Grant Program	https://www.ocalafl.org/home/showdocument?id=15514
City of Ocala Volunteer Application	https://www.ocalafl.org/home/showdocument?id=2334
Undergraduate Internship Application	https://www.ocalafl.org/home/showdocument?id=692
Intern Program Interest Form	https://www.ocalafl.org/home/showdocument?id=2424
Events Summary Registration Form	https://www.ocalafl.org/home/showdocument?id=2465
Special Event Permit Application	https://www.ocalafl.org/home/showdocument?id=2471
Community Sponsorship Policy	https://www.ocalafl.org/home/showdocument?id=678
City of Ocala Recreation and Parks Vendor Mailing List	https://us15.list-manage.com/subscribe?u=e693401d5956d382262d6faa5&id=68efb86135
35th Annual Light up Ocala Vendor Application	https://form.jotform.com/81204147742148
Light Up Ocala Even Sponsorship	https://www.ocalafl.org/home/showdocument?id=15140
Recreation and Parks ADA Website Information	https://www.ocalafl.org/Home/ShowDocument?id=676
Community Garden Application and Participation Rules	https://www.ocalafl.org/Home/ShowDocument?id=2460
Concessionaire Application	https://www.ocalafl.org/Home/ShowDocument?id=680
Metal Detecting Excavation Permit	https://www.ocalafl.org/Home/ShowDocument?id=4337
Noise Permit Application	https://www.ocalafl.org/Home/ShowDocument?id=2467
Contract and Deposit Agreement Residential Utility and Billed Services	https://www.ocalafl.org/home/showdocument?id=16064
Requesting a Payment Extension	https://www.ocalafl.org/government/city-departments-j-z/utility-services/customer-service-office/my-account-info/payment-extension
Ocala Electric Utility Application for Medical Alert Customer Status	https://www.ocalafl.org/home/showdocument?id=2135
Update Contact Information	https://www.ocalafl.org/government/city-departments-j-z/utility-services/customer-service-office/update-contact-information
Abandoned Property Registration Form	https://www.ocalafl.org/Home/ShowDocument?id=1967
Fictitious Name Registration Affidavit of Compliance	https://www.ocalafl.org/Home/ShowDocument?id=156
Alcohol Permit	https://www.ocalafl.org/Home/ShowDocument?id=158
Bingo Application	https://www.ocalafl.org/Home/ShowDocument?id=16001
Business Tax Certificate Application	https://www.ocalafl.org/Home/ShowDocument?id=162
Non-Profit Car Wash Even Application	https://www.ocalafl.org/Home/ShowDocument?id=164
Doggy Dining Permit Application	https://www.ocalafl.org/Home/ShowDocument?id=166
Electric Fence License Application	https://www.ocalafl.org/Home/ShowDocument?id=168
Gun Range Permit Application	https://www.ocalafl.org/Home/ShowDocument?id=170
Home Occupational License Application	https://www.ocalafl.org/Home/ShowDocument?id=172
Juvenile Dance Hall Application	https://www.ocalafl.org/Home/ShowDocument?id=17488
Mobile Auto Detailing	https://www.ocalafl.org/Home/ShowDocument?id=14319

City of Ocala
Documents, Forms, and Videos Review

Documents / Forms / Videos Name	Reference Link
Mobile Vendor Guidelines and Application	https://www.ocalafl.org/Home/ShowDocument?id=176
Pawnbroker: Second Hand Dealers License	https://www.ocalafl.org/Home/ShowDocument?id=178
Sidewalk Café Application	https://www.ocalafl.org/Home/ShowDocument?id=180
Alcohol Permit for Special Events	https://www.ocalafl.org/Home/ShowDocument?id=184
Teenage Dance Application	https://www.ocalafl.org/Home/ShowDocument?id=186
Transportation Franchise Application	https://www.ocalafl.org/Home/ShowDocument?id=188
Valet Parking Application and Indemnification Agreement	https://www.ocalafl.org/Home/ShowDocument?id=190
Valet Parking Renewal Application	https://www.ocalafl.org/Home/ShowDocument?id=192
Contractor Certification Application	https://www.ocalafl.org/home/showdocument?id=2073
Letter of Authorization	https://www.ocalafl.org/home/showdocument?id=2079
State Certified Contractor Form	https://www.ocalafl.org/home/showdocument?id=3768
Address Request Application	https://www.ocalafl.org/Home/ShowDocument?id=64
Affidavit of Compliance	https://www.ocalafl.org/Home/ShowDocument?id=66
Asbestos Renovation or Demolition Application	https://www.ocalafl.org/Home/ShowDocument?id=70
Blower Door Test Form	https://www.ocalafl.org/Home/ShowDocument?id=14815
Change of Contractor Authorization fill form	https://www.ocalafl.org/Home/ShowDocument?id=7643
Commercial Plan Check List	https://www.ocalafl.org/Home/ShowDocument?id=72
Construction Permit Application	https://www.ocalafl.org/Home/ShowDocument?id=6970
Construction Permit Revisions - Fill Form	https://www.ocalafl.org/Home/ShowDocument?id=7643
Demolition Permit	https://www.ocalafl.org/Home/ShowDocument?id=78
Demolition Permit (Off-Site Advertising Signs)	https://www.ocalafl.org/Home/ShowDocument?id=80
Driveway Permit Application	https://www.ocalafl.org/Home/ShowDocument?id=82
Gas Calculation Worksheet	https://www.ocalafl.org/Home/ShowDocument?id=8841
Gas Piping Test Affidavit	https://www.ocalafl.org/Home/ShowDocument?id=8841
House Moving Permit	https://www.ocalafl.org/Home/ShowDocument?id=90
Mobile Home Inspections	https://www.ocalafl.org/Home/ShowDocument?id=12448
New Commercial Plumbing Quantity Sheet	https://www.ocalafl.org/Home/ShowDocument?id=6974
Notice of Commencement	https://www.ocalafl.org/Home/ShowDocument?id=96
Notice of Termination	https://www.ocalafl.org/Home/ShowDocument?id=98
Owner - Builder Statement	https://www.ocalafl.org/Home/ShowDocument?id=100
Permit Extension Request	https://www.ocalafl.org/Home/ShowDocument?id=15065
Permit Revision Request Fill Form	https://www.ocalafl.org/Home/ShowDocument?id=102
Preliminary Inspection Request	https://www.ocalafl.org/Home/ShowDocument?id=17088
Product Approval Spec Sheet	https://www.ocalafl.org/Home/ShowDocument?id=104
Residential Plan Checklist	https://www.ocalafl.org/Home/ShowDocument?id=106
Roofing Affidavit	https://www.ocalafl.org/Home/ShowDocument?id=15216
Sign Permit - Permanent	https://www.ocalafl.org/Home/ShowDocument?id=110
Sign Permit - Temporary	https://www.ocalafl.org/Home/ShowDocument?id=112
Tent Permit Application	https://www.ocalafl.org/Home/ShowDocument?id=114
Threshold Building Affidavit	https://www.ocalafl.org/Home/ShowDocument?id=5055
Tree Removal Permit Application	https://www.ocalafl.org/Home/ShowDocument?id=116
Annexation Agreement	https://www.ocalafl.org/Home/ShowDocument?id=4
Appeal of Address Change to Board of Adjustment	https://www.ocalafl.org/Home/ShowDocument?id=6974
Appeal from the Decision of the Building Official	https://www.ocalafl.org/Home/ShowDocument?id=8841
Certificate of Appropriateness	https://www.ocalafl.org/Home/ShowDocument?id=4370
Certificate of Appropriateness - Demolition	https://www.ocalafl.org/Home/ShowDocument?id=4372
Comprehensive Plan Amendment	https://www.ocalafl.org/Home/ShowDocument?id=14
Developers Agreement	https://www.ocalafl.org/Home/ShowDocument?id=20
Division of Reconfiguration of Land Request	https://www.ocalafl.org/Home/ShowDocument?id=17610
Land Development Regulation Amendment Request	https://www.ocalafl.org/Home/ShowDocument?id=22
Land Use Amendment Large Scale	https://www.ocalafl.org/Home/ShowDocument?id=24
Land Use Amendment Small Scale	https://www.ocalafl.org/Home/ShowDocument?id=26
Land Use and Zoning Request for Information	https://www.ocalafl.org/Home/ShowDocument?id=2700
Minor Site Plan Approval	https://www.ocalafl.org/Home/ShowDocument?id=28
Preapplication Meeting Request fill Form	https://www.ocalafl.org/Home/ShowDocument?id=17828
Pre-Conceptual Shopping Center Plan Application	https://www.ocalafl.org/Home/ShowDocument?id=30
Project Completion Certification	https://www.ocalafl.org/Home/ShowDocument?id=2905

City of Ocala
Documents, Forms, and Videos Review

Documents / Forms / Videos Name	Reference Link
Public Hearing Request	https://www.ocalafl.org/Home/ShowDocument?id=32
PUD Amendment	https://www.ocalafl.org/Home/ShowDocument?id=34
PUD Rezoning	https://www.ocalafl.org/Home/ShowDocument?id=36
Request for Abrogation or Plat Vacation	https://www.ocalafl.org/Home/ShowDocument?id=38
Request for Rezoning	https://www.ocalafl.org/Home/ShowDocument?id=40
Request Rezoning Small Scale Land Use	https://www.ocalafl.org/Home/ShowDocument?id=42
RZL Rezoning	https://www.ocalafl.org/Home/ShowDocument?id=44
Shopping Center Rezoning	https://www.ocalafl.org/Home/ShowDocument?id=46
Sidewalk Waiver Request Form	https://www.ocalafl.org/Home/ShowDocument?id=2904
Signage Public Hearing	https://www.ocalafl.org/Home/ShowDocument?id=48
Site Plan Package Application and Checklists	https://www.ocalafl.org/Home/ShowDocument?id=52
Special Exceptions	https://www.ocalafl.org/Home/ShowDocument?id=54
Statement for Maintenance of Improvements	https://www.ocalafl.org/Home/ShowDocument?id=2902
Street-Specific Setback Reduction Request	https://www.ocalafl.org/Home/ShowDocument?id=15059
Subdivision Application Step 1 Preconceptual	https://www.ocalafl.org/Home/ShowDocument?id=7248
Subdivision Application Step 2 Conceptual	https://www.ocalafl.org/Home/ShowDocument?id=7250
Subdivision Application Step 3 Improvement Plan	https://www.ocalafl.org/Home/ShowDocument?id=7252
Subdivision Application Step 4 Final Plat	https://www.ocalafl.org/Home/ShowDocument?id=7254
Tree Restoration Plan Application	https://www.ocalafl.org/Home/ShowDocument?id=56
Variance	https://www.ocalafl.org/Home/ShowDocument?id=58
Voluntary Annexation Petition	https://www.ocalafl.org/Home/ShowDocument?id=60
Parking Contract Application	https://www.ocalafl.org/Home/ShowDocument?id=2849
Freight Zone Contract Application	https://www.ocalafl.org/Home/ShowDocument?id=2849
Ansafone Parking Contract Application	https://www.ocalafl.org/Home/ShowDocument?id=2851
Downtown CRA Grant Application	https://www.ocalafl.org/home/showdocument?id=17682
North Magnolia CRA Grant Application	https://www.ocalafl.org/home/showdocument?id=17684
West Ocala CRA Grant Application	https://www.ocalafl.org/home/showdocument?id=17686
East Ocala CRA Grant Application	https://www.ocalafl.org/home/showdocument?id=14397
Ocala PD Business Emergency Contact Form	https://www.ocalapd.com/home/showdocument?id=5135
Ocala PD Citizen Complaint Form	https://www.ocalapd.com/home/showdocument?id=8893
Ocala PD Citizen Report Form	https://www.ocalapd.com/home/showdocument?id=5143
Seniors Versus Crime Program Volunteer Application	https://www.ocalapd.com/home/showdocument?id=5153
Agreement for Police Special Duty Officers	https://www.ocalapd.com/home/showdocument?id=5155
Ocala PD Volunteer Application	https://www.ocalapd.com/home/showdocument?id=5157
PACC Summer Camp Application	https://www.ocalapd.com/home/showdocument?id=13205
Alarm Emergency Contact Form	https://www.ocalapd.com/reports/forms-documents/alarm-emergency-contact-form
Ocala PD Online Reporting	https://www.ocalapd.com/i-want-to/file-a-police-report
Residential Internet Inquiry	https://www.ocalafl.org/government/city-departments-j-z/ocala-fiber-network/residential-internet-inquiry
Business Internet Service Request	https://www.ocalafl.org/government/city-departments-j-z/telecommunications/shared-business-internet/internet-service-request
TPO Feedback Form	https://www.ocalamariontpo.org/what-we-do/tpo-feedback-form
TPS Enotification	https://www.ocalamariontpo.org/who-we-are/advanced-components/enotification
SunTran Feedback Form	https://www.suntran.org/how-to-ride/suntran-feedback-form
Suntran eNotification	https://www.suntran.org/about-us/advanced-components/enotification
SunTran Employment Application	https://www.suntran.org/home/showdocument?id=9071
Streetlight Outage Report Form	https://www.ocalafl.org/government/city-departments/utility-services/electric-utility/report-a-problem/streetlight-outage-report-form
Report a Utility Theft	https://www.ocalafl.org/government/city-departments/electric-utility/report-a-problem/utility-theft
Bus Stop Lighting	https://www.ocalafl.org/government/city-departments/electric-utility/report-a-problem/bus-stop-lighting

City of Ocala
Documents, Forms, and Videos Review

Documents / Forms / Videos Name	Reference Link
Sponsorship Request Form	https://www.ocalafl.org/government/city-departments-a-i/electric-utility/public-power/sponsorship-request-form
Rebate Form - Solar Water Heater	https://www.ocalafl.org/home/showdocument?id=14893
Rebate Form - Refrigerator	https://www.ocalafl.org/home/showdocument?id=14759
Rebate Form - Programmable Thermostat	https://www.ocalafl.org/home/showdocument?id=14761
Rebate Form - Freezer	https://www.ocalafl.org/home/showdocument?id=14763
Rebate Form - Dishwasher	https://www.ocalafl.org/home/showdocument?id=14755
Rebate Form - Clothes Washer	https://www.ocalafl.org/home/showdocument?id=14753
Rebate Form - Attic Insulation	https://www.ocalafl.org/home/showdocument?id=14749
Rebate Form - Air Conditioner/Heat Pump	https://www.ocalafl.org/home/showdocument?id=15045
Rebate Form - Heat Pump Water Heater	https://www.ocalafl.org/home/showdocument?id=14897
Rebate Form - Package Terminal AC or Heat Pump	https://www.ocalafl.org/home/showdocument?id=14899
Rebate Form - Commercial Lighting	https://www.ocalafl.org/home/showdocument?id=14757
Tree Pruning Request	https://www.ocalafl.org/government/city-departments/electric-utility/vegetation-management/tree-pruning-request
Mulch Delivery Request	https://www.ocalafl.org/government/city-departments/utility-services/electric-utility/vegetation-management/mulch-delivery-request
Solar/Net Metering Customer Checklist	https://www.ocalafl.org/home/showdocument?id=6752
Electric Utility Contact Us	https://www.ocalafl.org/government/city-departments/utility-services/electric-utility/contact-us
Procurement - Contact Us	http://bidocala.com/contact-us/
New Vendor Registration	https://vendors.worldprocurementusa.com/SignUp/CompanyInfo.aspx
Procurement Enotification	https://www.ocalafl.org/services/advanced-components/enotification
Bid Bond	http://bidocala.com/wp-content/uploads/Bid-Bond.pdf
Common Carrier Insurance Waiver Request	http://bidocala.com/wp-content/uploads/Common-Carrier-Insurance-Waiver-Request.pdf
Local Vendor Affidavit	http://bidocala.com/wp-content/uploads/Local-Vendor-Affidavit.pdf
Maintenance and Guarantee Bond, 1 Year	http://bidocala.com/wp-content/uploads/Maintenance-and-Guarantee-Bond-1-Year.pdf
Maintenance and Guarantee Bond, 2 Years	http://bidocala.com/wp-content/uploads/Maintenance-and-Guarantee-Bond-2-Years.pdf
Maintenance and Guarantee Bond, 3 Years	http://bidocala.com/wp-content/uploads/Maintenance-and-Guarantee-Bond-3-Years.pdf
Manufacturer's Certificate of Proper Installation	http://bidocala.com/wp-content/uploads/Manufacturers-Certificate-of-Proper-Installation.pdf
Vendor Information Form	http://bidocala.com/wp-content/uploads/New-Vendor-Information-Form.pdf
O&M Drawing Submittal	http://bidocala.com/wp-content/uploads/OM-Drawing-Submittal.pdf
Officer and Employee Disclosure Statement	http://bidocala.com/wp-content/uploads/Officer-and-Employee-Disclosure-Statement-and-Intro.pdf
Public Construction Bond	http://bidocala.com/wp-content/uploads/Public-Construction-Bond.pdf
Workers Compensation Exemption Affidavit	http://bidocala.com/wp-content/uploads/Workers-Compensation-Exemption-Affidavit.pdf
Sewer Verification Waiver	https://www.ocalafl.org/Home/ShowDocument?id=3123
Water Resources Internship Application	https://www.ocalafl.org/Home/ShowDocument?id=12734

Appendix D: Federal Highway Administration ADA Transition Plan Process Memo



U.S. Department
of Transportation
**Federal Highway
Administration**

Memorandum

Subject: **INFORMATION AND ACTION:**
ADA Transition Plan Process

Date: NOV 17 2015

From: Irene Rico 
Acting Associate Administrator for
Civil Rights

In Reply Refer To:
HCR-20

To: Division Administrators
Division Civil Rights Specialists

**THIS MEMORANDUM SUPERSEDES THE OFFICE OF CIVIL RIGHTS' (HCR)
NOVEMBER 17, 2014 MEMORANDUM ("INFORMATION AND ACTION:
SUBMISSIONS OF STATE ADA TRANSITION PLANS") IN ITS ENTIRETY.**

Purpose and Background:

The purpose of this memorandum is to describe the process that the Federal Highway Administration (FHWA) has developed to review Americans with Disabilities Act (ADA) transition plans prepared by State Departments of Transportation (DOTs) and to facilitate State DOTs' compliance with the ADA transition plan requirements. In particular, this memorandum:

- 1) Describes the Working Group and Review Team framework within which the FHWA ADA transition plan review process was developed and next steps to achieve ADA transition plan compliance by all State DOTs;
- 2) Identifies the minimum required attributes that need to be included in a State's ADA transition plan;
- 3) Describes the review process FHWA will implement for determining the status of a State's ADA transition plan;
- 4) Explains FHWA's jurisdictional authority to review State DOT ADA transition plans; and
- 5) Describes the connection between a State's Statewide Transportation Improvement Program (STIP) and the transition plan regulatory requirement.

As background, on November 17, 2014, the FHWA's Office of Civil Rights (HCR) issued a memorandum titled "**INFORMATION AND ACTION: Submissions of State ADA Transition Plans.**" That memorandum sought to clarify FHWA's policies and procedures with regard to State DOT ADA transition plan requirements and requested that FHWA Division Offices review their State's transition plan for compliance with regulatory requirements. As State DOTs

submitted their ADA transition plans, HCR began receiving questions from Division Administrators concerning a transition plan's required attributes.

ADA Transition Plan Working Group and Review Team:

With the amount of interest in the topic, the Associate Administrator for the Office of Civil Rights and the Chair of the Division Administrator (DA) Civil Rights Advisory Group agreed that it would be beneficial to create a Working Group to develop guidance on the transition plan attributes that are consistent with regulatory requirements. The Working Group was established in the Summer of 2015 with the following members: Tom Smith, DA West Virginia; James Christian, DA Florida; Joe Werning, DA Nebraska; Karla Petty, DA Arizona; Amy Jackson-Grove, DA Connecticut; Gary Corino, DA Oklahoma; Joseph Daily, DA Wyoming; Jim Esselman, FHWA Office of Chief Counsel; Warren Whitlock, AA Office of Civil Rights; Candace Groudine, HCR; Nichole Mcwhorter, HCR; Connie Yew, HCR; Elizabeth Hilton, Office of Infrastructure; Patrick Gomez, Resource Center (RC).

The effort began with two, all-day face-to-face meetings in July 2015 to discuss in depth, the broad range of challenges faced by States in completing their ADA transition plans, as well as the need to clarify for the States what is required by the regulations to ensure compliance with the ADA. Shortly after those meetings, a smaller, break-out team (referred to as the "ADA transition plan Review Team," hereinafter, "Review Team") was created by the Working Group and charged with the responsibility to identify minimum attributes that FHWA should evaluate in determining the adequacy of a State's ADA transition plan. This team also discussed how to address the large number of transition plans that had already been reviewed and accepted by Divisions. The Review Team consists of the following individuals: Tom Smith, DA West Virginia; Amy Jackson-Grove, DA Connecticut; Jim Esselman, Office of Chief Counsel; Elizabeth Hilton, Office of Infrastructure; Candace Groudine, Office of Civil Rights; and Patrick Gomez, RC. Each team member had also been a member of the larger Working Group.

In August 2015, the "What's Hot Webinar" hosted by the Division Administrators' Council (DAC) included discussion about the ADA Transition Plan Working Group and Review Team and a high level summary of what was emerging from the team's work.

At the September 2015 Fall Business Meeting's DAC Session, HCR provided an update on the efforts from the Working Group and Review Team, and requested feedback from all the Division Administrators.

Minimum Required Attributes:

The Review Team has identified a list of minimum required attributes that need to be included within a State's ADA transition plan. Each of these minimum required attributes corresponds with the minimum transition plan requirements set forth in the U.S. Department of Justice's (DOJ's) ADA Title II regulations at 28 CFR 35.150(d).

The attributes that are required to be included in a State's ADA transition plan consist of the following:

- 1) Identification of the official responsible for implementation of the transition plan (See 28 CFR 35.150(d)(3)(iv));
- 2) An inventory of barriers (i.e., identification of physical obstacles); (See 28 CFR 35.150(d)(3)(i) & 28 CFR 35.150(a));
- 3) A prioritized schedule of when barriers will be eliminated and deficiencies corrected (See 28 CFR 35.150(d)(2) & 28 CFR 25.150(d)(3)(iii)); and
- 4) A description of the methods that will be used to make facilities accessible (See 28 CFR 35.150(d)(3)(ii)).

More details about each attribute is provided in the attached “State DOT Transition Plan Attributes Review Guide” (Review Guide) that was presented during the October 13, 2015 webinar about the review process for Division Administrators and Civil Rights Specialists.

Review Process:

The following is a brief overview of the review process that FHWA will employ, using the Review Guide as a tool, for determining the status of a State’s ADA transition plan:

- After a State DOT submits its ADA transition plan to the State’s FHWA Division Office, the Division’s Civil Rights Specialist will conduct an initial review based on the Review Guide and brief the Division Administrator on his or her assessment.
- If the Division Administrator and Civil Rights Specialist believe the State’s transition plan does not meet the minimum attributes, they should work with the State DOT to address the identified deficiencies.
- When the Division Administrator and the Civil Rights Specialist are satisfied with the condition of the transition plan, the Division Administrator will then submit the transition plan to HCR.
- Upon receipt, HCR will convene the transition plan Review Team to review the plan; and
- The Review Team will meet with the Division Administrator and the Civil Rights Specialist to discuss the plan and provide recommendations, if needed. The Civil Rights Specialist will work with the State DOT to ensure that its plan contains the minimum attributes, to reconcile any recommendations, to finalize the plan, and then forward the plan to HCR for tracking purposes.

For States that previously submitted a transition plan that its FHWA Division Office accepted prior to the issuance of this memorandum, the Review Team will develop a schedule to review those plans in Fiscal Year 2016. If a State needs to make additional efforts to achieve consistency with the minimum attributes, the Review Team will advise the Division Administrator accordingly, but the Review Team does not anticipate changing the accepted status of those plans.

FHWA’s Jurisdictional Authority:

The DOJ is the Federal agency responsible for coordinating the activities of Federal agencies with respect to State and local government compliance with Title II of the ADA. The DOJ,

through its regulations at 28 CFR 35.190, has delegated authority to the U.S. Department of Transportation (DOT) to oversee and implement ADA compliance for all State and local governments that regulate or administer services, programs, or activities relating to transportation. The DOT has further delegated authority to FHWA to oversee and implement ADA compliance for State and local governments for issues affecting transportation in the public right-of-way. In addition, under 49 CFR 27.19, DOT recipients must comply with DOJ's ADA regulations to be considered in compliance with DOT's regulations under Section 504 of the Rehabilitation Act of 1973 (Section 504).

FHWA Division Offices work with State DOTs to ensure that the ADA and Section 504 requirements are incorporated in all program activities for projects within the public rights-of-way. The Section 504 regulations, at 49 CFR 27.11, require FHWA to monitor a State DOT's compliance with the ADA, including DOJ and DOT regulations that address self-evaluation and transition plans.

Requirements for Certifying that the State has an ADA Transition Plan that is Consistent with the Regulations:

At least every four years, States are required to submit an updated State Transportation Improvement Program (STIP) concurrently to the FHWA and the FTA for joint approval. At the time the STIP or STIP amendments are submitted, States are required to certify that the transportation planning process is being carried out in accordance with all applicable requirements of the provisions of the ADA and Section 504. (See 23 CFR 450.218(a)(6),(10)). Therefore, every four years, the State DOTs are certifying that they meet the requirements of the ADA and Section 504, which in the planning process would include transition plans. The Division can use the Federal approval of the STIP as an opportunity to discuss the ADA transition plan's consistency with the minimum transition plan attributes.

Technical Assistance for Division Offices and States:

HCR and the Resource Center will provide the Division Offices and States with any technical assistance or training that is needed to ensure that States are submitting final draft products that meet the minimum required attributes.

A webinar similar to the one conducted on October 13th will be held for the States within the next several weeks. In the meantime, please note that Division Civil Rights Specialists may share the minimum attributes with Local Public Agencies (LPAs) as needed.

If you have any questions, please contact Nichole McWhorter at nichole.mcwhorter@dot.gov or (202) 366-1396.

Attachment

cc: Directors of Field Services

State _____

State DOT Transition Plan Attributes Review Guide: All Elements posted conspicuously on website, for internal and external use	
Transition Plan Attribute	Review Comments
<p>Official responsible for implementation of the TP, i.e., Executive Director, Secretary, Commissioner, Chief Engineer, etc. 28 CFR 35.150(d)(3)(iv)</p>	
<p>Inventory of barriers (identification of physical obstacles) 28 CFR 35.150(d)(3)(i); 28 CFR 35.105 (a) – State demonstrates good faith by identifying intersection information, including curb ramps and other associated accessibility elements, as a starting point and showing movement and commitment toward developing a full inventory.</p> <p>Require an Action Plan to develop an inventory of sidewalks (slopes, obstructions, protruding objects, changes in levels, etc.), signals (APS), bus stops (bus pads), buildings, parking, rest areas (tourist areas, picnic areas, visitor centers, etc.), mixed use trails, linkages to transit.</p> <p>Best practice - have discussion of jurisdictional issues/responsibilities for sidewalks</p>	
<p>Schedule – Show a strong commitment toward upgrading ADA elements identified in the inventory of barriers in the short term (planned capital improvement projects) and a strong commitment over time toward prioritizing curb ramps at walkways serving entities covered by the ADA. 28 CFR 35.150(d)(2) This would also include prioritization information, planning, and investments directed at eliminating other identified barriers over time. 28 CFR 35.150(d)(3)</p> <p>Best practice - dedicate resources to eliminate identified ADA deficiencies</p>	
<p>Describe in detail the Methods that will be used to make the facilities accessible. 28 CFR 35.150(d)(3)(ii)</p> <p>Best practice – include the Standard that the STA is following (i.e., 2010 ADAAG, 2011 PROWAG)</p>	
Other ADA Requirements	Review Comments
<p>Public Involvement – Description of process to allow public to readily access and submit comments for both self-evaluation and transition plan. 28 CFR 35.150(d)(1); 28 CFR 35.105(b)</p> <p>Best practices: a) detailed list of individuals consulted posted conspicuously on website, does not have to be in actual TP, but must be documented and available; b) have both electronic and hard copy notice. 28 CFR 35.105(c)</p>	
<p>ADA policy statement is a requirement of State Agencies, but does not have to be in the TP per se, but it is a good practice and needs to be easily accessible by the public. 28 CFR 35.106</p> <p>Best practice - post conspicuously on website, for internal and external use</p>	
<p>Clear identification of the ADA Coordinator (dedicated trained staff) with contact information (i.e., name, office address, telephone number, email address, fax number) 28 CFR 35.107(a)</p>	
<p>Clear Complaint/Grievance Process to receive and address complaints/grievances from the public (is a requirement of State Agencies, but does not have to be in the TP per se, but it is a good practice and needs to be easily accessible by the public). 28 CFR 35.107(b)</p>	
<p>REVIEWER _____ DATE _____</p>	

Appendix E: City of Ocala 2015 ADA Transition Plan

E-1: Facility Evaluation Checklist

E-2: 2015 ADA Transition Plan

**OCALA RECREATION & PARKS
ADA TRANSITION PLAN CHECKLIST**

PARK/FACILITY NAME:

ADDRESS:

TYPE OF PARK/FACILITY:

Natural Amenity

Parking

Buildings

Sidewalks/Trails

Signage

Fencing

Benches

Picnic Tables

Picnic Pavilions

Lighting

Trash Receptacles

Fields/Courts

 Basketball

 Baseball

 Tennis

 Racquetball

 Shuffleboard

 Open Field

Grills

Playground

Other

NAME(S) OF SURVEYORS: Julie Johnson, Parks Operations Division Head
Jeff Kerley, Parks Operations Supervisor

DATE OF SURVEY:

**ADA TRANSITION CHECKLIST
PARKING LOTS/AREAS**

PARKING LOT/LOCATION	TOTAL PARKING SPACES	NUMBER ACCESSIBLE	NUMBER VAN ACCESSIBLE

ITEM	COMMENTS	YES	NO	N/A	SECTION
Does each lot/location have the required number of accessible spaces?					208
Does each lot/location have the required number of van accessible spaces?					208
Are locations serving accessible entrances/routes?					206 402 403
Signage (Does it have the correct verbiage and height/size)					501 502
Parking Space Width (Correct width for Car & Van)					501 502
Access Aisle Width (Correct width for Car & Van)					501 502
PASSENGAER LOADING ZONE					
Access Aisle is the correct width.					503
Signage (Is there proper signage)					503
Surveyor Comments:					

**ADA TRANSITION CHECKLIST
WALKING TRAILS**

ITEM	COMMENTS	YES	NO	N/A	SECTION
Are there accessible routes to the walking trail?					206 402 403
Are the slope requirements met?					206 402 403
Does the surfacing meet requirements?					206 402 403
Does the width meet requirements?					206 402 403
Surveyor Comments:					

**ADA TRANSITION CHECKLIST
WATER FEATURES**

ITEM	COMMENTS	YES	NO	N/A	SECTION
Are there accessible routes to all water features?					
Surveyor Comments:					

**ADA TRANSITION CHECKLIST
BENCHES/PICNIC TABLES/BLEACHERS**

ITEM	COMMENTS	YES	NO	N/A	SECTION
Are there accessible routes to all benches, picnic tables and bleachers?					206.2.2 402 403
Is wheel chair seating available at benches, picnic tables and bleachers?					305 805 902.3 903
Do the appropriate number of amenities include a space to accommodate a wheel chair?					305
Surveyor Comments:					

**ADA TRANSITION CHECKLIST
PAVILIONS**

ITEM	COMMENTS	YES	NO	N/A	SECTION
Are there accessible routes to pavilions?					206 402 403
Signage (Is there proper signage)					
Is there maneuvering space available for a wheel chair?					802
Is wheel chair seating available at these structures?					305 802 903
Surveyor Comments:					

ADA TRANSITION CHECKLIST

PLAYGROUNDS

ITEM	COMMENTS	YES	NO	N/A	SECTION
Are there accessible routes to play equipment?					240 206.2.17 402 403 1008
Is the safety surfacing accessible?					1008.2
Is the play equipment a Universally structure?					240.2
Is the play equipment an ADA accessible structure?					240.2
Surveyor Comments:					
7.5 Ft Sidewalk to Swing Set					

**ADA TRANSITION CHECKLIST
DRINKING FOUNTAINS**

ITEM	COMMENTS	YES	NO	N/A	SECTION
Are there accessible routes to 50% of all drinking fountains?					211
Are the fountains accessible by parallel approach/front approach with knee clearance?					306 602
Is the water flow within 3 inches of the front edge of the fountain?					602
Does the spout height meet requirements?					602
Are the controls located in the correct location and operable with one hand?					309 602
Surveyor Comments:					

**ADA TRANSITION CHECKLIST
ATHLETIC COURTS**

ITEM	COMMENTS	YES	NO	N/A	SECTION
Do all courts have an accessible route?					206.2.12 402 403
Gated Courts: Does entrance meet width requirements?					
Surveyor Comments:					

**ADA TRANSITION CHECKLIST
ATHLETIC FIELDS**

ITEM	COMMENTS	YES	NO	N/A	SECTION
Do all fields have an accessible route?					221.5
Are dugouts accessible?					402 403
Is spectator seating ADA accessible with a good line of sight?					221 802
Are there accessible routes to Concession areas?					402 403
Are there accessible routes to Restrooms?					402 403
Surveyor Comments:					

**ADA TRANSITION CHECKLIST
RESTROOMS**

Restroom Location:

ITEM	COMMENTS	YES	NO	N/A	SECTION
Do all restrooms have accessible routes?					206 402 403
Doors meet clearance and location requirements? (Including swing clearance)					404 603.2
Do stall sizes meet requirements?					604
Is there maneuvering space in stall for wheel chair access?					604
Are grab bars the correct height, length and distance from the wall?					604.5
Are all controls in the correct place and meet ADA requirements?					309.2 604.6
Are dispensers at the required height?					308 309.4 308
Do lavatories meet requirements such as height and knee clearance?					306 606
Do Toilets and Urinals meet height requirements?					309 604.4 605
Are mirrors at the minimum height requirement?					603.3
Do sinks meet requirements?					306 606
Is Pipe shielding used and no pipes are exposed?					606
Signage (Is there proper signage?)					703
Surveyor Comments:					

**ADA TRANSITION CHECLISK
BATH TUBS/SHOWERS**

ITEM	COMMENTS	YES	NO	N/A	SECTION
Is there an accessible route to these amenities?					
Doors meet clearance and location requirements? (Including swing clearance)					
Tubs/Showers have ADA accessible seats?					
Are grab bars the correct height, length and distance from the wall?					
Do controls meet requirements and are accessible?					
Are Spraying Unit is available per requirements?					
Roll In Showers: Are curb requirements met?					
Do Showers and stall enclosures meet size requirements?					
Surveyor Comments:					

Ocala Recreation & Parks
ADA Transition Plan

Park/ Facility: Anderson Park

Address: SE 12th Street & SE 11th Avenue

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Accessible routes to Picnic Area	206.2.2 402 403	93 Ft of Sidewalk to Picnic Area	1	City Staff	\$916.00	FY 2018 August 2018	
	Accessible routes to Benches	206.2.2 402 403	75 Ft of Sidewalk to existing bench on concrete pad and add companion seating.	1	City Staff	\$582.00	FY 2018 August 2018	
	Accessible route to Grill	206.2.2 402 403	5 x 5 concrete pad around grill	1	City Staff	\$36.00	FY 2018 August 2018	
	Accessible route to Picnic table	206.2.2 402 403	12 x 18 pad around picnic table.	1	City Staff	\$306.00	FY 2018 August 2018	

TOTAL PROJECTED COST: \$1,840.00

Ocala Recreation & Parks ADA Transition Plan

Park/ Facility: CLYATT PARK

Address: 1400 SE 17TH STREET

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	ADA Accessible Space – Baseball Field	208 501 502	Add two ADA parking spaces with signage make one van accessible.	1	City Staff	\$3,980.00	FY 2013 December 2012	Complete
	ADA Van Accessible Space – Park	208 501 502	Change on existing space to van accessible and add correct signage.	1	City Staff	\$200.00	FY 2013 July 2013	Complete
Picture Above	ADA Parking Signage	501 502	Raise current signs to correct height of 60”.	1	City Staff	\$25.00	FY 2013 July 2013	Complete
	Accessible Route to Picnic Table at Playground	206.2.2 402 403	Need 24 ft on concrete and a 24X36 pad.	2	City Staff	\$1,000.00	FY 2016 November 2015	

	Water Fountain – ADA Accessibility - Playground	306 602	Replace water fountain to meet front approach and parallel approach also to meet spout height requirements.	4	City Staff	\$4,370.00	FY 2016 November 2015	
	Water Fountain – ADA Accessibility - Courts	306 602	Replace water fountain to meet front approach and parallel approach also to meet spout height requirements.	4	City Staff	\$3,800.00	FY 2014 July 2014	Complete
	Accessible Route to Tennis Court	206.2.12 402 403	Move fence in front of gate opening back for wheel chair access.	2	City Staff	\$20.00	FY 2012 September 2012	Complete
	Park Restrooms – Dispenser Height	308 309.4	Move to required height between 41” – 48”.	3	City Staff	No Cost	FY 2012 August 2012	Complete
Picture Above	Park Restrooms – Exposed Pipes	606	Cover exposed 9” piping.	3	City Staff	\$50.00	FY 2012 August 2012	Complete
	Baseball Restrooms – Grab Bars	604.5	Install all new grab bars.	3	City Staff	\$150.00	FY 2012 August 2012	Complete
Picture Above.	Baseball Restrooms – Dispenser Height	308 309.4	Install all new dispensers. None	3	City Staff	No Cost	FY 2012	Complete

			exist.				August 2012	
	Baseball Restrooms – Toilet Height	309 604.4 605	Install new toilet with height of at least 17” no bigger than 19”.	3	City Staff	\$200.00	FY 2012 August 2012	Complete
	Baseball Restrooms – Mirrors	603.3	Install new mirrors none exist.	3	City Staff	\$250.00	FY 2012 August 2012	Complete
	Baseball Restrooms – Sinks	306 606	Install 2 new sinks to meet requirements.	3	City Staff	\$600.00	FY 2012 August 2012	Complete
	Baseball Restrooms – Exposed Pipes	606	Cover exposed pipes.	3	City Staff	\$50.00	FY 2012 August 2012	Complete
No Picture Available.	Baseball Restrooms – Signage	703	Add signage, none exist.	3	City Staff	\$20.00	FY 2012 August 2012	Complete

TOTAL PROJECTED COST: \$15,904.00

Ocala Recreation & Parks ADA Transition Plan

Park/ Facility: FISHER PARK

Address: 900 SE 22ND STREET

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Accessible Parking Space/Van Accessible	208 501 502	Add 2 ADA accessible parking spaces that are also van accessible with an aisle and signage.	1	City Staff	\$600.00	FY 2016 August 2016	
	Accessible Route and Companion Seating at Picnic Table	206.2.2 402 403 305 805 902.3 903	Need 50 Ft of Sidewalk to Picnic Table by playground and a 12 x 18 concrete pad.	2	City Staff	\$689.00	FY 2016 August 2016	
	Accessible Route to Grill	206.2.2 402 403	Need 5x5 pad of concrete around grill.	2	City Staff	\$37.00	FY 2016 August 2016	
	Accessible Route to Playground	240 206.2.17 402 403 1008	Need 70 Ft of sidewalk to playground.	2	City Staff	\$518.00	FY 2016 August 2016	

	Accessible Route to Water Fountain	211	Need 10 Ft of sidewalk for accessible route.	2	City Staff	\$73.00	FY 2016 September 2016	
No Picture Available	Water Fountain – ADA Accessibility	306 602	Replace water fountain to meet front approach and parallel approach also to meet spout height requirements.	4	City Staff	\$4,560.00	FY 2016 September 2016	
	Accessible Route to Racquetball Court	206.2.12 402 403	Need 92 Ft of sidewalk for accessible route	2	City Staff	\$680.00	FY 2016 August 2016	
	Accessible Route to Basketball Court	206.2.12 402 403	Need 50 Ft of sidewalk from Picnic Area to Basketball Court	2	City Staff	\$370.00	FY 2016 August 2016	
	Accessible Route to Picnic Area	206.2.2 402 403	Need 10 Ft of sidewalk to picnic area from racquetball courts.	2	City Staff	\$73.00	FY 2016 August 2016	
Pictured Above	Companion Seating Available at Picnic Table	305 805 902.3 903	Pour a 12 x 18 pad of concrete around picnic table by racquetball courts.	4	City Staff	\$319.00	FY 2016 August 2016	

TOTAL PROJECTED COST: \$7,919.00

Ocala Recreation & Parks
ADA Transition Plan

Park/ Facility: FORT KING MEMORIAL

Address: 3925 SE FT KING STREET

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
No Picture Available.	ADA Accessible Parking Space	208 501 502	Need to make one ADA accessible parking space with signage and pad.	1	City Staff	\$1,800.00	FY 2017 December 2016	
	Accessible Route to Monument	206 402 403	Pour 70 Ft on concrete sidewalk to monument from circle drive.	2	City Staff	\$815.00	FY 2017 December 2016	

TOTAL PROJECTED COST: \$2,615.00

The Fort King Site is ADA compliant.

Ocala Recreation & Parks
ADA Transition Plan

Park/ Facility: HERITAGE NATURE CONSERVANCY

Address: 2005 NE 3RD STREET

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	ADA Accessible Parking Space	208 501 502	Add an ADA accessible parking space by paving the parking lot.	1	Contractor	\$31,350.00	FY 2016 April 2016	
	Accessible Routes to Amenities/Park	206 402 403	Walking Trail inside park needs to be paved to meet accessible routes to amenities.	2	Contractor	\$23,100.00	FY 2016 April 2016	
	Accessible Route to Water Feature	206 402 403	Add handrails to the 2 existing wooden foot bridges that cross over the river bed.	2	City Staff	\$575.00	FY 2016 April 2016	
	Accessible Route to Picnic Table	206.2.2 402 403	Pour 10 Ft of sidewalk for trail to picnic table.	2	City Staff	\$44.00	FY 2016 April 2016	

	Accessible Route to Picnic Table	206.2.2 402 403	Pour 10 Ft of sidewalk for trail to picnic table.	4	City Staff	\$44.00	FY 2016 April 2016	
Picture Above.	Companion Seating at Picnic Tables	305 805 902.3 903	Need 4 Picnic Table concrete pads 12x16	4	City Staff	\$920.00	FY 2016 April 2016	
	Companion Seating at Benches	305 805 902.3 903	Need 3 Benches pads 5x9 off of trail.	4	City Staff	\$152.00	FY 2016 April 2016	
	Accessible Route to Front Pavilion	206 402 403	10 Ft of sidewalk from trail.	2	City Staff	\$44.00	FY 2016 April 2016	
	Accessible Route to East Pavilion	206 402 403	10 Ft of sidewalk from trail	2	City Staff	\$44.00	FY 2016 April 2016	
	Accessible Route to Playground equipment	240 206.2.17 402 403 1008	5 Ft of sidewalk to Spider Climber. All other equipment will be accessible when trail completed.	2	City Staff	\$35.00	FY 2016 April 2016	

	Restrooms – Door Clearance Requirements	404 603.2	Add addition 7Ft of concrete to existing slab.	3	City Staff	\$159.00	FY 2016 January 2016	
	Restrooms – Grab Bars	604.5	Move to correct height. 12” from back of the wall.	3	City Staff	No Cost	FY 2016 January 2016	
Picture Above.	Restrooms – Dispenser Height	308 309.4	Lower paper towels to 48” high	3	City Staff	No Cost	FY 2016 January 2016	
Picture Above.	Restrooms – Pipe Shielding	606	Cover exposed pipes	3	City Staff	\$50.00	January 2016	

TOTAL PROJECTED COST: \$56,517.00

NOTE: ADA Transition Plan for this location will solely depend on paving of the trail. All park amenities including restrooms, playground equipment, benches, etc. are not accessible without this enhancement.

Ocala Recreation & Parks
ADA Transition Plan

Park/ Facility: Highlands East
Address: 3160 SE 13th Street

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Access Route to Picnic Area	206.2.2 402 403	Pour 100 Ft concrete sidewalk to picnic area to make accessible.	2	City Staff	\$710.00	FY 2019 May 2019	
	Accessibility to Picnic Tables	305 805 902.3 903	Add 2 - 12 x 18 concrete pads under existing picnic tables.	4	City Staff	\$612.00	FY 2019 May 2019	
	Accessibility to Grill	206.2.2 402 403	Pour a 5 x 5 concrete pad around existing grill	4	City Staff	\$36.00	FY 2019 May 2019	
No Picture Available.	Wheel Chair Seating accommodations	305	Replace one existing Picnic table with an ADA table	4	City Staff	\$307.00	FY 2019 May 2019	
No Picture Available	Accessible Route to Play Equipment	206.2.2 402 403	Pour concrete sidewalks to equipment	2	City Staff	\$1,000	FY 2019 May 2019	

TOTAL PROJECTED COST: \$2,665.00

Ocala Recreation & Parks
ADA Transition Plan

Park/ Facility: Highlands West
Address: 2840 SE 13th Street

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Access Route to Picnic Area	206.2.2 402 403	Pour 75 Ft concrete sidewalk to picnic area to make accessible.	2	City Staff	\$532.00	FY 2019 March 2019	
	Accessibility to Picnic Tables	305 805 902.3 903	Add 2 12 x 18 concrete pads under existing picnic tables.	4	City Staff	\$613.00	FY 2019 March 2019	
	Accessibility to Grill	206.2.2 402 403	Pour a 5 x 5 concrete pad around existing grill	4	City Staff	\$36.00	FY 2019 March 2019	
No Picture Available	Wheel Chair Seating accommodations	305	Replace one existing Picnic table with an ADA table	4	City Staff	\$306.00	FY 2019 March 2019	
No Picture Available	Accessibility to Play Equipment	206.2.2 402 403	Concrete sidewalk connecting equipment.	2	City Staff	\$1,000.00	FY 2019 March 2019	

TOTAL PROJECT COST: \$2,487.00

Ocala Recreation & Parks
ADA Transition Plan

Park/ Facility: HILLDALE

Address: NE 8TH STREET

Photo	Barrier	ADA Reg.	Solution	Priority	By Whom	Projected Cost	Projected Date	Action Taken
No Amenities currently at this park. No Transition Plan needed.								

Ocala Recreation & Parks
ADA Transition Plan

Park/ Facility: IDYLWEIR
Address: SE 10TH & SE 11TH STREET

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Accessible Route to Park	206 402 403	Cut curb to gain access to park.	1	City Staff	\$150.00	FY 2013 Dec 2012	Complete
	Accessible Route to Picnic Area	206.2.2 402 403	Need 50 Ft of concrete to Picnic Area.	2	City Staff	\$308.00	FY 2013 April 2013	Complete
	Companion Seating at Picnic Table	305 805 902.3 903	Pour a 12x18 concrete pad for picnic table.	4	City Staff	\$266.00	FY 2013 April 2013	Complete
No Picture Available	Accessible Route to Grill	206.2.2 402 403	Install grill with a 5x5 concrete pad for grill	4	City Staff	\$61.00	FY 2013 April 2013	Complete

	Accessible Route to Playground	240 206.2.17 402 403 1008	Pour 30 Ft of concrete sidewalk to playground area.	2	City Staff	\$185.00	FY 2013 April 2013	Complete
	Accessible Route to Water Fountain	211	Pour 40 Ft of sidewalk to water fountain	4	City Staff	\$283.00	FY 2018 April 2018	
No Picture Available	Water Fountain – ADA Accessibility	306 602	Replace water fountain to meet front approach and parallel approach also to meet spout height requirements.	4	City Staff	\$4,370.00	FY 2018 April 2018	
	Accessible Route to Tennis Court	206.2.12 402 403	Pour 80 Ft concrete sidewalk from picnic area to tennis courts.	2	City Staff	\$493.00	FY 2013 April 2013	Complete

TOTAL PROJECTED COST: \$6,116.00

Ocala Recreation & Parks ADA Transition Plan

Park/ Facility: JERVEY GANTT – EAST

Address: 2200 BLOCK SE 36TH AVENUE

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	ADA Accessible Parking – Pavilion Lot	208 501 502	Add 3 ADA accessible spaces making one van accessible, including signage.	1	City Staff	\$1,000.00	FY 2013 January 2013	Complete
	ADA Accessible Parking – T-Ball Lot	208 501 502	Need to add 2 parking spaces, making one van accessible including signage.	1	City Staff	\$750.00	FY 2013 January 2013	Complete
	Accessible Route/Entrances – T-Ball Lot	206 402 403	Need 75 ft of sidewalk from parking lot to fields.	1	City Staff	\$506.00	FY 2019 June 2019	
	Accessible Route/Entrances – Pool Lot	206 402 403	Rework sidewalk entrance to pool grade too steep.	1	City Staff	\$330.00	FY 2015 June 2015	Complete

	ADA Accessible Parking – 24 th Street Lot	208 501 502	Add 4 ADA accessible spaces making on van accessible including signage.	1	City Staff	\$1,200.00	FY 2013 January 2013	Complete
	ADA Accessible Parking - MCYFL Lot	208 501 502	Add 4 parking pad, making one van accessible with correct signage.	1	City Staff	\$1,320.00	FY 2019 June 2019	
	Accessible Route/Entrances – MCYFL	206 402 403	Pour 100 Ft of sidewalk to get from parking lot to entrance.	1	City Staff	\$679.00	FY 2019 June 2019	
	Accessible Route to Large Pavilion	206 402 403	Regrade sidewalk to large pavilion to meet requirements.	2	City Staff	\$1,100.00	FY 2019 June 2019	
	ADA Accessible Drinking Fountain	211 306 602	Replace current fountain by softball field.	4	City Staff	\$4,560.00	FY 2019 October 2018	

	ADA Accessible Drinking Fountain	211 306 602	Replace current fountain by racquetball courts.	4	City Staff	\$3,800.00	FY 2015 April 2015	Complete
	Accessible Route to Tennis Courts	206.2.12 402 403	Need 140 Ft of sidewalk from Pool parking lot to courts.	2	City Staff	\$950.00	FY 2019 June 2019	Complete
	Accessible Route to Racquetball Court	206.2.12 402 403	Need 110 Ft alongside the courts for access.	2	City Staff	\$747.00	FY 2019 June 2019	Complete
	Accessible Route to Restrooms	206 402 403	Need 75 Ft from racquetball court to restrooms.	2	City Staff	\$508.00	FY 2019 June 2019	Complete
	Accessible Route to Softball Field	221.5	Need 25 ft from sidewalk to backstop.	2	City Staff	\$185.00	FY 2019 October 2018	CIP
	Accessible Route to Restrooms	206 402 403	Need 200 Ft of sidewalk from T-Ball.	2	City Staff	\$1,357.00	FY 2019 June 2019	CIP

	Accessible Route for Spectator Seating	206 402 403	Create concrete plaza between fields/behind backstops.	4	Contractor	\$8,500.00	FY 2019 June 2019	CIP
	ADA Accessible Dugouts	402 403	Replace existing dugout structures.	2	Contractor	\$28,800.00	FY 2018 July 2018	CIP
	Accessible Walking Trail	206 402 403	Pave existing walking trail.	2	Contractor	\$40,315.00	FY 2014 April 2014	Complete

TOTAL PROJECTED COST: \$79,103.00

Ocala Recreation & Parks ADA Transition Plan

Park/ Facility: JERVEY GANTT – WEST

Address: 2100 BLOCK SE 32ND AVENUE

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	ADA Van Accessible Parking Space – Recycle Park	208	One existing spot needs to be converted to van accessible.	1	City Staff	\$200.00	FY 2012 September 2012	Complete
	ADA Van Accessible Parking Space – Coleman Center	208	One existing spot needs to be converted to van accessible.	1	City Staff	\$240.00	FY 2017 September 2017	
	Accessible Route to Walking Trail – Gravel Lot	206 402 403	From parking lot to trail need 50 Ft of sidewalk.	1	City Staff	\$354.00	FY 2015 May 2015	Complete
	Accessible Route to Benches – Basketball Courts	206 402 403	Need (2) 9x6 bench pad.	2	City Staff	\$146.00	FY 2017 September 2017	

	Accessible Route to Benches – Walking Trail	206 402 403	Need (2) 9x6 bench pad.	4	City Staff	\$146.00	FY 2017 September 2017	
	Accessible Route to Benches – Playground	206 402 403	Need (3) 9x6 bench pad and 5 Ft of concrete to each for a total of 15 Ft.	4	City Staff	\$326.00	FY 2014 June 2014	Complete
	Accessible Route to Shelter	206 402 403	Need 125 Ft of sidewalk to pavilion.	2	City Staff	\$887.00	FY 2015 May 2015	Complete
	Accessible Route to Small Pavilion	206 402 403	From trail to small pavilion need 40 Ft of sidewalk.	2	City Staff	\$283.00	FY 2015 May 2015	Complete
	Accessible Route to Small Pavilion	206 402 403	From trail to small pavilion need 75 Ft of sidewalk.	2	City Staff	\$531.00	FY 2015 May 2015	Complete
	ADA Accessible Water Fountain	211 306 602	Need to install an accessible water fountain to replace existing at the playground.	4	City Staff	\$3,800.00	FY 2013 June 2013	Complete

	ADA Accessible Water Fountain	211 306 602	Need to install an accessible water fountain to replace existing at the Volleyball.	4	City Staff	\$4,370.00	FY 2015 May 2015	Complete
	Accessible Route to Bleachers – Basketball & Volleyball Court	206.2.2 402 403	Need 2 bleacher pads (5x24).	4	City Staff	\$340.00	FY 2015 May 2015	Complete
	Restrooms – Grab Bars	604.5	Move to proper height between 33” – 36”	3	City Staff	No Cost	FY 2013 October 2012	Complete
Picture Above.	Restrooms – Toilet Controls	309.2 604.6	Install 2 new toilets.	3	City Staff	\$800.00	FY 2013 October 2012	Complete
Picture Above.	Restrooms – Dispensers	308 309.4	Move all dispensers to 41” to 48”	3	City Staff	No Cost	FY 2013 October 2012	Complete
Picture Above.	Restrooms -Toilet Height	309 604.4 605	Replace one toilet to meet height of 18”.	3	City Staff	\$200.00	FY 2013 October 2012	Complete
Picture Above.	Restrooms – Pipe Shielding	606	Cover Exposed pipes.	3	City Staff	\$50.00	FY 2013 October 2012	Complete
No Picture Available.	Restroom Signage	703	Add signage to doors.	3	City Staff	\$10.00	FY 2013 October 2012	Complete

	<p>Accessible Route to Restrooms</p>	<p>206 402 403</p>	<p>Rework slop and grade, to steep to restroom.</p>	<p>2</p>	<p>City Staff</p>	<p>\$300.00</p>	<p>FY 2013 October 2012</p>	<p>Complete</p>
--	--------------------------------------	----------------------------	---	----------	-------------------	-----------------	---------------------------------	-----------------

TOTAL PROJECTED COST: \$14,127.00

Ocala Recreation & Parks
ADA Transition Plan

Park/ Facility: Lamb Park

Address: NW 13th and 9th Avenue

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Accessible Route from basketball court to picnic table.	206.2.2 402 403	Pour a 28 Ft sidewalk to make a accessible route.	4	City Staff	\$218.00	FY 2019 March 2019	
	Companion seating available at bench.	305 805 902.3 903	Add additional concrete to existing pad.	4	City Staff	\$69.00	FY 2019 March 2019	
	Wheel Chair seating available at Picnic Table	305 805 902.3 903	Pour a 12 x 18 concrete pad for existing picnic table.	4	City Staff	\$337.00	FY 2019 March 2019	

	<p>Accessibility to Grill</p>	<p>206.2.2 402 403</p>	<p>Pour a 5 x 5 pad around the grill to allow access to the grill.</p>	<p>4</p>	<p>City Staff</p>	<p>\$40.00</p>	<p>FY 2019 March 2019</p>	
<p>Pictured Below.</p>	<p>Accessible Route to Park</p>	<p>206 402 403</p>	<p>Need 100 FT of sidewalk to gain access to park.</p>	<p>1</p>	<p>City Staff</p>	<p>\$781.00</p>	<p>FY 2019 March 2019</p>	
	<p>Accessible Route to Basketball Courts</p>	<p>240 206.2.17 402 403 1008</p>	<p>12 Ft Sidewalk from eastside of park to basketball court.</p>	<p>2</p>	<p>City Staff</p>	<p>\$94.00</p>	<p>FY 2019 March 2019</p>	
	<p>Accessible Route to Play Equipment – Whirl</p>	<p>240 206.2.17 402 403 1008</p>	<p>10 Ft Sidewalk to Whirl.</p>	<p>2</p>	<p>City Staff</p>	<p>\$77.00</p>	<p>FY 2019 March 2019</p>	

	<p>Accessible Route to Play Equipment - Climber</p>	<p>240 206.2.17 402 403 1008</p>	<p>36 Ft sidewalk from Whirl to Climber</p>	<p>2</p>	<p>City Staff</p>	<p>\$281.00</p>	<p>FY 2019 March 2019</p>	
	<p>Companion Seating Available at Benches</p>	<p>305 805 902.3 903</p>	<p>9 x 5 pad for Bench (Between Whirl and Climber)</p>	<p>4</p>	<p>City Staff</p>	<p>\$69.00</p>	<p>FY 2019 March 2019</p>	
	<p>Accessible Route to Play Equipment – See Saw</p>	<p>240 206.2.17 402 403 1008</p>	<p>16 Ft Sidewalk from Climber to See Saw</p>	<p>2</p>	<p>City Staff</p>	<p>\$124.00</p>	<p>FY 2019 March 2019</p>	
	<p>Accessible Route to Play Equipment - Swing</p>	<p>240 206.2.17 402 403 1008</p>	<p>23 Ft sidewalk from Picnic Area to Swings</p>	<p>2</p>	<p>City Staff</p>	<p>\$178.00</p>	<p>FY 2019 March 2019</p>	

	<p>Accessible Route to Play Equipment – Swing to Sidewalk</p>	<p>240 206.2.17 402 403 1008</p>	<p>34 Ft Sidewalk from Swings to Sidewalk</p>	<p>2</p>	<p>City Staff</p>	<p>\$264.00</p>	<p>FY 2019 March 2019</p>	
	<p>Accessible Routes to drinking fountains</p>	<p>211</p>	<p>8 Ft sidewalk need to Fountain with 5 x 5 pad.</p>	<p>4</p>	<p>City Staff</p>	<p>\$101.00</p>	<p>FY 2019 March 2019</p>	
<p>No Picture Available</p>	<p>Water Fountain is not ADA complaint.</p>	<p>306 602</p>	<p>Replace Water Fountain that meets all requirements</p>	<p>4</p>	<p>City Staff</p>	<p>\$4,180.00</p>	<p>FY 2019 March 2019</p>	
	<p>Accessible Route to Volleyball Court</p>	<p>206.2.12 402 403</p>	<p>58 Ft Sidewalk from north side of park</p>	<p>2</p>	<p>City Staff</p>	<p>\$453.00</p>	<p>FY 2019 March 2019</p>	

	Companion Seating Available at Benches	305 805 902.3 903	9 x 5 pad for Bench (Volleyball Court)	4	City Staff	\$69.00	FY 2019 March 2019	
--	---	----------------------------	---	---	------------	---------	------------------------------	--

TOTAL PROJECTED COST: \$7,335.00

Ocala Recreation & Parks
ADA Transition Plan

Park/ Facility: LILLIAN BRYANT

Address: 2200 NW 17TH PLACE

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Handicap Parking Signage Height is currently at 51 ½ "high.	501 502	Raise Sign to Proper Height so the bottom of the signs measures at 60" high.	1	City Staff	\$150.00	FY 2012 September 2012	Complete
	Accessible Route to Walking Trail	206 402 403	Need 150 Ft of Sidewalk to connect to walking trail	2	City Staff	\$925.00	FY 2012 July 2012	Complete
	Walking Trail Requirements	206 402 403	Meet slope, surfacing and width requirements the trail must be paved.	2	City Staff	\$30,575.00	FY 2012 April 2012	Complete

	Accessible Route to North Picnic Area	206.2.2 402 403	Need 15 Ft of sidewalk from walking trail and 24x36 pad for 2 picnic tables.	1	City Staff	\$1,400.00	FY 2016 May 2016	Complete
Pictured Above	Accessible Route to North Picnic Area Grill	206.2.2 402 403	Need a 7 Ft sidewalk to grill with a 5x5 pad.	1	City Staff	\$88.00	FY 2016 May 2016	Complete
	Accessible Route to South Picnic Area	206.2.2 402 403	Need 25 Ft of Sidewalk from parking/trail and 24x36 pad for 2 picnic tables.	2	City Staff	\$1,342.00	FY 2014 January 2014	Complete
Pictured Above.	Accessible Route to South Picnic Area Grill	206.2.2 402 403	Need a 7 Ft sidewalk to grill with a 5x5 pad.	2	City Staff	\$80.00	FY 2014 January 2014	Complete
	Accessible Route to Bench on Walking Trail with Companion Seating – North Quadrant	206.2.2 402 403 305 805 902.3 903	Pour a 9x6 concrete pad around existing bench.	4	City Staff	\$73.00	FY 2014 May 2014	Complete
No Picture Available	Accessible Route to Bench on Walking Trail with Companion Seating –East Quadrant	206.2.2 402 403 305 805 902.3 903	Pour a 9x6 concrete pad and install a new bench.	4	City Staff	\$73.00	FY 2014 May 2014	Complete

No Picture Available	Accessible Route to Bench on Walking Trail with Companion Seating – South Quadrant	206.2.2 402 403 305 805 902.3 903	Pour a 9x6 concrete pad and install a new bench.	4	City Staff	\$73.00	FY 2014 May 2014	Complete
	Accessible Route to Bench on Walking Trail with Companion Seating – West Quadrant	206.2.2 402 403 305 805 902.3 903	Pour a 9x6 concrete pad around existing bench.	4	City Staff	\$73.00	FY 2014 May 2014	Complete
	Accessible Route to Bench at Playground with Companion Seating	206.2.2 402 403 305 805 902.3 903	Pour a 9x6 concrete pad around existing bench and 21 Ft of sidewalk to bench.	4	City Staff	\$195.00	FY 2013 May 2013	Complete
	Pavilion – Wheel Chair seating available at structure.	305 802 903	Add 2 ADA accessible Picnic Tables to pavilion.	2	City Staff	\$534.00	FY 2013 October 2012	Complete
	ADA Accessible Water Fountains	211 306 602	Install new fountain at Softball field next to sidewalk.	4	City Staff	\$4,560.00	FY 2016 May 2016	

No Picture Available.	ADA Accessible Water Fountains	211 306 602	Install new fountain at playground.	4	City Staff	\$4,180.00	FY 2014 December 2013	Complete
	Accessible Route to Volleyball Court	206.2.1 2 402 403	Need 65 Ft of sidewalk to court with a 5x5 pad for bench.	2	City Staff	\$431.00	FY 2013 May 2013	Complete
	Accessible Route to Tennis Court	206.2.1 2 402 403	Need 100 Ft of sidewalk from playground to courts. Move existing walk thru back 5 ft.	2	City Staff	\$693.00	FY 2014 May 2014	CANCELLED TENNIS COURTS BEING REMOVED DUE TO SINK HOLE
	Accessible Route to Restrooms from Trail	206 402 403	Need 200 Ft of sidewalk from restrooms to trail.	2	City Staff	\$1,234.00	FY 2013 May 2013	Complete
	Accessible Route to Restrooms from Pavilion	206 402 403	Need 100 Ft of sidewalk from restrooms to pavilion.	2	City Staff	\$617.00	FY 2013 May 2013	Complete
No Picture Available.	Restrooms Signage	703	Replace missing for men and women restroom. Add new signs.	3	City Staff	\$20.00	FY 2013 May 2013	Complete

	Grab Bars (Restrooms)	604.5	Lower the bars to proper height 36".	3	City Staff	No Cost	FY 2013 May 2013	Complete
Pictured Above	Toilet (Restrooms) Current Seat Height is 15".	604.4	Replace Toilet with regulation height between 17" and 19" in womens and mens. Total of 3.	3	City Staff	\$150.00	FY 2013 May 2013	Complete
	Dispensers Heights	308 309.4	Move all dispensers to required height of 41" to 48"	3	City Staff	No Cost	FY 2013 May 2013	Complete
Pictured Above	Sink Piping (Restrooms) Piping exposed.	606.5	Cover exposed pipes.	3	City Staff	\$50.00	FY 2013 May 2013	Complete

TOTAL PROJECTED COST: \$52,503.00

Ocala Recreation & Parks
ADA Transition Plan

Park/ Facility: MLK Memorial

Address: 500 Block SW MLK Avenue

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Handicap Parking Signage at incorrect height	501 502	Raise sign to correct height.	1	City Staff	\$25.00	FY 2012 April 2012	Complete
No Picture Available	Van Accessible signage needed.	501 502	Add "Van Accessible" Signs to parking space	1	City Staff	\$25.00	FY 2012 April 2012	Complete

TOTAL PROJECT COST: \$50.00

Ocala Recreation & Parks ADA Transition Plan

Park/ Facility: MLK RECREATION COMPLEX

Address: 1510 NW 4TH STREET

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Required Number of ADA Accessible Spaces.	208 501 502	Add another space to the Recycle Park parking lot with correct signage.	1	City Staff	\$715.00	FY 2014 October 2013	Complete
Pictured Above.	Required Number of ADA Van Accessible Spaces	208 501 502	Make one space van accessible at Recycle Park parking lot with correct signage.	1	City Staff	\$220.00	FY 2014 October 2013	Complete
	Companion Seating & Accessible Route to Benches.	206.2.2 402 403 305 805 902.3 903	Need 9x6 bench pads at playground for companion seating and accessible route.	4	City Staff	\$79.00	FY 2017 April 2017	
	Accessible Route to Large Pavilion	206 402 403	Need 50 Ft of sidewalk for access to large pavilion from parking lot.	2	City Staff	\$370.00	FY 2017 April 2017	

	Accessible Route to Shelter by Football Field.	206 402 403	Need 20 Ft of sidewalk for access to pavilion by football field (east side).	2	City Staff	\$148.00	FY 2017 April 2017	
	Accessible Route to Shelter by Football Field Concession Stand	206 402 403	Need 5 Ft of sidewalk for access to pavilion.	2	City Staff	\$36.00	FY 2017 April 2017	
	Maneuvering Space under Large Pavilion	802	Remove some picnic tables to allow more spaces.	4	City Staff	No Cost	FY 2012 April 2012	COMPLETE
	Accessible Route to Playground.	240 206.2.17 402 403 1008	Need 20 Ft of sidewalk to Playground from trail .	2	City Staff	\$148.00	FY 2017 April 2017	
	ADA Accessible Water Fountain – Large Pavilion, Playground and Courts	211 306 602	Replace existing water fountain with ADA accessible fountain.	4	City Staff	\$4,180.00	FY 2016 December 2015	
	ADA Accessible Water Fountain – Football Field, Trail, Small Shelter	211 306 602	Replace existing water fountain with ADA accessible fountain.	4	City Staff	\$4,560.00	FY 2017 April 2017	

	ADA Accessible Water Fountain –Baseball Fields and Trail	211 306 602	Replace existing water fountain with ADA accessible fountain.	4	City Staff	\$4,370.00	FY 2016 December 2015	CANCELLED
	Accessible Route to Basketball Courts	206.2.12 402 403	Need 20 Ft of sidewalk	2	City Staff	\$148.00	FY 2017 April 2017	
	Accessible Route to Spectator Seating – Football Field	221 802	Need two (2) concrete bleacher pads 25 x 25. One on each side of the field	4	City Staff	\$1,542.00	FY 2016 May 2016	Complete
	Accessible Route to Southside Bleachers – Football Field	221.5	Need 100 Ft of concrete from parking lot to bleachers.	4	City Staff	\$1,481.00	FY 2017 April 2017	
Pictured Above.	Accessible Route to Northside Bleachers – Football Field.	221.5	Need 60 Ft of sidewalk to connect trail to bleachers pads.	4	City Staff	\$444.00	FY 2017 April 2017	
	Baseball Field Restrooms – Dispenser Height	308 309.4	Raise dispensers to required height of 41” to 48”.	3	City Staff	No Cost	FY 2013 March 2013	Complete

Pictured Above.	Baseball Field Restrooms – Pipe Shielding	606	Cover exposed pipes.	3	City Staff	\$200.00	FY 2013 March 2013	Complete
Pictured Above.	Baseball Field Restrooms – Signage	703	Add proper signage that is missing.	3	City Staff	\$10.00	FY 2013 March 2013	Complete
	Football Field Restrooms – Pipe Shielding	606	Cover exposed pipes.	3	City Staff	\$200.00	FY 2013 March 2013	Complete

TOTAL PROJECTED COST: \$19,176.00

Ocala Recreation & Parks
ADA Transition Plan

Park/ Facility: Nature Park

Address: 1600 SE 30th Avenue

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Handicap Parking Signage	501 502	Needs correct height and Van accessible sign.	1	City Staff	\$150.00	FY 2013 March 2013	Complete
	Handicap Parking Space Width	501 502	Remove regular space and increase handicap space to correct width.	1	City Staff	\$500.00	FY 2013 March 2013	Complete
Pictured Above	Handicap Parking Space Access Aisle Width	501 502	Remove Regular space and add an access aisle to space.	1	City Staff	\$400.00	FY 2013 March 2013	Complete
	Accessible Routes to All Water Features	402 403 505 1005	Sidewalk to fishing dock does not meet slope requirements. Rework slope to meet requirements or add handrails.	2	City Staff	\$1,725.00	FY 2019 May 2019	

No Picture Available	Wheel Chair Seating available at Picnic tables	305 805 902.3 903	Replace 3 picnic tables with ADA compliance tables.	4	City Staff	\$920.00	FY 2019 May 2019	
	Accessible Route to Pavilion	206 402 403	Grade to pavilion to steep. Rework sidewalk.	2	City Staff	\$345.00	FY 2019 May 2019	
	Maneuvering Space under Pavilion for a Wheel Chair	802	Install smaller 6 Ft Picnic Table to allow maneuvering space for wheel chair accessibility.	4	City Staff	\$307.00	FY 2019 May 2019	
	Accessible Routes to Play Equipment	240 206.2.17 402 403 1008	200 Ft of Sidewalk to gain accessibility to play equipment.	2	City Staff	\$1,419.00	FY 2019 May 2019	
No Picture Available	Drinking Fountains not ADA Accessible	306 602	Replace with ADA accessible drinking fountain	4	City Staff	\$4,370.00	FY 2019 May 2019	

	<p>Accessible Route to Drinking Fountain</p>	<p>211</p>	<p>Grade to Steep Rework grade to meet requirements</p>	<p>4</p>	<p>City Staff</p>	<p>\$288.00</p>	<p>FY 2019 May 2019</p>	
	<p>Accessible routes to all Restrooms</p>	<p>206 402 403</p>	<p>Grade to Steep – rework grade to meet requirements</p>	<p>1</p>	<p>City Staff</p>	<p>\$575.00</p>	<p>FY 2019 May 2019</p>	
	<p>Grab Bars (Height, Distance, Length)</p>	<p>604.5</p>	<p>Install a rear bar 36” and side bar 42”</p>	<p>3</p>	<p>City Staff</p>	<p>\$460.00</p>	<p>FY 2019 May 2019</p>	
<p>Pictured Above.</p>	<p>Control Locations</p>	<p>309.2 604.6</p>	<p>Install new toilet to meet standards.</p>	<p>3</p>	<p>City Staff</p>	<p>\$173.00</p>	<p>FY 2019 May 2019</p>	

	<p>Required Height of Dispensers</p>	<p>308 309.4</p>	<p>Move dispensers to at least 48"</p>	<p>3</p>	<p>City Staff</p>	<p>\$8.00</p>	<p>FY 2019 May 2019</p>	
<p>Pictured Above.</p>	<p>Pipe shielding exposed</p>	<p>606</p>	<p>Cover exposed pipes and sharp surfaces.</p>	<p>3</p>	<p>City Staff</p>	<p>\$29.00</p>	<p>FY 2019 May 2019</p>	

TOTAL PROJECTED COST: \$ 11,669.00

Ocala Recreation & Parks
ADA Transition Plan

Park/ Facility: NORTHSIDE

Address: 2000 NE 12TH AVENUE

Photo	Barrier	ADA Reg.	Solution	Priority	By Whom	Projected Cost	Projected Date	Action Taken
<p>No Amenities currently at this park. No Transition Plan needed.</p>								

Ocala Recreation & Parks
ADA Transition Plan

Park/ Facility: OCALA REGIONAL SPORTSPLEX

Address: 3500 SW 67TH AVENUE

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	ADA Parking Space Signage	501 502	Add Van accessible signs and raise to required height on 60".	1	City Staff	\$650.00	FY 2013 October 2012	Complete
No Picture Available	Passenger Loading Zone - Signage	503	Add correct signage.	1	City Staff	\$150.00	FY 2013 March 2013	Complete
	Passenger Loading Zone – Access Aisle	503	Cut curb for access to existing pad.	1	City Staff	\$200.00	FY 2013 March 2013	Complete
	Accessible Route to Benches	206.2.2 402 403	Need 20 ft of sidewalk to get to benches by playground and (2) 5x5 pads.	4	City Staff	\$110.00	FY 2014 May 2014	Complete
No Picture Available.	Accessible Route to Bleachers – Football/Soccer Field	206.2.2 402 403	Need (2) 27 x 10 concrete pads for bleachers.	4	City Staff	\$382.00	FY 2018 October 2018	

	Accessible Route to Grill	206 402 403	Need 15 Ft of sidewalk to grill with 5x5 pad.	4	City Staff	\$134.00	FY 2018 May 2018	
See Picture Below.	Accessible Route to Playground Equipment	240 206.2.17 402 403 1008	Need 25 Ft of sidewalk to playground.	2	City Staff	\$169.00	FY 2014 May 2014	Complete
	ADA Accessible Structure	240.2	Replace playground Equipment and surfacing with ADA accessible structure.	2	City Staff	\$20,000.00	FY 2013 May 2013	Complete
	ADA Accessible Water Fountain	306 602	Replace water fountain by softball field with ADA accessible fountain.	4	City Staff	\$4,370.00	FY 2018 November 2017	
	ADA Accessible Water Fountain	306 602	Replace water fountain by football/soccer field with ADA accessible fountain.	4	City Staff	\$4,370.00	FY 2018 October 2017	
	Spectator Seating at Basketball Court	221 802	Need a 5x24 concrete pad for bench.	4	City Staff	\$170.00	FY 2018 October 2018	

	Spectator Seating at Volleyball Court	221 802	Need a 5x10 concrete pad for bench.	4	City Staff	\$70.00	FY 2018 October 2018	
	Accessible Route to Football/Soccer	221.5	Need 96 Ft of sidewalk to gain field access.	2	City Staff	\$681.00	FY 2018 October 2018	
	Football/Soccer Field Bathroom – Pipe Shielding	606	Cover exposed pipes	3	City Staff	\$50.00	FY 2012 August 2012	Complete
	Football/Soccer Field Bathroom – Toilet Control Locations	309.2 604.6	Replace with a new toilet.	3	City Staff	\$100.00	FY 2012 August 2012	Complete
	Softball Field Bathrooms – Dispenser Height	308 309.4	Move paper towel dispenser to 41” between 48”	3	City Staff	No Cost	FY 2012 August 2012	Complete
Pictured Above.	Softball Field – Toilet Control Locations	309.2 604.6	Replace with a new toilet.	3	City Staff	\$100.00	FY 2012 August 2012	Complete

Pictured Above.	Softball Field Bathroom – Pipe Shielding	606	Cover exposed pipes	3	City Staff	\$50.00	FY 2012 August 2012	Complete
	Concession Stand Bathrooms – Dispenser Height	308 309.4	Move toilet paper and soap dispenser to 41” between 48”	3	City Staff	No Cost	FY 2012 August 2012	Complete
Pictured Above.	Concession Stand – Toilet Control Locations	309.2 604.6	Replace with a new toilet.	3	City Staff	\$100.00	FY 2012 August 2012	Complete

TOTAL PROJECTED COST: \$31,856.00

Ocala Recreation & Parks
ADA Transition Plan

Park/ Facility: Poinciana Park
Address: 1670 SW Ft. King Street

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Accessible Route to Picnic Table	402 206.2.2 403	Include an 84 foot concrete sidewalk to gain access to the picnic table	4	City Staff	\$720.00	FY 2016 November 2015	Complete
	Wheel Chair Seating Available at Picnic Table	903 305	Pour a 12 x 18 concrete pad for picnic table to allow for end wheel chair seating	4	City Staff	\$312.00	FY 2016 November 2015	Complete
	Accessible Route to Grill	402 206.2.2 403	Include a 7 foot concrete sidewalk to gain access to the grill	4	City Staff	\$60.00	FY 2016 November 2015	Complete
Same as Above	Maneuvering Availability around Grill	903 305	Pour a 5 x 5 concrete pad around the grill.	4	City Staff	\$60.00	FY 2016 November 2015	Complete

	Accessible Route to Bench	402 206.2.2 403	Include a 7.5 Ft concrete sidewalk to gain access to the bench.	4	City Staff	\$60.00	FY 2016 November 2015	Complete
	Wheel Chair Seating Available at Bench	903 305	Pour a 10 x 6 concrete pad for bench to allow for end wheel chair seating	4	City Staff	\$90.00	FY 2016 November 2015	Complete
	Accessible Route to Basketball Court	206.2.12 402 403	Pour a 7.5 Ft of sidewalk to basketball court for an accessible route.	2	City Staff	\$60.00	FY 2016 November 2015	Complete

TOTAL PROJECTED COST: \$1,422.00

Ocala Recreation & Parks ADA Transition Plan

Park/ Facility: POLLY PALMER

Address: 3700 BLOCK SW 27TH AVENUE

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Accessible Route to Benches	206.2.2 402 403	Need 15 Ft of concrete to bench.	4	City Staff	\$110.00	FY 2018 May 2018	
	Companion Seating at Bench	305 805 902.3 903	Pour a 9x5 concrete bench pad.	4	City Staff	\$66.00	FY 2018 May 2018	
	Walking Trail Slope Requirements	206 402 403	Rework parts of the trail to meet proper slope requirements.	2	City Staff	\$600.00	FY 2018 July 2018	CIP to Resurface? \$60,000
	ADA Parking Space	208 501 502	Add an ADA parking space with signage.	1	City Staff	\$210.00	FY 2018 January 2018	

TOTAL PROJECTED COST: \$986.00

Ocala Recreation & Parks
ADA Transition Plan

Park/ Facility: POWHATTAN

Address: 3800 SE 3RD STREET

Photo	Barrier	ADA Reg.	Solution	Priority	By Whom	Projected Cost	Projected Date	Action Taken
No Amenities currently at this park. No Transition Plan needed.								

Ocala Recreation & Parks
ADA Transition Plan

Park/ Facility: RITTERHOFF PARK

Address: 1400 BLOCK SE 17TH STREET

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	ADA Accessible Parking & Van Accessible Parking	208 501 502	Add an ADA accessible parking space to parking lot with signage and correct aisle width.	1	City Staff	\$550.00	FY 2014 October 2013	Complete
	Accessible Route to Bench	206.2.2 402 403	Need 32Ft of concrete to bench.	4	City Staff	\$227.00	FY 2014 October 2013	Complete
Same as Above.	Companion Seating at 2 Benches	305 805 902.3 903	Need two 9 x 6 bench pads.	4	City Staff	\$152.00	FY 2014 October 2013	Complete
	Accessible Route to Pavilion	206 402 403	Need 215Ft of concrete to pavilion.	2	City Staff	\$1,526.00	FY 2014 October 2013	Complete

	<p>Accessible Route to Grill</p>	<p>206 402 403</p>	<p>Need 10 Ft of concrete and a 5x5 pad for grill.</p>	<p>4</p>	<p>City Staff</p>	<p>\$112.00</p>	<p>FY 2014 October 2013</p>	<p>Complete</p>
	<p>Accessible Route to Water Fountain</p>	<p>211</p>	<p>Relocate water fountain next to pavilion were new sidewalk will be poured.</p>	<p>4</p>	<p>City Staff</p>	<p>No Cost</p>	<p>FY 2018 October 2017</p>	<p>Complete</p>
<p>No Picture Available</p>	<p>ADA accessible Water Fountain</p>	<p>306 602</p>	<p>Replace water with ADA accessible fountain.</p>	<p>4</p>	<p>City Staff</p>	<p>\$4,370.00</p>	<p>FY 2018 October 2017</p>	

TOTAL PROJECTED COST: \$6,937.00

Ocala Recreation & Parks
ADA Transition Plan

Park/ Facility: SCOTT SPRINGS

Address: 2300 SW 24TH AVENUE

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Parking Space Aisle Width for Front Paved Lot.	501 502	Add an aisle to handicap parking space.	1	City Staff	\$600.00	FY 2017 October 2016	Complete
	ADA Space Signage Height	501 502	All Parking lot signage-raise sign to the proper height.	1	City Staff	\$180.00	FY 2017 October 2016	Complete
	Accessible Walking Trail	206 402 403	To meet surfacing, slope and accessible requirements would need to pave the walking trail.	2	Contractor	\$68,672.00	FY 2013 August 2013	Complete
	Accessible Route to front park Bench with companion seating.	206.2.2 402 403 305 805 902.3 903	Need 45 Ft of concrete sidewalk to bench and 9x5 pad.	4	City Staff	\$398.00	FY 2017 June 2017	Complete

	Accessible Route to front park picnic table with companion seating.	206.2.2 402 403 305 805 902.3 903	Need 50 Ft of concrete to picnic area with a 12x18 pad.	4	City Staff	\$689.00	FY 2017 June 2017	Complete
	Accessible Route to Boardwalk	206.2.2 402 403	Need 30 Ft from restrooms to boardwalk.	2	City Staff	\$222.00	FY 2017 June 2017	Complete
	Accessible Route to Restrooms from Parking Lot	206 402 403	Need 45 Ft of concrete to restrooms.	2	City Staff	\$332.00	FY 2017 June 2017	Complete
	Accessible Route to Picnic Table from Restrooms	206.2.2 402 403	Need 35 Ft of concrete with a 12 x 8 pad.	4	City Staff	\$578.00	FY 2017 June 2017	Complete
	Accessible Route to Pavilion from Restroom and Parking Lot	206 402 403	Need 85Ft of concrete to tie in restrooms and parking lot to pavilion.	1	City Staff	\$629.00	FY 2017 June 2017	Complete

	Accessible Route to Grill	206 402 403	Need 10 Ft of concrete to grill with a 5x5 pad.	4	City Staff	\$110.00	FY 2017 June 2017	Complete
	ADA Accessible Water Fountain	306 602	Need to replace existing water fountain with an ADA accessible fountain.	4	City Staff	\$4,560.00	FY 2017 June 2017	Complete
	Restrooms – Dispenser height requirement.	308 309.4	Move dispensers to height of 41” to 48”	3	City Staff	No Cost	FY 2012 September 2012	Complete
	Accessible Route to Grotto	206 402 403	Install additional boardwalk and observation deck, connect to existing observation deck.	2	Contractor	\$90,000	FY 2017 December 2017	CIP in 2017

TOTAL PROJECTED COST: \$150,170.00

Ocala Recreation & Parks ADA Transition Plan

Park/ Facility: Second Chance

Address: NW 19th and 2nd Avenue

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Accessible Route to Picnic Table	206.2.2 402 403	40 Ft sidewalk with 12 x 18 pad for picnic table	4	City Staff	\$512.00	FY 2018 September 2018	
	Accessible Route to Grill	206.2.2 402 403	7 Ft sidewalk to Grill with 5 x 5 pad	4	City Staff	\$74.00	FY 2018 September 2018	
	Accessible Route to Play Equipment – Swing Set	240 206.2.17 402 403 1008	14 Ft sidewalk to swing set.	2	City Staff	\$86.00	FY 2018 September 2018	
	Accessible Route to Basketball Court	206.2.12 402 403	Pour a 75Ft sidewalk to basketball court	2	City Staff	\$462.00	FY 2018 September 2018	

TOTAL PROJECTED COST: \$1,134.00

Ocala Recreation & Parks ADA Transition Plan

Park/ Facility: TODD C. PROSSER

Address: SE 12TH STREET & 11TH AVENUE

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Accessible Route to Bench	206.2.2 402 403	Need 80 Ft of concrete sidewalk to bench	4	City Staff	\$592.00	FY 2017 November 2016	
	Accessible Route to Picnic Area	206.2.2 402 403	Pour 55 Ft of concrete from road to picnic area.	2	City Staff	\$407.00	FY 2017 November 2016	
	Accessible Route & Seating at Picnic Table	206.2.2 402 403 305 805 902.3 903	Pour a 12 x 18 concrete pad around existing picnic table at picnic area.	4	City Staff	\$320.00	FY 2017 November 2016	
	Accessible Route to Grill	206.2.2 402 403	Pour a 5 x5 concrete pad around the grill and 20 Ft of sidewalk to gain access to grill.	4	City Staff	\$221.00	FY 2017 November 2016	

	<p>Accessible Seating at Bench</p>	<p>305 805 902.3 903</p>	<p>Pour a 5 x 9 concrete bench pad.</p>	<p>4</p>	<p>City Staff</p>	<p>\$66.00</p>	<p>FY 2017 November 2016</p>	
--	------------------------------------	--------------------------------------	---	----------	-------------------	----------------	----------------------------------	--

TOTAL PROJECTED COST: \$1,606.00

Ocala Recreation & Parks ADA Transition Plan

Park/ Facility: TOMS PARK

Address: 2300 N MAGNOLIA AVENUE

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Required number of accessible and van accessible spaces with correct width.	208 501 502	Add an ADA space to West Parking Lot.	1	City Staff	\$500.00	FY 2013 June 2013	Complete
	Accessible Route to Benches	206.2.2 402 403	100 Ft Sidewalk from playground sidewalk to Bench near pond.	4	City Staff	\$617.00	FY 2013 June 2013	Complete
Pictured Above.	Accessible Seating at Benches	305 805 902.3 903	Pour a 6 x 9 concrete pad for bench overlooking the pond	4	City Staff	\$66.00	FY 2013 June 2013	Complete
	Accessible Route to Benches	206.2.2 402 403	50 Ft sidewalk to bench	4	City Staff	\$308.00	FY 2013 June 2013	Complete
Pictured Above.	Accessible Seating at Benches	305 805 902.3 903	Pour a 5 x 9 pad for bench.	4	City Staff	\$66.00	FY 2013 June 2013	Complete

	Accessible Route to Picnic Area	206.2.2 402 403	50 Ft of sidewalk from East parking lot.	2	City Staff	\$308.00	FY 2013 June 2013	Complete
Pictured Above.	Accessible Seating at Picnic Area	305 805 902.3 903	Pour a 12 x 18 pad for picnic table at picnic area.	4	City Staff	\$266.00	FY 2013 June 2013	Complete
	Accessible Routes to all Playground Equipment	240 206.2.17 402 403 1008	Pour 450 Ft of Sidewalk to playground from West Parking Lot	2	City Staff	\$2,777.00	FY 2013 June 2013	Complete
	Accessible Routes to all Playground Equipment	240 206.2.17 402 403 1008	Pour 200 Ft of sidewalk to playground from East Parking lot	2	City Staff	\$1,234.00	FY 2013 June 2013	Complete

TOTAL PROJECTED COST: \$6,142.00

Ocala Recreation & Parks ADA Transition Plan

Park/ Facility: PRESERVE AT PINE OAKS

Address: 2201 NW 21ST STREET

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Parking Space Signage	501 502	Raise signage to 60" and add van accessible verbiage.	1	City Staff	\$150.00	FY 2012 September 2012	Complete
	Accessible Route to Bench looking pond.	206 402 403 505 1005	Install a new bench and 9x6 pad and 200 Ft of sidewalk to the bench.	4	City Staff	\$1,742.00	FY 2015 January 2015	Complete
	Accessible Route to Picnic Table	206.2.2 402 403	Need 23 Ft of sidewalk with 12x18 pad for table.	2	City Staff	\$468.00	FY 2015 January 2015	Complete

	<p>Accessible Route to Grill</p>	<p>206.2.2 402 403</p>	<p>Need 9 Ft of sidewalk to grill with a 5 x5 pad.</p>	<p>4</p>	<p>City Staff</p>	<p>\$98.00</p>	<p>FY 2015 January 2015</p>	<p>Complete</p>
	<p>ADA Accessible Water Fountain.</p>	<p>211 306 602</p>	<p>Relocate and replace water fountain with an ADA accessible drinking fountain.</p>	<p>4</p>	<p>City Staff</p>	<p>\$4,180.00</p>	<p>FY 2018 February 2018</p>	
	<p>Accessible Route to Restrooms</p>	<p>221.5</p>	<p>Need 375 Ft of sidewalk to connect to restrooms.</p>	<p>2</p>	<p>City Staff</p>	<p>\$2,545.00</p>	<p>FY 2018 February 2018</p>	
<p>No Picture Available</p>	<p>Restrooms – Grab Bars</p>	<p>604.5</p>	<p>Currently no grab bars – Install new bars.</p>	<p>3</p>	<p>City Staff</p>	<p>\$300.00</p>	<p>FY 2013 September 2013</p>	<p>Complete</p>
<p>Pictured Below</p>	<p>Restrooms – Dispenser Heights.</p>	<p>308 309.4</p>	<p>Move all dispensers to correct height of 41” to 48”</p>	<p>3</p>	<p>City Staff</p>	<p>No Cost</p>	<p>FY 2013 September 2013</p>	<p>Complete</p>

	Restrooms – Toilet Height	309 604.4 605	Install new toilets to meet height requirements of 17” to 19” Replace a total of 2 toilets	3	City Staff	\$400.00	FY 2013 September 2013	Complete
No Picture Provided	Restrooms – Light Switches	309.2 604.6	Lower light switches in both to 48”	3	City Staff	\$500.00	FY 2013 September 2013	Complete
	Restrooms – Pipe Shielding	606	Cover pipes	3	City Staff	\$50.00	FY 2013 September 2013	Complete
	Restrooms – Signage	703	Purchase new signs for men’s restrooms	2	City Staff	\$50.00	FY 2013 September 2013	Complete
Pictured Above	Stall Size & Maneuvering Space	604	Convert both bathrooms into one large restroom by removing stall dividers.	1	City Staff	\$500.00	FY 2013 September 2013	Complete

TOTAL PROJECTED COST: \$11,130.00

Ocala Recreation & Parks ADA Transition Plan

Park/ Facility: THOMPSONS BOWL
Address: 900 BLOCK SW 9TH AVENUE

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Accessible Handicap Parking/Van Accessible	208 206 402 403 501 502	Add an ADA accessible Parking space pad to parking lot with aisle and signage.	1	City Staff	\$1,800.00	FY 2016 May 2016	
	Accessible Route to Walking Trail	206 402 403	Need 5 Ft of sidewalk to trail.	2	City Staff	\$37.00	FY 2016 May 2016	
	Walking Trail Slope Requirements	206 402 403	Add sidewalk to meet proper grade.	2	City Staff	\$2,400.00	FY 2016 May 2016	

	Accessible Route to Bench	206.2.2 402 403	Pour a 20 Ft sidewalk to bench in middle of the park.	4	City Staff	\$148.00	FY 2016 May 2016	Complete
	Companion Seating available at bench.	305 805 902.3 903	Need a 5x9 pad under bench for accessible seating.	4	City Staff	\$66.00	FY 2016 May 2016	Complete
	Accessible Route to Water Fountain	211	Need 10 Ft of sidewalk to water fountain.	4	City Staff	\$73.00	FY 2016 May 2016	
No Picture Available.	Water Fountain – ADA Accessibility	306 602	Replace water fountain to meet front approach and parallel approach also to meet spout height requirements.	4	City Staff	\$4,560	FY 2016 May 2016	

TOTAL PROJECTED COST: \$9,084.00

Ocala Recreation & Parks ADA Transition Plan

Park/ Facility: TURNIPSEED PARK

Address: SE 7TH STREET & 13TH AVENUE

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Accessible Route to Bench	206.2.2 402 403	Pour 40 Ft of concrete from roadway to bench.	4	City Staff	\$295.00	FY 2018 December 2017	
Same As Above	Companion Seating at Bench.	305 805 902.3 903	Pour concrete to existing bench pad.	4	City Staff	\$66.00	FY 2018 December 2017	
	Accessible Route to Picnic Area	206.2.2 402 403	Pour 50 Ft of concrete from road to picnic area.	2	City Staff	\$370.00	FY 2018 December 2017	
	Accessible Route & Seating at Picnic Table	206.2.2 402 403 305 805 902.3 903	Pour a 12 x 18 concrete pad around existing picnic table at picnic area.	2	City Staff	\$320.00	FY 2018 December 2017	

	<p>Accessible Route to Grill</p>	<p>206.2.2 402 403</p>	<p>Pour a 5 x5 concrete pad around the grill.</p>	<p>4</p>	<p>City Staff</p>	<p>\$73.00</p>	<p>FY 2018 December 2017</p>	
	<p>Accessible Route to Park</p>	<p>206 402 403</p>	<p>Cut curb for access into the park.</p>	<p>1</p>	<p>City Staff</p>	<p>\$180.00</p>	<p>FY 2018 December 2017</p>	

TOTAL PROJECTED COST: \$1,304.00

Ocala Recreation & Parks
ADA Transition Plan

Park/ Facility: TUSCAWILLA PARK

Address: 300 – 899 NE SANCHEZ AVENUE

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Accessible Route to Walking Trail	206 402 403	250 Ft from playground to walking trail.	2	City Staff	\$1,775.00	FY 2013 May 2013	Complete
	Accessible Route to Basketball Court – Watula Parking Lot	206.2.12 402 403	92 Ft of sidewalk from parking lot to Basketball court. 8 Ft from basketball to racquetball courts.	2	City Staff	\$708.00	FY 2015 November 2014	Complete
No Picture Available.	Accessible Bench for Basketball	206.2.2 402 403	Install (2) 6Ft player benches on concrete pads.	4	City Staff	\$646.00	FY 2015 November 2014	Removed for safety reasons
	Accessible Benches on Walking Trail	206.2.2 402 403	Two (2) benches on trail with 9x6 pad and 10ft of sidewalk to each.	4	City Staff	\$293.00	FY 2015 November 2014	Complete

	Accessible Route to Concession Stand – Baseball Field	402 403	Construct sidewalk for access to concession stand.	2	Contractor	\$7,000.00	FY 2012 June 2012	Complete
	ADA Accessible Parking Spaces – Sanchez	208 501 502	On Street space for Baseball (1) and Tennis (1). Paint and Sign spaces.	1	City Staff	\$500.00	FY 2012 June 2012	Complete
	Accessible Route to Baseball Field	221.5	Cut curb on street and 66 Ft of sidewalk.	1	City Staff	\$457.00	FY 2012 June 2012	Complete
	Accessible Route to Tennis Courts	206.2.12 402 403	Cut curb on street to gain access to existing sidewalk.	2	City Staff	\$50.00	FY 2012 June 2012	Complete
	Accessible Spectator Seating – Baseball Field	221 802	Install bleachers with ADA seating on concrete slab.	4	City Staff	\$7,100.00	FY 2012 June 2012	Complete

	Accessible Route to Restrooms from Sanchez Avenue	206 402 403	56 Ft of sidewalk and cut curb.	2	City Staff	\$454.00	FY 2015 November 2014	Complete
	Accessible Route to South End of Park	206 402 403	Access to Pride in Bloom Plaza from Sanchez Avenue. 91 Ft of sidewalk and cut curb.	1	City Staff	\$703.00	FY 2015 November 2014	Complete
	Water Fountain – ADA Accessibility - Playground	306 602	Replace water fountain to meet front approach and parallel approach also to meet spout height requirements.	4	City Staff	\$4,370.00	FY 2015 November 2014	Complete
	Accessible Route to Water Features	402 403 505 1005	Install ADA accessible Fishing Dock.	2	Contractor	\$45,000.00	FY 2013 March 2013	Complete

TOTAL PROJECTED COST: \$74,055.00

Ocala Recreation & Parks ADA Transition Plan

Park/ Facility: WALKER PARK

Address: SE 7TH & SE 17TH AVENUE

Photo	Barrier	ADA Reg.	Solution	Priority By FY	By Whom	Projected Cost	Projected Date	Action Taken
	Accessible Route to Picnic Area	206.2.2 402 403	Need 85 Ft of concrete to picnic area.	2	City Staff	\$629.00	FY 2017 April 2017	
No Picture Available.	Accessible Route to Grill	206.2.2 402 403	Install Grill with a 5x5 concrete pad around grill for access.	4	City Staff	\$43.00	FY 2017 April 2017	
	Companion Seating at Picnic Table	305 805 902.3 903	Pour a 12 x 18 concrete pad around picnic table.	4	City Staff	\$319.00	FY 2017 April 2017	
	Accessible Route to Bench	206.2.2 402 403	Need 25 Ft of concrete to bench	4	City Staff	\$185.00	FY 2017 April 2017	
	Accessible Route to Playground Area and Benches	240 206.2.2 206.2.17 402 403 1008	Need 80 Ft of Concrete. 50 Ft for playground. 30 Ft for benches.	2	City Staff	\$592.00	FY 2017 April 2017	

	<p>Accessible Route to Water Fountain</p>	<p>211</p>	<p>Relocate water fountain to picnic area eliminating the need to pour more concrete and put in a prime location.</p>	<p>4</p>	<p>City Staff</p>	<p>No Cost</p>	<p>FY 2017 April 2017</p>	
<p>No Picture Available.</p>	<p>ADA Accessible Water Fountain</p>	<p>306 602</p>	<p>Replace fountain to meet all ADA standards.</p>	<p>4</p>	<p>City Staff</p>	<p>\$4,560.00</p>	<p>FY 2017 April 2017</p>	

TOTAL PROJECTED COST: \$6,328.00

Ocala Recreation & Parks
ADA Transition Plan

Park/ Facility: WYOMINA PARK

Address: NE 10TH STREET & 11TH AVENUE

Photo	Barrier	ADA Reg.	Solution	Priority by FY	By Whom	Projected Cost	Projected Date	Action Taken
	Handicap Parking Signage Height.	501 502	Raise sign to correct height of 60"	1	City Staff	\$30.00	FY 2012 August 2012	Complete
	Accessible Route to Picnic Area	206.2.2 402 403	Need 125 Ft f concrete to picnic area.	2	City Staff	\$848.00	FY 2016 February 2016	Complete
	Companion Seating at Picnic Tables (2)	305 805 902.3 903	Need two (2) 12 x 18 concrete pads for picnic tables.	4	City Staff	\$585.00	FY 2016 February 2016	Complete
	Accessible Route to Grill	206.2.2 402 403	Need a 5x5 grill pad	4	City Staff	\$40.00	FY 2016 February 2016	Complete

	Accessible Route to Play Equipment	240 206.2.17 402 403 1008	Need 225 Ft to get to all playground equipment.	2	City Staff	\$1,527.00	FY 2016 February 2016	Complete
	Accessible Route to Water Fountain	211	Need 60 Ft of concrete to get to water fountain	4	City Staff	\$407.00	FY 2016 February 2016	
No Picture Available.	ADA Accessible Water Fountain	306 602	Need to replace water fountain with an ADA accessible fountain.	4	City Staff	\$4,180.00	FY 2016 February 2016	

TOTAL PROJECTED COST: \$7,617.00

Appendix F: Facility Maps

F-1: Signalized Intersections


F-2: Sidewalk Corridors

F-3: Transit Stops

City of Ocala
ADA Transition Plan
Signalized Intersections
January 2019



Kimley»Horn





Legend

-  Signalized Intersections
-  City Limits

City of Ocala
ADA Transition Plan
Sidewalk Corridors
January 2019



Kimley»Horn



Legend

-  Railroad Crossing
-  Sidewalk Corridors
-  City Limits


**City of Ocala
ADA Transition Plan
Transit Stops
January 2019**




Kimley»Horn



Legend

-  City-maintained Stops
-  County-maintained Stops
-  City Limits



Appendix G: Interlocal Agreement between City of Ocala and Marion County

Contract # TPO/17-013

INTERLOCAL AGREEMENT

THIS INTERLOCAL AGREEMENT is made and entered into this 17th day of October 2017, by and between the CITY OF OCALA, a municipal corporation existing under the laws of the State of Florida, hereinafter referred to as CITY, and MARION COUNTY, a political subdivision of the State of Florida, hereinafter referred to as COUNTY.

WHEREAS, the provision of adequate and effective public transportation services is an existing and growing problem in Marion County; and

WHEREAS, the public transportation system, SunTran, began operation on December 15, 1998, and has continued to provide the community with public transportation service; and

WHEREAS, the CITY and COUNTY are authorized by Section 163.01, Florida Statutes, to enter into Interlocal Agreements to make the most efficient use of their powers by cooperating with each other on a basis of mutual advantage and thereby to provide services and facilities in a manner that will accord best with geographic, economic, population and other factors influencing the needs and development of the local community.

NOW, THEREFORE, for and in consideration of the mutual terms, covenants and conditions to be complied with on the part of the respective parties hereto, it is agreed as follows:

SECTION 1 - PURPOSE OF THIS AGREEMENT

The purpose of this Agreement is to provide for public transportation services within the area of Marion County designated in the Transit Development Plan as modified or amended and to state the terms and conditions upon which cooperative funding shall be provided and an understanding between the Parties as to the manner in which the service will be provided.

SECTION 2 - ESTABLISHMENT OF POLICY BOARD

The Ocala/Marion County TPO shall serve as the policy board for the public transportation system. The TPO shall be responsible for establishment of all fares, service standards, rules and regulations of the system.

SECTION 3 - ESTABLISHMENT OF ADMINISTRATIVE AGENCY

The CITY shall serve as the administrative agency for the public transportation system. The CITY shall provide public transportation for the general public by the operation of revenue vehicles over designated routes on a fixed schedule. TPO staff shall be responsible for the day-to-day administration and oversight of the service. The TPO staff will provide the TPO quarterly reports outlining the ridership, revenues, expenses, and other information pertinent to the public transportation system.

SECTION 4 - CONTRACTUAL AUTHORITY FOR THE ADMINISTRATIVE AGENCY

The CITY, as administrator of the system, shall be authorized to apply for and receive grants-in-aid or other assistance from the Federal Government and/or the State of Florida. Said grants or other assistance shall be used to carry out the purposes of this Interlocal Agreement. The CITY shall also receive any funds provided by local entities for the financial support of the public transit system as described in this Interlocal Agreement.

The CITY is also authorized to enter into a management, operation, and maintenance contract with a private company to oversee the day-to-day operations of the public transportation system.

SECTION 5 - CAPITAL AND OPERATIONAL CONTRIBUTIONS

The CITY agrees to acquire the physical facilities (i.e. buses, signage, bus stop furnishings, etc.) that shall be required to operate a public transportation system. The CITY shall be the legal entity responsible for the operation and management of the public transportation system.

The CITY and COUNTY agree that the financial support for the purposes set forth in this Interlocal Agreement shall be borne by each of the Parties as follows: the CITY shall pay sixty (60) percent of any local monies required and the COUNTY shall provide forty (40) percent for any grant related to capital and operation. Local monies are defined as those necessary to match any State program (Block Grant, TRIP, CIGP or other programs that may be established) or Federal program (Section 5305(d), 5307, 5309, or other programs that may be established). In addition, other necessary funds, capital or operating, not covered by any grant program or other financial assistance shall be the responsibility of the CITY and COUNTY in the same manner as described above.

The funds for capital and operating costs shall be provided by the Parties to this Interlocal Agreement to the CITY on a quarterly basis.

All revenues derived from the operation of the transit system shall be utilized to reduce the operating costs of the system.

SECTION 6 - TERM AND RENEWAL OF INTERLOCAL AGREEMENT

This Interlocal Agreement shall be for the term of **October 1, 2017 to September 30, 2022**. Prior to the expiration of this Interlocal Agreement, the terms and conditions shall be reviewed by the TPO to determine continuation of the public transportation system. This Interlocal Agreement may be terminated by a simple majority vote of either party at least 180 days prior to the end of any fiscal year (October 1 - September 30). Notice of intent to terminate shall be

given to the other party within 2 weeks of said vote. The effective date of termination shall be the end of the then current fiscal year.


SECTION 7 - TRANSFER OR DISPOSITION OF PROPERTY

In the event of transfer of administrative agency duties to another entity or agency, all property acquired pursuant to this Interlocal Agreement will transfer to the newly designated administrative agency. In the event of termination of the public transportation system, the disposition or distribution of any properties or monies acquired under operation of this Agreement shall be on a proportionate rate basis, with the appropriate share to the Parties hereto being in direct proportion to each Party's contribution after required reimbursements to federal sources.


IN WITNESS WHEREOF, the undersigned parties have caused this Interlocal Agreement to be duly executed in their behalf on this 29th day of November, 2017.

BOARD OF COUNTY COMMISSION OF
MARION COUNTY, FLORIDA

By: 
Carl Zalak
Chairman, Marion County BOCC

Attest: 
David R. Ellspermann
Clerk of the Court

Approved as to form and legality:


Matthew G. Minter
County Attorney



CITY OF OCALA
By: 
Brent Malever
President, Ocala City Council

Attest: 
~~Angel B. Jacobs~~ Roseann J. Fusco
City Clerk Deputy City Clerk

Approved as to form and legality:


~~Patrick G. Gilligan~~ Robert W. Batsel, Jr.
City Attorney

ACCEPTED BY CITY COUNCIL
October 17, 2017
DATE
OFFICE OF THE CITY CLERK

Appendix H: Sample Action Log

City of Metropolis
ADA Self-Evaluation and Transition Plan
Action Log
10/15/2018

Facility Type	GPS ID	Project Name	Finding #	Self-Evaluation Finding	Cost Projection	Priority Value	Priority Rank	Funding Year	Year Completed
Building	1	Ashley's Place Child Advocacy Center	4	The maneuvering space on the pull side of the main entrance door is only 3 inches where a minimum of 18 inches is required.	\$ 3,000	2	High		
Building	17	Clearview Park Recreation Center	1	There are 15 parking spaces provided none of which are accessible parking spaces.	\$ 3,000	2	High		
Building	17	Clearview Park Recreation Center	2	There are 11 parking spaces provided none of which are accessible parking spaces. One is required for compliance and it must be a van accessible space.	\$ 3,000	2	High		
Building	5	Fire Hall #1	1	There are no accessible parking stalls provided in this parking lot. A total of 20 spaces are provided therefore 1 accessible space that is van accessible is required to be provided.	\$ 3,500	3	High		
Building	5	Fire Hall #1	2	The main entrance door into the facility requires a 2-1/2" step for entry.	\$ 1,500	3	High		
Building	6	Fire Hall #2	1	There are no accessible parking stalls provided in this parking lot. A total of 6 spaces are provided therefore 1 accessible space that is van accessible is required to be provided.	\$ 3,500	3	High		
Building	6	Fire Hall #2	2	The main entrance door into the facility requires a 6" step for entry.	\$ 1,500	3	High		
Building	10	Police Annex	5	The accessible route leading from the access aisle to the building entrance has a 9% running slope.	\$ 3,500	3	High		
Building	13	Rosemont House Museum	1	There is no accessible route to the main building. Stairs only access is provided.	\$ 5,000	3	High		
Building	13	Rosemont House Museum	12	The lanterns project more than 4 inches into the circulation path at 57" above ground surface.	\$ 650	3	High		
Building	13	Rosemont House Museum	20	There is a 6-5/8" step to get into the kitchen area of the carriage house.	\$ 3,000	3	High		
Building	1	Ashley's Place Child Advocacy Center	1	There are 10 parking spaces serving this facility none of which are accessible.	\$ 3,000	4	High		
Building	2	Metropolis Public Utilities Main Office	1	The access aisle has a 2.5% cross slope where a maximum of 1:48 (2.08%) is required.	\$ 3,000	4	High		
Building	2	Metropolis Public Utilities Main Office	2	The connection between the access aisle and the walkway has an abrupt change in level with grass growing along the connection.	\$ 300	4	High		
Building	2	Metropolis Public Utilities Main Office	5	The transaction counter is too high at 41-1/2".	\$ 2,000	4	High		
Building	2	Metropolis Public Utilities Main Office	7	The transaction counter is too high at 42-1/2".	\$ 2,000	4	High		
Building	2	Metropolis Public Utilities Main Office	9	The restroom 76" wide which is not large enough to accommodate a wheelchair turning space.	\$ 12,000	4	High		
Building	2	Metropolis Public Utilities Main Office	15	The restroom 76" wide which is not large enough to accommodate a wheelchair turning space.	\$ 12,000	4	High		
Building	2	Metropolis Public Utilities Main Office	24	The sink in the kitchenette is 36" high where 34" maximum is required. Additionally no knee or toe space is provided.	\$ 2,000	4	High		
Building	2	Metropolis Public Utilities Main Office	30	Exiting the Men's restroom only has a 4-1/2" maneuvering clearance on the pull side where a minimum of 18" is required.	\$ 1,500	4	High		
Building	2	Metropolis Public Utilities Main Office	32	The restroom 65" wide which is not large enough to accommodate a wheelchair turning space.	\$ 12,000	4	High		
Building	3	City Hall	4	The access aisle is missing at the accessible parking stall.	\$ 2,000	4	High		
Building	3	City Hall	5	The access aisle is missing at the accessible parking stall.	\$ 2,000	4	High		
Building	3	City Hall	7	The accessible parking space has a 7.0% cross slope where a maximum of 1:48 (2.08%) is required.	\$ 3,000	4	High		
Building	3	City Hall	9	The access aisle is missing at the accessible parking stall.	\$ 2,000	4	High		
Building	5	Fire Hall #1	16	The door opening does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	4	High		
Building	5	Fire Hall #1	17	The restroom is 60" wide which is not large enough to accommodate a wheelchair turning space.	\$ 8,000	4	High		
Building	5	Fire Hall #1	18	The door opening does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	4	High		
Building	5	Fire Hall #1	19	The restroom is 57" wide which is not large enough to accommodate a wheelchair turning space.	\$ 8,000	4	High		
Building	6	Fire Hall #2	13	There are 2 toilet compartments none of which are wheelchair accessible. 5% and a minimum of 1 toilet compartment must be wheelchair accessible.	\$ 3,000	4	High		
Building	6	Fire Hall #2	16	There are no accessible shower stalls provided.	\$ 2,500	4	High		
Building	7	Fire Hall #3	1	The access aisle is missing at the accessible parking stall.	\$ 700	4	High		
Building	7	Fire Hall #3	2	The accessible parking stall is not wide enough.	\$ 700	4	High		
Building	7	Fire Hall #3	12	The water closet's clear floor space is 38" wide to the edge of the lavatory.	\$ 3,000	4	High		
Building	7	Fire Hall #3	18	There are 2 toilet compartments neither of which are wheelchair accessible. 5% and a minimum of 1 toilet compartment must be wheelchair accessible.	\$ 3,000	4	High		
Building	8	Fire Hall #4	1	The accessible parking space has a 3.8% running slope where a maximum of 1:48 (2.08%) is required.	\$ 2,500	4	High		
Building	8	Fire Hall #4	2	The access aisle has a 4.2% running slope where a maximum of 1:48 (2.08%) is required.	\$ 2,500	4	High		
Building	10	Police Annex	1	The access aisle has a 3.8% running slope where a maximum of 1:48 (2.08%) is required.	\$ 3,000	4	High		
Building	10	Police Annex	2	The accessible parking space has a 3% running slope where a maximum of 1:48 (2.08%) is required.	\$ 3,000	4	High		
Building	10	Police Annex	3	The accessible parking stall is not wide enough for a van accessible parking stall.	\$ 300	4	High		

Facility Type	GPS ID	Project Name	Finding #	Self-Evaluation Finding	Cost Projection	Priority Value	Priority Rank	Funding Year	Year Completed
Building	10	Police Annex	6	The entrance is not accessible and is missing signage. An identification sign identifying that this entrance is not accessible and directional signage pointing in the direction to the accessible entrance is required. When a directional sign is required it should be located to minimize backtracking. In some cases this could mean locating a sign at the beginning of a route not just at the inaccessible entrances to a building.	\$ 250	4	High		
Building	10	Police Annex	8	The restroom is 6'-5" wide which is not large enough to accommodate a wheelchair turning space.	\$ 12,000	4	High		
Building	10	Police Annex	13	The door opening does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	4	High		
Building	10	Police Annex	14	The restroom is 35" wide which is not large enough to accommodate a wheelchair turning space.	\$ 12,000	4	High		
Building	10	Police Annex	16	The door opening does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	4	High		
Building	10	Police Annex	17	The restroom is 55" wide which is not large enough to accommodate a wheelchair turning space.	\$ 12,000	4	High		
Park Sidewalk	2006	Triple Creek Park	N/A	See facility report and GIS data for detailed sidewalk evaluation findings.	\$ 536,471	1	High		
Park Unsignalized Intersection	90000	Intersection of Triple Creek Park and Touchdown Dr (Lat. 36.4095; Long. -86.426)	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Triple Creek Park and Touchdown Dr (Lat. 36.4095; Long. -86.426)	\$ 30,000	2	High		
Park Unsignalized Intersection	90001	Intersection of Triple Creek Park Trail and Touchdown Dr (Lat. 36.4097; Long. -86.426)	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Triple Creek Park Trail and Touchdown Dr (Lat. 36.4097; Long. -86.426)	\$ 7,000	2	High		
Park Unsignalized Intersection	90002	Intersection of Triple Creek Park and driveway (Lat. 36.4081; Long. -86.427)	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Triple Creek Park and driveway (Lat. 36.4081; Long. -86.427)	\$ 16,000	2	High		
Park Unsignalized Intersection	90008	Intersection of Triple Creek Park and parking lot (Lat. 36.4137; Long. -86.424)	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Triple Creek Park and parking lot (Lat. 36.4137; Long. -86.424)	\$ 6,000	2	High		
Park Unsignalized Intersection	90009	Intersection of Triple Creek Park and midblock crossing (Lat. 36.4117; Long. -86.425)	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Triple Creek Park and midblock crossing (Lat. 36.4117; Long. -86.425)	\$ 18,000	2	High		
Park Unsignalized Intersection	90011	Intersection of Triple Creek Park and parking lot (Lat. 36.4116; Long. -86.425)	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Triple Creek Park and parking lot (Lat. 36.4116; Long. -86.425)	\$ 4,000	2	High		
Park Unsignalized Intersection	90013	Intersection of Triple Creek Park and parking lot (Lat. 36.4120; Long. -86.425)	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Triple Creek Park and parking lot (Lat. 36.4120; Long. -86.425)	\$ 10,000	2	High		
Park Unsignalized Intersection	90014	Intersection of Triple Creek Park and parking lot (Lat. 36.4124; Long. -86.425)	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Triple Creek Park and parking lot (Lat. 36.4124; Long. -86.425)	\$ 10,000	2	High		
Park Unsignalized Intersection	90015	Intersection of Triple Creek Park and parking lot (Lat. 36.4132; Long. -86.425)	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Triple Creek Park and parking lot (Lat. 36.4132; Long. -86.425)	\$ 3,000	2	High		
Park Unsignalized Intersection	90021	Intersection of Municipal Park and parking lot (Lat. 36.4038; Long. -86.438)	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Municipal Park and parking lot (Lat. 36.4038; Long. -86.438)	\$ 8,000	2	High		
Park Unsignalized Intersection	90023	Intersection of Municipal Park and driveway (Lat. 36.4028; Long. -86.439)	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Municipal Park and driveway (Lat. 36.4028; Long. -86.439)	\$ 9,000	2	High		
Park Unsignalized Intersection	90024	Intersection of Municipal Park and parking lot (Lat. 36.4034; Long. -86.436)	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Municipal Park and parking lot (Lat. 36.4034; Long. -86.436)	\$ 10,000	2	High		
Park Unsignalized Intersection	90039	Intersection of Long Hollow Golf Course and parking lot (Lat. 36.3881; Long. -86.487)	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Long Hollow Golf Course and parking lot (Lat. 36.3881; Long. -86.487)	\$ 8,000	2	High		
Park Unsignalized Intersection	90005	Intersection of Triple Creek Park Trail and parking lot (Lat. 36.4106; Long. -86.427)	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Triple Creek Park Trail and parking lot (Lat. 36.4106; Long. -86.427)	\$ 3,000	3	High		
Park Unsignalized Intersection	90006	Intersection of Triple Creek Park and Joseph Shafer Middle School	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Triple Creek Park and Joseph Shafer Middle School (Lat. 36.4077; Long. -86.435)	\$ 18,000	3	High		
Park Unsignalized Intersection	90010	Intersection of Triple Creek Park and parking lot (Lat. 36.4147; Long. -86.425)	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Triple Creek Park and parking lot (Lat. 36.4147; Long. -86.425)	\$ 3,000	3	High		
Park Unsignalized Intersection	90026	Intersection of Municipal Park and concession stand (Lat. 36.4023; Long. -86.435)	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Municipal Park and concession stand (Lat. 36.4023; Long. -86.435)	\$ 6,000	3	High		
Park Unsignalized Intersection	90027	Intersection of Clearview Park and parking lot (Lat. 36.3976; Long. -86.460)	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Clearview Park and parking lot (Lat. 36.3976; Long. -86.460)	\$ 3,000	3	High		
Signalized Intersection	3	Intersection of W Broadway/W Main St and Red River Rd/W Main St	N/A	See facility report and GIS data for detailed evaluation findings at intersection of W Broadway/W Main St and Red River Rd/W Main St	\$ 61,000	2	High		
Signalized Intersection	4	Intersection of W Main St and S Locust Ave	N/A	See facility report and GIS data for detailed evaluation findings at intersection of W Main St and S Locust Ave	\$ 55,000	2	High		
Signalized Intersection	6	Intersection of S Water Ave and Smith St	N/A	See facility report and GIS data for detailed evaluation findings at intersection of S Water Ave and Smith St	\$ 87,000	2	High		
Signalized Intersection	7	Intersection of E Main St and Boyers Ave	N/A	See facility report and GIS data for detailed evaluation findings at intersection of E Main St and Boyers Ave	\$ 71,000	2	High		
Signalized Intersection	16	Intersection of Maple St and Hancock St/Dan P. Herron	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Maple St and Hancock St/Dan P. Herron	\$ 118,000	2	High		
Building	1	Ashley's Place Child Advocacy Center	2	There is no accessible route to the play elements.	\$ 3,000	5	Medium		
Building	1	Ashley's Place Child Advocacy Center	3	There is no accessible route to the gazebo.	\$ 3,000	5	Medium		

Facility Type	GPS ID	Project Name	Finding #	Self-Evaluation Finding	Cost Projection	Priority Value	Priority Rank	Funding Year	Year Completed
Building	1	Ashley's Place Child Advocacy Center	9	There is no accessible route to the main area of the building which includes an open seating area the observation rooms boys' and girls' restrooms and the kitchen.	\$ 15,000	5	Medium		
Building	1	Ashley's Place Child Advocacy Center	10	The door opening does leading to the boys' and girls' restrooms is only 30" wide.	\$ 2,500	5	Medium		
Building	1	Ashley's Place Child Advocacy Center	13	The door opening leading into the conference room does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	5	Medium		
Building	1	Ashley's Place Child Advocacy Center	14	The door opening leading into the main office does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	5	Medium		
Building	1	Ashley's Place Child Advocacy Center	15	The maneuvering space on the pull side of the doors or gate does not adequately extend beyond the latch side of the door.	\$ 5,000	5	Medium		
Building	1	Ashley's Place Child Advocacy Center	17	The door opening leading into the kitchen area does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	5	Medium		
Building	2	Metropolis Public Utilities Main Office	11	The toilet is not located within the range allowed from the side wall or partition.	\$ 2,300	5	Medium		
Building	2	Metropolis Public Utilities Main Office	20	The maneuvering space on the pull side of the door 128 only has a 12" maneuvering clearance where a minimum of 18" is required.	\$ 2,500	5	Medium		
Building	2	Metropolis Public Utilities Main Office	22	The maneuvering space on the pull side of door 123 only has an 17" maneuvering clearance where a minimum of 18" is required.	\$ 2,500	5	Medium		
Building	2	Metropolis Public Utilities Main Office	34	The toilet is not located within the range allowed from the side wall or partition.	\$ 2,300	5	Medium		
Building	2	Metropolis Public Utilities Main Office	46	There are 12 doors throughout the warehouse that have door knob style hardware that requires grasping and twisting to operate.	\$ 4,500	5	Medium		
Building	2	Metropolis Public Utilities Main Office	58	Water and drain pipes under lavatories are not adequately insulated.	\$ 100	5	Medium		
Building	2	Metropolis Public Utilities Main Office	66	Water and drain pipes under lavatories are not adequately insulated.	\$ 100	5	Medium		
Building	3	City Hall	14	There is not enough space between the back wall and the front return wall of the elevator car. Elevator cars must provide 51 inches minimum between the back wall and the front return wall.	\$ 150,000	5	Medium		
Building	3	City Hall	15	The centerline of the car control buttons are too high to the top "Emergency Call" button at 53" above finished floor.	\$ -	5	Medium		
Building	3	City Hall	16	There are 16 doors on the basement level that have door hardware that requires grasping and twisting to operate.	\$ 6,000	5	Medium		
Building	3	City Hall	18	The coat racks (2) project more than 4 inches into the circulation path.	\$ 300	5	Medium		
Building	3	City Hall	19	The coat racks (2) are positioned too high for either a side or front approach.	\$ 200	5	Medium		
Building	3	City Hall	22	The ramp does not have handrails.	\$ 1,000	5	Medium		
Building	3	City Hall	30	The door opening does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	5	Medium		
Building	3	City Hall	37	The door opening does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	5	Medium		
Building	3	City Hall	38	The maneuvering space on the pull side of the door only has an 11" maneuvering clearance where a minimum of 18" is required.	\$ 2,500	5	Medium		
Building	3	City Hall	44	The door opening does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	5	Medium		
Building	3	City Hall	51	The door opening does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	5	Medium		
Building	3	City Hall	59	There are 55 doors throughout the first floor that are equipped with knob style door hardware requiring grasping and twisting to operate.	\$ 20,625	5	Medium		
Building	3	City Hall	70	There are not enough accessible toilet compartments. 5% and a minimum of 1 toilet compartment must be wheelchair accessible.	\$ 4,500	5	Medium		
Building	3	City Hall	75	The door opening does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	5	Medium		
Building	3	City Hall	76	The maneuvering space on the pull side of the door only has an 18" maneuvering clearance where a minimum of 18" is required.	\$ 2,500	5	Medium		
Building	3	City Hall	85	The transaction counter is too high at 40".	\$ 2,000	5	Medium		
Building	3	City Hall	88	The door opening does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	5	Medium		
Building	3	City Hall	89	The maneuvering space on the pull side of the door only has a 2" maneuvering clearance where a minimum of 18" is required.	\$ 2,500	5	Medium		
Building	3	City Hall	91	The door opening does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	5	Medium		
Building	3	City Hall	92	The maneuvering space on the pull side of the door only has a 2-1/2" maneuvering clearance where a minimum of 18" is required.	\$ 2,500	5	Medium		
Building	3	City Hall	99	There are 5 doors throughout the Mayor's office that have openings that do not provide at least 32 inches between the face of the door and the opposite stop.	\$ 12,500	5	Medium		
Building	3	City Hall	100	The door opening does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	5	Medium		
Building	3	City Hall	104	The transaction counter is too high at 42-3/8".	\$ 2,000	5	Medium		
Building	3	City Hall	107	There are 41 doors throughout the second floor that are equipped with knob style door hardware requiring grasping and twisting to operate.	\$ 15,375	5	Medium		

Facility Type	GPS ID	Project Name	Finding #	Self-Evaluation Finding	Cost Projection	Priority Value	Priority Rank	Funding Year	Year Completed
Building	3	City Hall	109	There is no accessible route to the council seating area.	\$ 2,000	5	Medium		
Building	3	City Hall	111	There are 2 door openings that do not provide at least 32 inches between the face of the door and the opposite stop.	\$ 5,000	5	Medium		
Building	3	City Hall	113	The door opening does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	5	Medium		
Building	3	City Hall	114	The maneuvering space on the pull side of the door only has a 19-1/2" maneuvering clearance where a minimum of 18" is required.	\$ 2,500	5	Medium		
Building	3	City Hall	120	The door opening does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	5	Medium		
Building	3	City Hall	128	There are 2 sets of doors leading into the Women's employee restroom. Neither of them have openings that provide at least 32 inches between the face of the door and the opposite stop.	\$ 5,000	5	Medium		
Building	3	City Hall	129	The maneuvering space on the pull side of the door only has a 2-1/2" maneuvering clearance where a minimum of 18" is required.	\$ 2,500	5	Medium		
Building	3	City Hall	135	The door opening does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	5	Medium		
Building	4	Farmers Market	5	The water and drain pipes under the lavatory are not adequately insulated.	\$ 100	5	Medium		
Building	4	Farmers Market	6	The toilet is not located within the range allowed from the side wall or partition.	\$ 2,300	5	Medium		
Building	4	Farmers Market	13	The water and drain pipes under the lavatory are not adequately insulated.	\$ 100	5	Medium		
Building	4	Farmers Market	14	The toilet is not located within the range allowed from the side wall or partition.	\$ 2,300	5	Medium		
Building	5	Fire Hall #1	6	The maneuvering space on the pull side of the door leading from reception only has a 9" maneuvering clearance where a minimum of 18" is required.	\$ 2,500	5	Medium		
Building	5	Fire Hall #1	8	There are 24 doors throughout the facility that have door hardware that requires grasping and twisting to operate.	\$ 9,000	5	Medium		
Building	5	Fire Hall #1	32	The exit door from the bay area has an opening that does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	5	Medium		
Building	6	Fire Hall #2	4	The door maneuvering clearance on the pull side of the door leading from the back area to the front lobby does not adequately extend beyond the latch side of the door.	\$ 2,500	5	Medium		
Building	6	Fire Hall #2	5	The door leading from the lobby area into the bay area is in a 12" alcove with no maneuvering clearance on the push side.	\$ 2,500	5	Medium		
Building	6	Fire Hall #2	6	There are approximately 6 doors throughout the facility with door operating hardware that requires grasping and twisting to operate.	\$ 2,250	5	Medium		
Signalized Intersection	17	Intersection of E Main St and Westland Ave	N/A	See facility report and GIS data for detailed evaluation findings at intersection of E Main St and Westland Ave	\$ 81,000	5	Medium		
Signalized Intersection	18	Intersection of W Broadway and N Locust Ave	N/A	See facility report and GIS data for detailed evaluation findings at intersection of W Broadway and N Locust Ave	\$ 103,000	5	Medium		
Signalized Intersection	19	Intersection of Nashville Pk and Wall St/Metropolis Plaza	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Nashville Pk and Wall St/Metropolis Plaza	\$ 21,000	5	Medium		
Signalized Intersection	20	Intersection of Nashville Pk and Village Green Dr	N/A	See facility report and GIS data for detailed evaluation findings at intersection of Nashville Pk and Village Green Dr	\$ 20,000	5	Medium		
Signalized Intersection	12	Intersection of E Broadway and N Water Ave	N/A	See facility report and GIS data for detailed evaluation findings at intersection of E Broadway and N Water Ave	\$ 65,000	7	Medium		
Signalized Intersection	15	Intersection of SR 174 (Long Hollow Pike) and Big Station Camp	N/A	See facility report and GIS data for detailed evaluation findings at intersection of SR 174 (Long Hollow Pike) and Big Station Camp	\$ 27,000	7	Medium		
Building	2	Metropolis Public Utilities Main Office	13	The mirror is mounted too high at 41-1/2" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	2	Metropolis Public Utilities Main Office	18	The mirror is mounted too high at 41" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	2	Metropolis Public Utilities Main Office	29	The mirror is mounted too high at 49" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	2	Metropolis Public Utilities Main Office	37	The mirror is mounted too high at 41" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	2	Metropolis Public Utilities Main Office	42	The mirror is mounted too high at 41" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	3	City Hall	34	The mirror is mounted too high at 48" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	3	City Hall	41	The mirror is mounted too high at 46-1/2" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	3	City Hall	48	The mirror is mounted too high at 48" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	3	City Hall	55	The mirror is mounted too high at 48" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	3	City Hall	62	The rear grab bar does not extend adequately past the centerline of the toilet on the wall side.	\$ 400	9	Low		
Building	3	City Hall	63	The toilet paper is not installed within the compliant range.	\$ 200	9	Low		
Building	3	City Hall	65	The mirror is mounted too high at 40-1/2" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	3	City Hall	71	The water and drain pipes under the lavatory are not adequately insulated. Water supply and drain pipes under lavatories and sinks shall be insulated or otherwise configured to protect against contact. There shall be no sharp or abrasive surfaces under lavatories and sinks.	\$ 150	9	Low		
Building	3	City Hall	72	The mirror is mounted too high. Mirrors must have the bottom edge of the reflecting surface a maximum of 40 inches above the floor if above a sink or counter. Mirrors not located above lavatories or countertops shall be installed with the bottom edge of the reflecting surface 35 inches maximum above the finish floor or ground.	\$ 1,500	9	Low		

Facility Type	GPS ID	Project Name	Finding #	Self-Evaluation Finding	Cost Projection	Priority Value	Priority Rank	Funding Year	Year Completed
Building	3	City Hall	79	The mirror is mounted too high at 48-1/2" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	3	City Hall	95	The mirror is mounted too high at 48" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	3	City Hall	117	The mirror is mounted too high at 48" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	3	City Hall	125	The mirror is mounted too high at 48-1/2" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	3	City Hall	132	The mirror is mounted too high at 49" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	3	City Hall	139	The mirror is mounted too high at 49" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	4	Farmers Market	10	The mirror is mounted too high at 52-1/2" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	4	Farmers Market	18	The mirror is mounted too high at 52-1/2" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	6	Fire Hall #2	15	The mirror is mounted too high at 48-1/2" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	8	Fire Hall #4	12	The accessible toilet compartment door is not self-closing.	\$ 100	9	Low		
Building	8	Fire Hall #4	20	The door exceeds the maximum pressure of 5 lb to open the door.	\$ 100	9	Low		
Building	8	Fire Hall #4	21	The compartment door is not self closing.	\$ 100	9	Low		
Building	10	Police Annex	31	The mirror is mounted too high at 54-1/2" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	11	Police Station	24	The mirror is mounted too high at 51-1/2" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	11	Police Station	25	The toilet seat cover dispenser is mounted too high.	\$ 200	9	Low		
Building	11	Police Station	26	The toilet paper dispenser is mounted too close to the top of the grab bar minimizing the gripping surface.	\$ 200	9	Low		
Building	11	Police Station	27	The paper towel dispenser's operation mechanism is too high off the floor.	\$ 200	9	Low		
Building	11	Police Station	29	The transaction counter is only 19" long and mounted too high at 43" above finished floor.	\$ 2,000	9	Low		
Building	11	Police Station	47	The coat hook is installed greater than 48 inches above the finished floor. Where a forward reach is unobstructed the high forward reach shall be 48 inches maximum above the finished floor.	\$ 100	9	Low		
Building	11	Police Station	65	The toilet seat cover dispenser is mounted too high at 58" above finished floor.	\$ 200	9	Low		
Building	11	Police Station	68	The mirror is mounted too high at 51-1/2" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	11	Police Station	73	The toilet seat cover dispenser is mounted too high at 58" above finished floor.	\$ 200	9	Low		
Building	11	Police Station	76	The mirror is mounted too high at 51-1/2" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	15	Civic Center	43	The mirror is mounted too high at 41" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	15	Civic Center	50	The mirror is mounted too high at 41" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	15	Civic Center	67	The coat hook is installed greater than 48 inches above the finished floor.	\$ 100	9	Low		
Building	15	Civic Center	74	The coat hook is installed greater than 48 inches above the finished floor.	\$ 100	9	Low		
Building	15	Civic Center	80	The top rim of the lavatory is too high.	\$ 2,000	9	Low		
Building	15	Civic Center	84	The hand dryer projects more than 4 inches into the path to the lavatory.	\$ 200	9	Low		
Building	15	Civic Center	85	The coat hook is installed greater than 48 inches above the finished floor.	\$ 100	9	Low		
Building	15	Civic Center	87	The threshold at the restroom door is broken and heaving.	\$ 300	9	Low		
Building	15	Civic Center	92	The hand dryer projects more than 4 inches into the path leading to the lavatory.	\$ 200	9	Low		
Building	15	Civic Center	98	The mirror is mounted too high at 41-1/2" to the bottom of the reflective surface.	\$ 100	9	Low		
Building	15	Civic Center	106	The mirror is mounted too high at 40-1/2" to the bottom of the reflective surface.	\$ 200	9	Low		
Building	1	Ashley's Place Child Advocacy Center	6	The threshold when exiting the door is 1-1/2" and 1-1/4" when entering the door from the outside.	\$ 400	11	Low		
Building	1	Ashley's Place Child Advocacy Center	16	The observation room contains storage items and/or supplies which obstruct the clear floor and/or turning space within the restroom.	\$ -	11	Low		
Building	1	Ashley's Place Child Advocacy Center	18	The sink in the kitchenette is 36" high where 34" maximum is required. Additionally no knee or toe space is provided.	\$ 2,000	11	Low		
Building	1	Ashley's Place Child Advocacy Center	19	The range controls are located such that operation require reaching across burners.	\$ 2,000	11	Low		
Building	1	Ashley's Place Child Advocacy Center	26	The door opening at the staff restroom does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	11	Low		
Building	1	Ashley's Place Child Advocacy Center	27	The threshold leading into the staff restroom is greater than 1/2 inch high.	\$ 500	11	Low		
Building	1	Ashley's Place Child Advocacy Center	28	The restroom is only 68" wide and has no compliant features.	\$ 15,000	11	Low		
Building	2	Metropolis Public Utilities Main Office	23	The transaction counter is too high at 41-3/8".	\$ 2,000	11	Low		
Building	2	Metropolis Public Utilities Main Office	44	The work surface is too high at 39" to the top of the counter.	\$ -	11	Low		
Building	2	Metropolis Public Utilities Main Office	45	The work surface is too high at 40" to the top of the counter.	\$ -	11	Low		
Building	2	Metropolis Public Utilities Main Office	49	The restroom 58" wide which is not large enough to accommodate a wheelchair turning space.	\$ 12,000	11	Low		
Building	2	Metropolis Public Utilities Main Office	51	The restroom 60" wide which is not large enough to accommodate a wheelchair turning space.	\$ 12,000	11	Low		
Building	2	Metropolis Public Utilities Main Office	53	The sink in the kitchenette is 35" high where 34" maximum is required. Additionally no knee or toe space is provided.	\$ 2,000	11	Low		
Building	2	Metropolis Public Utilities Main Office	56	There are no accessible showers in the locker room.	\$ 8,000	11	Low		
Building	2	Metropolis Public Utilities Main Office	57	There is no compliant bench in the locker room.	\$ 800	11	Low		
Building	2	Metropolis Public Utilities Main Office	64	There are no accessible showers in the locker room.	\$ 8,000	11	Low		
Building	2	Metropolis Public Utilities Main Office	65	There is no compliant bench in the locker room.	\$ 800	11	Low		
Building	2	Metropolis Public Utilities Main Office	70	The sink in the kitchenette is 36" high where 34" maximum is required.	\$ 2,000	11	Low		
Building	3	City Hall	11	A 6" step up is required to enter the building.	\$ 700	11	Low		
Building	3	City Hall	12	A 1" step is required to enter the building.	\$ 700	11	Low		
Building	3	City Hall	13	A 6-1/2" step is required to enter the building at the employee only entrance.	\$ 700	11	Low		
Building	3	City Hall	27	The sink in the basement lounge is 36" high where 34" maximum is required.	\$ 2,000	11	Low		

Facility Type	GPS ID	Project Name	Finding #	Self-Evaluation Finding	Cost Projection	Priority Value	Priority Rank	Funding Year	Year Completed
Building	3	City Hall	45	The landing at the door does not provide compliant latch side clearance.	\$ 3,000	11	Low		
Building	3	City Hall	46	There are 2 toilet compartments neither of which are wheelchair accessible. 5% and a minimum of 1 toilet compartment must be wheelchair accessible.	\$ 3,000	11	Low		
Building	3	City Hall	52	The landing at the door does not provide compliant latch side clearance.	\$ 3,000	11	Low		
Building	3	City Hall	53	There are 2 toilet compartments neither of which are wheelchair accessible. 5% and a minimum of 1 toilet compartment must be wheelchair accessible.	\$ 2,000	11	Low		
Building	3	City Hall	81	The sink in the break room is 36" high where 34" maximum is required.	\$ 2,000	11	Low		
Building	3	City Hall	82	The paper towel dispenser's operation mechanism is too high off the floor.	\$ 200	11	Low		
Building	3	City Hall	83	The door opening does not provide at least 32 inches between the face of the door and the opposite stop.	\$ 2,500	11	Low		
Building	3	City Hall	84	The sink in the kitchenette is 36" high where 34" maximum is required.	\$ 2,000	11	Low		
Building	3	City Hall	86	The work surface is too high at 40" above finished floor where a maximum of 34" above finished floor is required.	\$ 2,000	11	Low		
Building	3	City Hall	97	The sink in the break room 36" high where 34" maximum is required.	\$ 2,000	11	Low		
Building	3	City Hall	101	The restroom is not large enough to accommodate accessible fixtures and wheelchair turning space.	\$ -	11	Low		
Building	3	City Hall	102	The sink in the small break area is 36" high where 34" maximum is required. Additionally no knee or toe space is provided.	\$ 2,500	11	Low		
Building	3	City Hall	103	The microwave is not positioned correctly for either a side or front approach.	\$ 300	11	Low		
Building	3	City Hall	105	The sink in the kitchenette is 36" high where 34" maximum is required.	\$ 2,000	11	Low		
Building	3	City Hall	110	The sink in the kitchenette is 35-5/8" high where 34" maximum is required.	\$ 2,000	11	Low		
Building	5	Fire Hall #1	4	Compliant knee and toe clearance is not provided at the accessible table.	\$ -	11	Low		
Building	5	Fire Hall #1	5	The shelving unit projects more than 4 inches into the circulation path.	\$ 200	11	Low		
Building	5	Fire Hall #1	7	The vision light panel is mounted too high.	\$ 2,500	11	Low		
Building	5	Fire Hall #1	10	The coat hooks are installed greater than 48 inches above the finished floor.	\$ 100	11	Low		
Building	5	Fire Hall #1	11	The sink in the kitchenette is 36" high where 34" maximum is required. Additionally no knee or toe space is provided.	\$ 2,000	11	Low		
Building	5	Fire Hall #1	13	A 3" step down is required to exit the door at the kitchen area leading to employee only outside smoking area.	\$ 1,500	11	Low		
Building	5	Fire Hall #1	20	The shelf projects more than 4 inches into the circulation path.	\$ 200	11	Low		
Building	5	Fire Hall #1	21	There is no compliant bench in the locker room.	\$ 700	11	Low		
Building	5	Fire Hall #1	23	There are 3 toilet compartments none of which are wheelchair accessible. 5% and a minimum of 1 toilet compartment must be wheelchair accessible.	\$ 3,000	11	Low		
Building	5	Fire Hall #1	24	The rim of the urinal is too high.	\$ 1,350	11	Low		
Building	5	Fire Hall #1	25	Knee clearance at 27 inches off the floor is not 8 inches minimum deep.	\$ 2,500	11	Low		
Building	5	Fire Hall #1	26	The water and drain pipes under the lavatory are not adequately insulated.	\$ -	11	Low		
Building	5	Fire Hall #1	27	The faucet controls require twisting of the wrist.	\$ -	11	Low		
Building	5	Fire Hall #1	28	The mirror is mounted too high at 48" to the bottom of the reflective surface.	\$ 100	11	Low		
Building	5	Fire Hall #1	29	There are no accessible shower stalls.	\$ 3,500	11	Low		
Building	5	Fire Hall #1	30	The paper towel dispenser projects more than 4 inches into the circulation path.	\$ 400	11	Low		
Building	5	Fire Hall #1	31	The paper towel dispenser's operation mechanism is too high off the floor.	\$ -	11	Low		
Building	5	Fire Hall #1	33	The threshold is greater than 1/2 inch high.	\$ 500	11	Low		
Building	5	Fire Hall #1	34	The path in the bay area contains cross slopes greater than 2%.	\$ -	11	Low		
Building	6	Fire Hall #2	8	The sink in the kitchen area is 36" high where 34" maximum is required. Additionally no knee or toe space is provided.	\$ 2,000	11	Low		
Building	6	Fire Hall #2	9	The microwave is positioned too high for either a side or front approach.	\$ 500	11	Low		
Building	6	Fire Hall #2	10	The controls are located such that operation require reaching across burners.	\$ 2,000	11	Low		
Building	6	Fire Hall #2	19	The clothes rod hook is installed greater than 48 inches above the finished floor.	\$ 200	11	Low		
Building	6	Fire Hall #2	20	There is no compliant bench in the locker room.	\$ 700	11	Low		